

No.	Tank ID	PGA (g)	Diameter, D (m)	Height, H (m)	H / D	H Liq (m)	Pct Full	DS	Damage Observed	Remarks	Tank Anchors	Source
17	Holanda Chem Plant	0.35						1	No damage		UA	Spectra, Vol 7, B, 1991
18	Holanda Chem Plant	0.35						1	No damage		UA	Spectra, Vol 7, B, 1991
19	Holanda Chem Plant	0.35						1	No damage		UA	Spectra, Vol 7, B, 1991
20	Holanda Chem Plant	0.35						1	No damage		UA	Spectra, Vol 7, B, 1991
21	Holanda Chem Plant	0.35						1	No damage		UA	Spectra, Vol 7, B, 1991
22	Holanda Chem Plant	0.35						1	No damage		UA	Spectra, Vol 7, B, 1991
23	Holanda Chem Plant	0.35						1	No damage		UA	Spectra, Vol 7, B, 1991
24	Holanda Chem Plant	0.35						1	No damage		UA	Spectra, Vol 7, B, 1991
25	Holanda Chem Plant	0.35						1	No damage		UA	Spectra, Vol 7, B, 1991
26	Holanda Chem Plant	0.35						1	No damage		UA	Spectra, Vol 7, B, 1991
27	Transmerquim	0.35	8.66	8.66				3	EFB - severe, no leak	Built 1989	UA	Spectra, Vol 7, B, 1991
28	Transmerquim	0.35	8.66	8.66				3	EFB - severe, no leak	Built 1989	UA	Spectra, Vol 7, B, 1991
29	Transmerquim	0.35						2	Rocking, broken inlet/outlet pipe, loss of some contents		UA	Spectra, Vol 7, B, 1991
30	Transmerquim	0.35						1	No damage		UA	Spectra, Vol 7, B, 1991
31	Transmerquim	0.35						1	No damage		UA	Spectra, Vol 7, B, 1991
32	Transmerquim	0.35						1	No damage		UA	Spectra, Vol 7, B, 1991
33	Transmerquim	0.35						1	No damage		UA	Spectra, Vol 7, B, 1991
34	Transmerquim	0.35						1	No damage		UA	Spectra, Vol 7, B, 1991

No.	Tank ID	PGA (g)	Diameter, D (m)	Height, H (m)	H / D	H Liq (m)	Pct Full	DS	Damage Observed	Remarks	Tank Anchors	Source
35	Transmerquim	0.35						1	No damage		UA	Spectra, Vol 7, B, 1991
36	Transmerquim	0.35						1	No damage		UA	Spectra, Vol 7, B, 1991
37	Transmerquim	0.35						1	No damage		UA	Spectra, Vol 7, B, 1991
38	Transmerquim	0.35						1	No damage		UA	Spectra, Vol 7, B, 1991
<p>Comments</p> <p>Tanks 1 - 14 at Recope Refinery, Port of Moin, Costa Rica</p> <p>Spillage of oil from at least one tank was confined in a dike. This is arbitrarily assigned to tank 738 (DS=4)</p> <p>Holanda Chemical Plant. 2 of 12 tanks were damaged</p> <p>Transmerquim plant located next to Holanda. 2 of 12 tanks suffered EFB</p> <p>The level of ground shaking at these three sites was considered "moderate" but not instrumental recordings available</p> <p>Ground motion for Port of Moin, near Limon, was estimated based on mapped intensity MMI VIII = PGA 0.35g.</p>												

Table B-16. Costa Rica 1992 M7.5

No.	Tank ID	PGA (g)	Diameter, D (m)	Height, H (m)	H / D	H Liq (m)	Pct Full	DS	Damage Observed	Remarks	Tank Anchors	Source
1	BDVWA A	0.56	16.90	7.30	0.43	6.68	0.92	4	EFP around entire tank, failed at shell / bottom plate at 2 locations. 6" overflow pipe failed, lifted 2 feet out of ground. Tank shifted 3" laterally. Failure of side pipe	Welded steel, AWWA D100 1974, 0.25" shell, 0.25" bottom, 3/16" roof	UA	Cooper 1997, Ballantyne and Crouse 1997
2	BDVWA B	0.55	8.10	7.30	0.90	6.95	0.95	2	Minor damage		UA	Cooper 1997, Ballantyne and Crouse 1997
3	BDVWA C	0.55	18.10	7.30	0.40	6.89	0.94	2	Minor damage		UA	Cooper 1997, Ballantyne and Crouse 1997
4	BDVWA 10	0.55	9.90	4.90	0.49	4.45	0.91	2	Minor damage		UA	Cooper 1997, Ballantyne and Crouse 1997
5	BDVWA 22-A	0.54	9.90	4.90	0.49	4.45	0.91	2	Minor damage		UA	Cooper 1997, Ballantyne and Crouse 1997
6	BDVWA 22-B	0.54	9.90	4.90	0.49	4.45	0.91	2	Minor damage		UA	Cooper 1997, Ballantyne and Crouse 1997
7	BDVWA 22-C	0.54	14.00	4.90	0.35	4.45	0.91	2	Minor damage		UA	Cooper 1997, Ballantyne and Crouse 1997
8	BDVWA 22-D	0.54	22.30	4.90	0.22	4.42	0.90	2	Minor damage		UA	Cooper 1997, Ballantyne and Crouse 1997
9	BDVWA 34	0.55	6.40	4.90	0.77	4.48	0.91	2	Minor damage		UA	Cooper 1997, Ballantyne and Crouse 1997
10	HDWD 2 M.G.	0.15	36.60	7.30	0.20	U		1	No significant damage		UA	Cooper 1997, Wald 1998
11	HDWD R-7	0.15	25.90	7.30	0.28	U		1	No significant damage		UA	Cooper 1997, Wald 1998
12	HDWD R-8	0.15	10.00	7.30	0.73	U		1	No significant damage		UA	Cooper 1997, Wald 1998
13	HDWD R-14	0.20	21.30	5.50	0.26	U		1	No significant damage		UA	Cooper 1997, Wald 1998
14	HDWD R-15	0.19	22.90	7.30	0.32	U		1	No significant damage		UA	Cooper 1997, Wald 1998
15	HDWD R-2	0.15	25.90	7.30	0.28	U		1	No significant damage		UA	Cooper 1997, Wald 1998
16	HDWD R-3	0.20	25.90	7.30	0.28	U		1	No significant damage		UA	Cooper 1997, Wald 1998
17	HDWD R-4	0.20	9.10	7.30	0.80	U		1	No significant damage		UA	Cooper 1997, Wald 1998
18	HDWD R-5	0.20	7.90	7.30	0.92	U		1	No significant damage		UA	Cooper 1997, Wald 1998

No.	Tank ID	PGA (g)	Diameter, D (m)	Height, H (m)	H / D	H Liq (m)	Pct Full	DS	Damage Observed	Remarks	Tank Anchors	Source
19	HDWD Upper Ridge	0.10	13.10	7.30	0.56	U		1	No significant damage		UA	Cooper 1997, Wald 1998
20	HDWD Lower Ridge	0.10	5.50	4.9	0.89	U		1	No significant damage		UA	Cooper 1997, Wald 1998
21	HDWD Upper Fox	0.15	24.40	12.2	0.50	U		1	No significant damage		UA	Cooper 1997, Wald 1998
22	HDWD Lower Fox	0.15	10.90	4.9	0.45	U		1	No significant damage		UA	Cooper 1997, Wald 1998
23	HDWD Golden Bee	0.15	14.40	9.8	0.68	U		1	No significant damage		UA	Cooper 1997, Wald 1998
24	HDWD Homestead	0.10	11.80	7.3	0.62	U		1	No significant damage		UA	Cooper 1997, Wald 1998
25	HDWD Hospital Desert Gold	0.15	11.8	7.3	0.62	U		1	No significant damage		UA	Cooper 1997, Wald 1998
26	CSA 70-1	0.47	11.8	7.3	0.62	6.71	0.92	4	EFB all around, shell tearing, pullout of dresser couplings for 2 side attached pipes	Designed per API 12B, 1979, Bolted steel, 10 ga shell 10ga bottom plate	UA	Cooper 1997, Wald 1998
27	Beryl - SCWC	0.14	9.14	7.32	0.80	6.4	0.87	2	Small Leakage of bottom flange	Bolted	U	Ballantune and Crouse 1997
28	Basalt - SCWC	0.14	9.14	7.32	0.80	6.4	0.87	2	Failure of pipe through bottom penetration	Bolted	U	Ballantune and Crouse 1997
29	Arville-N - SCWC	0.14	8.93	12.65	1.42	11.28	0.89	2	Failure of pipe through bottom penetration	Welded (fillet)	U	Ballantune and Crouse 1997
30	Arville-S - SCWC	0.14	8.93	13.56	1.52	12.19	0.90	1	tank lateral movement	Welded	U	Ballantune and Crouse 1997
31	SCE Coolwater 1 of 3	0.53	83.2	15.2	0.18	15.2	1.00	1	No damage	API 650	U	Cooper 1997
32	SCE Coolwater 2 of 3	0.53	83.2	15.2	0.18	13.68	0.90	1	No damage	API 650	U	Cooper 1997

No.	Tank ID	PGA (g)	Diameter, D (m)	Height, H (m)	H / D	H Liq (m)	Pct Full	DS	Damage Observed	Remarks	Tank Anchors	Source
33	SCE Coolwater 3 of 3	0.53	67.2	14.5	0.22	1.45	0.10	1	No damage	API 650	U	Cooper 1997
<p>Comments</p> <p>Landers Mw 7.3 followed by Big Bear M 6.5 3 hours later</p> <p>All damage in this table due to Landers event</p> <p>BDVWA = Bighorn Desert View Water Agency. HDWD = Hi Desert Water District. CSA = San Bernardino County Service Area 70</p> <p>SCWC - 4 tanks in Barstow, CA</p>												

Table B-17. Landers 1992 M7.3

No.	Tank ID	PGA (g)	Diameter, D (m)	Height, H (m)	H / D	H Liq (m)	Pct Full	DS	Damage Observed	Remarks	Tank Anchors	Source
1	Van Nuys 1	0.55	8.80	14.60	1.66	7.90	0.54	1	Bolt shearing on tank walkway	Assumed between 1/3 and 2/3 full. API 650 1963	UA	Cooper 1997, Wald 1998
2	Van Nuys 2	0.55	11.00	13.70	1.25	6.85	0.50	1	Bolt shearing on tank walkway	Assumed between 1/3 and 2/3 full. API 650 1963	UA	Cooper 1997, Wald 1998
3	Van Nuys 3	0.55	20.40	14.60	0.72	7.30	0.50	1	Bolt shearing on tank walkway	Assumed between 1/3 and 2/3 full. API 650 1963	UA	Cooper 1997, Wald 1998
4	Van Nuys 4	0.55	21.90	14.60	0.67	7.30	0.50	1	Bolt shearing on tank walkway	Assumed between 1/3 and 2/3 full. API 650 1963	UA	Cooper 1997, Wald 1998
5	Van Nuys 5	0.55	4.60	9.10	1.98	4.55	0.50	1	Bolt shearing on tank walkway	Assumed between 1/3 and 2/3 full. API 650 1963	UA	Cooper 1997, Wald 1998
6	1 of 5	0.55	3.20	10.00	3.13	9.50	0.95	1	Minor damage to walkway	Assumed nearly full	UA	Cooper 1997, Wald 1998
7	2 of 5	0.55	3.20	10.00	3.13	9.50	0.95	1	Minor damage to walkway	Assumed nearly full	UA	Cooper 1997, Wald 1998
8	3 of 5	0.55	3.20	10.00	3.13	0.00	0.00	1	Minor damage to walkway	Assumed nearly full	UA	Cooper 1997, Wald 1998
9	4 of 5	0.55	3.20	10.00	3.13	0.00	0.00	1	Minor damage to walkway	Assumed nearly full	UA	Cooper 1997, Wald 1998
10	5 of 5	0.55	3.20	10.00	3.13	0.00	0.00	1	No significant damage	Assumed other 3 tanks out of service had no liquid	UA	Cooper 1997, Wald 1998
11	A Sepulveda Terminal	0.90	19.80	11.00	0.56	7.32	0.67	1	Slight sloshing	API 650, mid-60s	UA	Cooper 1997, Wald 1998, EERI 1995
12	B	0.90	21.90	11.00	0.50	3.66	0.33	1	Slight sloshing	API 650, mid-60s	UA	Cooper 1997, Wald 1998, EERI 1995
13	C	0.90	18.30	11.00	0.60	3.66	0.33	1	Slight sloshing	API 650, mid-60s	UA	Cooper 1997, Wald 1998, EERI 1995
14	AG 1	0.90	3.70	7.30	1.97	7.30	1.00	1	Minor paint cracks	UL 142, mid-60s	A	Cooper 1997, Wald 1998
15	AG 2	0.90	3.70	7.30	1.97	0.00	0.00	1	No significant damage	UL 142, mid-60s	A	Cooper 1997, Wald 1998
16	Aliso 1	0.70	12.20	7.30	0.60	U	0.75	5	Collapse	Bolted, mostly full based on amount of leakage	U	Cooper 1997, Wald 1998

No.	Tank ID	PGA (g)	Diameter, D (m)	Height, H (m)	H / D	H Liq (m)	Pct Full	DS	Damage Observed	Remarks	Tank Anchors	Source
17	Aliso 2	0.70	12.20	7.30	0.60	U		3	Photo shows some shell damage	Bolted, may be damaged	U	Cooper 1997, Wald 1998
18	Aliso 3	0.70	12.20	7.30	0.60	U		1	No significant damage	Bolted	U	Cooper 1997, Wald 1998
19	Aliso 4	0.70	12.20	7.30	0.60	U		1	No significant damage	Bolted	U	Cooper 1997, Wald 1998
20	Amir	0.90	12.80	9.09	0.71	U		3	EFB		U	Ballantyne and Crouse 1997, Wald 1998
21	Lautenschlager 1	0.90	19.00	6.7	0.35	5.94	0.89	1	No significant damage	Welded, 1965	U	Cooper 1997, Ballantyne and Crouse 1997 Wald 1998
22	Lautenschlager 2	0.90	19.00	7.3	0.38	5.94	0.81	1	No significant damage	Welded 1988	U	Cooper 1997, Ballantyne and Crouse 1997 Wald 1998
23	Tapo	0.90	40.00	9.8	0.25	8.69	0.89	1	No significant damage	Welded 1963	U	Cooper 1997, Ballantyne and Crouse 1997 Wald 1998
24	Crater East	0.75	9.10	7.3	0.80	6.13	0.84	1	No significant damage	Survived, pct full from text in Cooper	U	Cooper 1997, Ballantyne and Crouse 1997 Wald 1998
25	Crater West	0.75	11.90	7.3	0.61	6.13	0.84	1	No significant damage	Survived, pct full from text in Cooper	U	Cooper 1997, Ballantyne and Crouse 1997 Wald 1998
26	Alamo	0.70	30.50	6.3	0.21	6.25	0.99	1	No significant damage	Welded 1964	U	Cooper 1997, Ballantyne and Crouse 1997 Wald 1998
27	Katerine	0.90	12.00	7.3	0.61	6.25	0.86	4	Failed by EFB with loss of contents	Bolted, built 1964	U	Cooper 1997, Ballantyne and Crouse 1997 Wald 1998
28	Rebecca North	0.85	12.00	7.3	0.61	6.86	0.94	4	Failed by EFB with loss of contents	Bolted, built 1964	U	Cooper 1997, Ballantyne and Crouse 1997 Wald 1998
29	Rebecca South	0.85	12.00	7.3	0.61	6.86	0.94	4	Failed by EFB with loss of contents	Bolted, built 1964	U	Cooper 1997, Ballantyne and Crouse 1997 Wald 1998

No.	Tank ID	PGA (g)	Diameter, D (m)	Height, H (m)	H / D	H Liq (m)	Pct Full	DS	Damage Observed	Remarks	Tank Anchors	Source
30	Sycamore North	0.70	9.10	7.3	0.80	5.03	0.69	4	Failed by EFB with loss of contents	Bolted, built 1964	U	Cooper 1997, Ballantyne and Crouse 1997 Wald 1998
31	Sycamore South	0.70	9.10	7.3	0.80	5.03	0.69	4	Failed by EFB with loss of contents	Bolted, built 1964	U	Cooper 1997, Ballantyne and Crouse 1997 Wald 1998
32	SCWC 1 of 4	0.70	15.80	9.8	0.62	U	0.99	1	Survived	Welded	U	Cooper 1997, Wald 1998
33	SCWC 2 of 4	0.70	15.80	9.8	0.62	U		1	Survived	Welded	U	Cooper 1997, Wald 1998
34	SCWC 3 of 4	0.70	27.40	9.8	0.36	U		1	Survived	Welded	U	Cooper 1997, Wald 1998
35	SCWC 4 of 4	0.70	39.00	9.8	0.25	U		1	Survived	Welded	U	Cooper 1997, Wald 1998
36	LADWP Topanga	0.40	11.00	9	0.82	8.08	0.90	2	Replaced broken inlet / outlet valve. Loss of contents	Pct full from B&C. Welded steel, built 1936	UA	Cooper 1997, Ballantyne and Crouse 1997, Brown et al 1995
37	LADWP Zelzah	0.50	21.30	12.2	0.57	9.85	0.81	2	Roof collapsed, local buckling at top, broken valve. Loss of contents	Pct full from B&C. Welded steel built 1948	UA	Cooper 1997, Ballantyne and Crouse 1997, Brown et al 1995
38	LADWP Mulholland	0.40	15.80	10.2	0.65	0	0.00	2	overflow pipe pulled away. Loss of contents	Pct full from B&C. Welded steel built 1931	UA	Cooper 1997, Ballantyne and Crouse 1997, Brown et al 1995
39	LADWP Beverly Glen	0.50	30.50	12.3	0.40	U		2	Roof collapsed, local buckling, dresser coupling pulled out. Loss of contents	Riveted, built 1932. Wood roof replaced with hypalon bladder	UA	Cooper 1997, Brown et al 1995
40	MWD Jensen Clearwell	0.70	42.67	12.19	0.29	11.67	0.96	1	No tank damage		UA	Cooper 1997, Ballantyne and Crouse 1997, Brown et al 1995
41	LADWP Coldwater	0.30	30.48	12.19	0.40	U		2	Roof shifted and collapsed, inlet / outlet pipe failure. Loss of contents	Riveted built 1925. Wood roof shifted and collapsed.	UA	Ballantyne and Crouse 1997, Brown et al 1995
42	LADWP Granada High	1.00	16.80	10.7	0.64	9.66	0.90	5	Tank collapsed and tank removed	Riveted built 1929. Same tank was damaged in the 1971 San Fernando EQ	UA	Cooper 1997, Ballantyne and Crouse 1997, Brown et al 1995

No.	Tank ID	PGA (g)	Diameter, D (m)	Height, H (m)	H / D	H Liq (m)	Pct Full	DS	Damage Observed	Remarks	Tank Anchors	Source
43	LADWP Alta Vista 1	0.60	16.46	8.78	0.53	8.84	1.01	1	No tank damage	Riveted built 1929	UA	Cooper 1997, Ballantyne and Crouse 1997, Brown et al 1995
44	LADWP Alta Vista 2	0.60	28.96	11.13	0.38	9.3	0.84	1	No tank damage	Welded steel, built 1954. Assumed same pga as Alta Vista 1	UA	Cooper 1997, Ballantyne and Crouse 1997, Brown et al 1995
45	LADWP Alta View	0.30	19.81	12.95	0.65	12.5	0.97	1	Settlement		UA	Ballantyne and Crouse 1997, Brown et al 1995
46	LADWP Kittridge 3	0.30	57.90	15.54	0.27	U		1	No tank damage	Welded built 1973	UA	Ballantyne and Crouse 1997, Brown et al 1995
47	LADWP Kittridge 4	0.30	57.90	15.54	0.27	U		1	No tank damage	Welded built 1987	UA	Ballantyne and Crouse 1997, Brown et al 1995
48	LADWP Corbin	0.43	47.50	9.1	0.19	7.62	0.84	2	Minor drain line damage, partially buried	Welded built 1987	UA	Cooper 1997, Ballantyne and Crouse 1997, Brown et al 1995
49	Donick	0.30	37.43	7.32	0.20	6.86	0.94	1	No tank damage		UA	Ballantyne and Crouse 1997, Brown et al 1995
50	Santa Clarita	0.56	24.38	12.19	0.50	11.89	0.98	4	EFB, roof damage	Assumed same PGA as Magic Mountain tanks (also located at Valencia)	U	Cooper 1997, Ballantyne and Crouse 1997, Wald 1998
51	Valencia Round Moutain	0.56	40.30	9.8	0.24	9.07	0.93	1	No tank damage	AWWA D100	U	Cooper 1997, Ballantyne and Crouse 1997, Wald 1998
52	Hasley	0.50	36.60	12.2	0.33	11.29	0.93	1	No tank damage	AWWA D100	U	Cooper 1997, Wald 1998
53	Magic Mountain 2	0.56	22.30	7.3	0.33	6.1	0.84	U	Damaged by outflow of MM 1	Bolted, 1975	U	Cooper 1997, Ballantyne and Crouse 1997, Wald 1998
54	Magic Mountain 1	0.56	18.30	7.3	0.40	6.1	0.84	5	Complete failure, bottom shell torn at base, collapse	Bolted, 1971	U	Cooper 1997, Ballantyne and Crouse 1997, Wald 1998
55	Magic Mountain 3	0.56	24.40	9.8	0.40	9.07	0.93	1	No damage, tank partially buried 2.5 feet	AWWA D100. Welded with external roof rafters	U	Cooper 1997, Ballantyne and Crouse 1997, Wald 1998

No.	Tank ID	PGA (g)	Diameter, D (m)	Height, H (m)	H / D	H Liq (m)	Pct Full	DS	Damage Observed	Remarks	Tank Anchors	Source
56	Presley	0.50	21.30	9.8	0.46	9.07	0.93	1	No damage	AWWA D100	U	Cooper 1997, Wald 1998
57	4 Million	0.55	45.70	9.1	0.20	8.42	0.93	1	No damage	AWWA D100	U	Cooper 1997, Wald 1998
58	Seco	0.43	22.30	7.3	0.33	6.75	0.92	1	No damage	AWWA D100	U	Cooper 1997, Wald 1998
59	Larwin	0.55	18.30	12.2	0.67	9.75	0.80	5	Complete failure, EFB, tie down straps pulled, lifted foundation, nozzle tear outs	AWWA D100 1986. Straps 3/8"x3" at 4" On Center.	A	Cooper 1997, Wald 1998, EERI 1995
60	Poe	0.55	27.40	9	0.33	8.33	0.93	2	Roof rafter damage, sagging roof, no EFB	AWWA D100	U	Cooper 1997, Wald 1998
61	Paragon	0.43	22.30	9.8	0.44	9.07	0.93	1	No damage	AWWA D100	U	Cooper 1997, Wald 1998
62	Newhall 1	0.63	18.29	9.14	0.50	8.23	0.90	5	EFB, collapse, piping damage. Tank failed	Welded	UA	Cooper 1997, Wald 1998, EERI 1995
63	Newhall 2	0.63	12.20	9.8	0.80	8.82	0.90	3	Broken piping, EFB, Foundation settling	Built 1954, welded	UA	Cooper 1997, Wald 1998, EERI 1995
64	Newhall 3	0.63	12.20	9.8	0.80	8.82	0.90	3	Broken piping, EFB, Foundation settling	Built 1954, welded	UA	Cooper 1997, Wald 1998, EERI 1995
65	Newhall 4	0.63	12.20	9.8	0.80	8.82	0.90	3	Broken piping, EFB, Foundation settling, Roof rafters pulled out	Built 1962, AWWA	UA	Cooper 1997, Wald 1998, EERI 1995
66	Newhall 5	0.63	19.50	9.8	0.50	8.82	0.90	4	Roof rafter damage, EFB, inlet/outlet piping sheared	Built 1962. DS changed from 3 to 4	UA	Cooper 1997, Wald 1998, EERI 1995
67	Newhall 6	0.63	6.10	6.1	1.00	5.49	0.90	5	EFB, piping failure, plate failure, Tank replaced	Built 1960s	UA	Cooper 1997, Wald 1998, EERI 1995
68	Newhall 7	0.63	27.40	9.8	0.36	8.82	0.90	2	Roof shell seam opened, rafters fell, no EFB	Built 1975. Bottom course t=0.5"	UA	Cooper 1997, Wald 1998, EERI 1995
69	Newhall 8	0.63	18.30	7.3	0.40	6.57	0.90	2	Roof rafters pulled away from the shell, roof damage		UA	Cooper 1997, Wald 1998
70	Newhall 10	0.63	24.40	12.2	0.50	10.98	0.90	1	No apparent damage	Built 1989, AWWA	UA	Cooper 1997, Wald 1998

Comments

City of Simi Water District. 34 tanks in District, about 10 had damage. All damaged tanks were at east end of District (closer to fault). None of these tanks are in the table above

Simi: one tank had a failed underdrain pipe. Visual inspection of 2 tanks showed them unanchored, likely all were unanchored. This data not in above table

SCWC = Southern California Water Company

LADWP = Los Angeles Department of Water and Power

Tanks 51 - 61 are part of the Valencia Water Company

Tanks 62-70 are all welded, built to AWWA D100 or similar criteria

8 Prestressed concrete circular tanks in region with strong shaking (>0.2g) (6 buried or partially buried) performed well, built 1958-1992

There were other steel tanks at industrial sites which had EFB, which are not reported in this table

Tanks A, B, C, AG1, AG2 are at the Sepulveda terminal

Table B-18. Northridge 1994 M6.7

No.	Tank ID	PGA (g)	Diameter, D (m)	Height, H (m)	H / D	H Liq (m)	Pct Full	DS	Damage Observed	Remarks	Tank Anchors	Source
1	Fuel Pier Yard. Small craft refuel tank	0.20	10.04	15.06	1.50	7.53	0.50	1			A	Hashimoto 1989
2	Power Plant #3, Tank 4	0.20	5.44	8.15	1.50	6.12	0.75	1			A	Hashimoto 1989
3	Power Plant #3, Tank 5	0.20	5.44	8.15	1.50	6.12	0.75	1			A	Hashimoto 1989
4	Las Ventanas Power Plant	0.25	6.08	9.12	1.50	6.84	0.75	1		Capacity estimated	A	Hashimoto 1989
5	Las Ventanas Power Plant	0.25	6.08	9.12	1.50	6.84	0.75	1		Capacity estimated	A	Hashimoto 1989
6	Las Ventanas Power Plant	0.25	6.08	9.12	1.50	6.84	0.75	1		Capacity estimated	A	Hashimoto 1989
7	LVPP Oil storage day tank	0.25	9.30	13.94	1.50	10.46	0.75	1		Capacity estimated	A	Hashimoto 1989
8	LVPP Oil storage day tank	0.25	9.30	13.94	1.50	10.46	0.75	1		Capacity estimated	A	Hashimoto 1989
9	Kettleman Gas Compressor Stn Lube Oil Fuel Tank 2	0.20	2.85	4.27	1.50	3.21	0.75	1			A	Hashimoto 1989
10	Kettleman Gas Compressor Stn Lube Oil Fuel Tank 3	0.20	2.85	4.27	1.50	3.21	0.75	1			A	Hashimoto 1989
11	Kettleman Gas Compressor Stn Lube Oil Fuel Tank 6	0.20	2.85	4.27	1.50	3.21	0.75	1			A	Hashimoto 1989
12	Pleasant Valley Pump Station Surge Tower	0.56	6.31	48.37	7.66	36.27	0.75	2	All anchor bolts stretched 1.5". No leaks	Anchored with 1.5" diameter J bolts. PGA from nearby recording	A	Hashimoto 1989
13	San Lucas Canal Pump Station 17-R Surge Tank	0.35	2.85	5.93	2.08	4.45	0.75	4	Tank rocked, stretched or broken most anchors. 24" pipeline failed, likely loss of contents	Average tank dimensions. PGA = 0.35g is average for all pump stations, this one had more damage and may have had more PGA	A	Hashimoto 1989
14	Union Oil Butane Plant Diesel Fuel Oil Tank	0.60	2.42	3.63	1.50	2.72	0.75	1			A	Hashimoto 1989
15	Union Oil Butane Plant Diesel Fuel Oil Tank	0.60	2.42	3.63	1.50	2.72	0.75	1			A	Hashimoto 1989
16	Humboldt Bay 3 Condensate Storage Tank	0.30	4.56	7.99	1.75	5.99	0.75	1		Aluminum tank	A	Hashimoto 1989
17	Humboldt Bay 3 Condensate Storage Tank	0.25	4.56	7.99	1.75	5.99	0.75	1		Aluminum tank	A	Hashimoto 1989
18	Sandia Fuel Oil Tank	0.25	7.43	14.85	2.00	11.14	0.75	3	All 20 Wejit anchors failed. Elephant foot buckling without leak		A	Hashimoto 1989
19	Asososca Lake Surge Tank	0.50	4.86	21.40	4.40	14.70	0.67	2	Stretched 16 anchor bolts, no	Capacity estimated	A	Hashimoto 1989

No.	Tank ID	PGA (g)	Diameter, D (m)	Height, H (m)	H / D	H Liq (m)	Pct Full	DS	Damage Observed	Remarks	Tank Anchors	Source
20	Sendai Refinery Fire Water Storage Tank	0.28	11.71	17.57	1.50	15.24		2	loss of contents Anchor bolts stretched or pulled 1 to 6 inches, some leaking at a valve, no buckling or rapid loss of water	Capacity estimated. Shell t = 3/8" est., btoom plate = .25" est. 14 1.25" diam anchor bolts A307, attached by chairs	A	Hashimoto 1989
21	Caxton Paper Mill Chip storage silo	0.40	11.31	16.96	1.50	12.72	0.75	1		Capacity estimated	A	Hashimoto 1989
22	Caxton Paper Mill Hydrogen Peroxide Tank	0.40	2.64	3.95	1.50	2.97	0.75	1		Capacity estimated	A	Hashimoto 1989
23	Caxton Paper Mill Secondary Bleach Tower	0.40	5.44	8.15	1.50	6.85	0.84	1		Capacity estimated	A	Hashimoto 1989
24	New Zealand Distillery Bulk Storage Tank #2	0.50	7.48	5.61	0.75	4.71	0.84	1		Capacity estimated	A	Hashimoto 1989
25	New Zealand Distillery Bulk Storage Tank #5	0.50	4.59	3.44	0.75	2.58	0.75	1		Capacity estimated	A	Hashimoto 1989
26	New Zealand Distillery Bulk Storage Tank #6	0.50	4.59	3.44	0.75	2.58	0.75	1		Capacity estimated	A	Hashimoto 1989
27	New Zealand Distillery Bulk Storage Tank #7	0.50	8.77	6.58	0.75	4.93	0.75	1		Capacity estimated	A	Hashimoto 1989
28	New Zealand Distillery Receiver Tank #9	0.50	3.32	2.49	0.75	1.87	0.75	1		Capacity estimated	A	Hashimoto 1989
29	Whakatane Board Mills Pulp Tank	0.30	7.84	11.76	1.50	8.82	0.75	1		Capacity estimated	A	Hashimoto 1989
30	Whakatane Board Mills Pulp Tank	0.30	7.84	11.76	1.50	8.82	0.75	1		Capacity estimated	A	Hashimoto 1989
31	Whakatane Board Mills Pulp Tank	0.30	7.84	11.76	1.50	8.82	0.75	1		Capacity estimated	A	Hashimoto 1989
32	Glendale power plant Distilled Water tank 1A	0.28	3.62	5.42	1.50	4.07	0.75	1			A	Hashimoto 1989
33	Glendale power plant Distilled Water tank 1B	0.28	3.62	5.42	1.50	4.07	0.75	1			A	Hashimoto 1989
34	Glendale power plant Distilled Water tank 2	0.28	4.01	6.01	1.50	4.51	0.75	1		Capacity estimated	A	Hashimoto 1989
35	Glendale power plant Fuel oil day tank #1	0.28	3.62	5.42	1.50	4.07	0.75	1			A	Hashimoto 1989
36	Pasadena Power plant Unit B1 distilled water tank	0.20	7.28	10.92	1.50	8.19	0.75	1		Capacity estimated	A	Hashimoto 1989

No.	Tank ID	PGA (g)	Diameter, D (m)	Height, H (m)	H / D	H Liq (m)	Pct Full	DS	Damage Observed	Remarks	Tank Anchors	Source
37	Pasadena Power plant Unit B2 distilled water tank	0.20	7.78	9.56	1.23	8.54	0.89	1		A36. t= 5/16" lower course, 1/4" upper course, 1/4" bottom plate. 10 1.25" diam anchor bolts A307 using chairs	A	Hashimoto 1989
38	Pasadena Power plant Unit B3 distilled water tank	0.20	5.46	13.92	2.55	12.19	0.88	1		A283 Gr B. t= 5/16" lower course, 1/4" upper course, .375" bottom plate. 24 1.5" diam. Anchor bolts A307 using chairs	A	Hashimoto 1989
39	Pasadena Power plant Unit B1 distilled water tank	0.17	7.28	10.92	1.50	8.19	0.75	1		Capacity estimated	A	Hashimoto 1989
40	Pasadena Power plant Unit B2 distilled water tank	0.17	7.78	9.56	1.23	8.54	0.89	1	No damage	A36. t= 5/16" lower course, 1/4" upper course, 1/4" bottom plate. 10 1.25" diam anchor bolts A307 using chairs	A	Hashimoto 1989
41	Pasadena Power plant Unit B3 distilled water tank	0.17	5.48	13.92	2.55	12.19	0.88	1	No damage	A283 Gr B. t= 5/16" lower course, 1/4" upper course, .375" bottom plate. 24 1.5" diam. Anchor bolts A307 using chairs	A	Hashimoto 1989
<p>Comments</p> <p>Tanks 1 - 3. Adak 1986. Tanks 4 - 8. Chile 1985. Tanks 9 - 15. Coalinga 1983. Tank 16. Ferndale 1975. Tank 16. Ferndale 1975.</p> <p>Tank 18. Greenville 1980. Tank 19. Managua 1972. Tank 20. Miyagi-ken-ogi 1978. Tanks 21 - 31. New Zealand 1987. Tanks 32 - 38 San Fernando 1971. Tanks 39 - 41 Whittier 1987.</p> <p>Most tanks at least 50% full at time of earthquake. Unless otherwise specified in Hashimoto, set at 75% full</p>												

Table B-19. Anchored Tanks, Various Earthquakes

Abbreviation	Description
A	Anchored
API	American Petroleum Institute (API 650 code)
AWWA	American Water Works Association (AWWA D100 code)
D	Diameter. For most tanks, the diameter dimension is the inside diameter of the tank
DS	Damage State. See text for descriptions. May be from 1 to 5
EERI	Earthquake Engineering Research Institute
EFB	Elephant Foot Buckling
g	acceleration of gravity (=32.2 ft / sec / sec)
ga	gage thickness
H	Height. Generally the height from the top of the floor to the overflow level. The actual tank may be higher (above the overflow level)
I/O	Inlet / outlet pipe
Liq	Height of Liquid. The estimated (sometimes known) height of fluid contents at the time of the earthquake
m	meter. Note: most tanks in these tables are actually sized to the nearest foot. The metric conversion here does not infer accuracy to the exact dimension in feet.
MMI	Modified Mercalli Intensity
Pct Full	The percent full of the tank (= H Liq / H)
PGA	Peak Ground Acceleration in g
U	Unknown
UA	Unanchored
Z	Design level peak ground acceleration

Table B-20. Legend for Tables B-8 through B-19

B.6 Fragility Curve Fitting Procedure

The empirical data in Tables B-8 through B-18 are assembled into one database. Fragility curves are then fitted into this dataset.

Fragilities were developed using the complete tank database as follows:

- A subset of the complete database was developed for only those tanks with the attributes desired. If a particular tank did not have the attribute, then it was excluded from the analysis.
- The tanks were “binned” into nine PGA bins. Each bin was for a range of 0.1g, with the exception of 0.71 to 0.90g and 0.91g to 1.20g. The higher g bins were wider as there were fewer tanks in these PGA ranges. The PGA for each bin was set at the average of the PGA values for each tank in that bin. The percent of tanks reaching or exceeding a particular damage state was calculated for each bin.
- A lognormal fragility curve was calculated for each of the four damage state ranges. For example, a fragility curve was calculated for all tanks that reached damage state 2 (DS2) or above, DS3 or above, DS4 or above and DS5. The fragility curve uses the median acceleration to reach that damage state or above and a lognormal dispersion parameter, β . The “best fit” fragility curve was selected by performing a least square regression for all possible fragility curves in the range of $A=0.01g$ to $5.00g$ (in $0.01g$ steps) and $\beta=0.01$ to 0.80 (in 0.01 steps).

- Since an unequal number of tanks are in each bin, the analysis was performed using just an unweighted regression analysis with nine data points for the nine bins, and also a weighted regression analysis in which the number of data points in each bin reflect the actual number of tanks in each bin. The weighted analysis is considered a better representation. Using the data in Table 5-9, 263 tanks are in the 0.16g bin and just 10 tanks are in the 1.18g bin. In the weighted analysis, the 0.16g bin is given about 26 times more weight in the regression analysis.

B.7 Analytical Formulation for Steel Tank Fragility Curves

Section 5.7 of Part 1 presents representative fragility curves for various classes of water tanks: steel, concrete, wood, elevated. The procedures used to develop analytical or stress-based fragility curves is described in some detail by Bandpadhyay et al [1993] and Kennedy et al [1989]. See Section 5.8 of Part 1 for references.

Section B.7 provides some examples to show how analytically based fragility curves can be developed for specific tank geometries.

Steel tank with a wood-framed roof (see [Figure B-1](#)). The tank is 75 feet in diameter and 32 feet high. Maximum water depth is 31 feet above the base plate, with a maximum capacity of 1 million gallons. The tank wall thickness is sized to achieve a 15,000 psi hoop tensile stress under normal static conditions. The tank is supported in a reinforced concrete ring beam with embedded hold-down anchors spaced at 6.5 feet intervals around the circumference of the tank.

The wood framed roof consists of 3/4 inch plywood sheathing supported by 3-by-12 radial joists at 4-feet on-center and by 4 x 12 radial beams. The beams are supported by the perimeter of the tank and by interior pipe columns.

The following calculations are based on developing the overturning moment for the tank. Minor adjustments to the calculations to account for inner and outer radius, etc. are left for detailed design. See AWWA D100 [AWWA] for the nomenclature used in this example.

$R = 37.5$ feet (tank radius)

$L = 32$ feet (tank height)

$H = 31$ feet (water height)

$t = 0.375$ inches (weighted average over height)

$E = 29,000$ ksi (modulus of elasticity, steel)

$\rho = 0.490$ kcf (density of steel, kip per cubic foot)

$H/R = 0.827$

$t/R = 0.000833$

From Figure C.1 of ASCE [1984), $e_f = 0.05$, $e_s = 0.15$, $e_a = 0.465$.

For the tank filled with water, the impulsive first mode frequency is 7.1 Hz, following ASCE 1984 procedures. Note that a slightly different frequency would be computed using AWWA D100 simplified rules.

The convective first mode frequency is 0.19 Hz using equation (7-8) of ASCE [1984].

The shell has four 8-foot high courses. The bottom course has $t = 0.5$ inches, the second course has $t = 0.375$ inches, and the top two courses have $t = 0.25$ inches. Note that the t to be used in calculating the fundamental impulsive frequency is weighted over the height with a parabolic weighting function. More detailed analysis can be performed to refine the first mode frequency if the situation warrants.

Note that the top course t need only be 0.104 inches thick if the shell is designed using hoop stress as the only criteria. Some tank owners specify that $t = 0.25$ inches is the minimum.

The average dead weight of the wooden roof is assumed to be 10 pounds per square foot. $W_r = 10$ psf. $W_r = 44.2$ kips. $X_r = 33$ feet.

The dead weight of the tank shell is 0.449 kips per linear foot of circumference. $W_s = 0.449$ klf. $W_s = 105.8$ kips. $X_s = 13.45$ feet.

The weight of water when the tank is full (31 foot depth) is $W_w = 1.934$ ksf. $W_w = 8,546$ kips.

The total weight of roof, water and shell is $W_t = 8,546$ kips.

Following AWWA D100:

$$W1/W_t = 0.47. X1/H = 0.38 \text{ (impulsive component)}$$

$$W1 = 4,017 \text{ kips, } X1 = 11.78 \text{ feet}$$

$$W2/W_t = 0.51. X2/H = 0.58 \text{ (convective component)}$$

$$W2 = 4,358 \text{ kips. } X2 = 17.98 \text{ feet.}$$

To establish the overturning moment for purposes of assessing elephant foot buckling, the following assumptions are made:

- A 'SRSS' combination of the impulsive and convective components is assumed to be the best fit. Current codes use an absolute sum method, which will generally overpredict the true maximum overturning moment by a slight amount.
- The spectral acceleration of the convective mode is assumed to be 10% of the impulsive mode. This is a simplified generalization, and will depend upon the actual shape of the response spectra for the tank-specific site. However, this simplification is reasonable for many situations, and allows the estimation of the overturning moment to be a function of only one spectral ordinate.
- For purposes of developing a fragility curve, the input demand will be the 5% damped spectral ordinate at the impulsive mode frequency.

$$OTM = \sqrt{\left[\frac{S_{ai}}{g} (W_s X_s + W_r X_r + W_1 X_1) \right]^2 + \left[\frac{S_{ac}}{g} (W_2 X_2) \right]^2}$$

Using the above values, OTM = 50,810 foot-pounds times (Sai)/(g) where Sai = 5% damped spectral acceleration at the impulsive mode frequency, and g is in the same units as Sai.

Using the allowable compressive stresses for the lowest course shell (t = 0.5 inch) based on AWWA D100 Section 13.3.3.4.1(1991 edition):

fa = 2.14 ksi - ignoring internal water pressure

delta fc = 5.16 ksi - increase in compressive allowable to reflect internal hoop pressure

fc = 6.29 ksi - includes the effect of internal hoop pressure, plus 1.33 seismic increase factor

The overturning moment to reach fc = 6.29 ksi is M = 164,385 kip-feet. As the actual OTM is 50,810 kip-feet for a 1g spectral acceleration at 7.1 Hz, the required spectral acceleration needed to reach the code-limit fc is 3.24g (=164,385/50,810).

Table B-21 summarizes the various overstrength factors and uncertainties that are implied in the above calculations.

Factor	F	β_u	β_r
F_strength	1.5	0.05	0.05
F_ductility	1.0	0.0	0.0
F_workmanship	1.0	0.15	0.0
F_damping	1.0	0.1	0.1
F_period	1.0	0.2	0.1
F_model	0.75	0.25	0.2
F_total	1.13	0.37	0.25

Table B-21. Probabilistic Factors for Sample Steel Tank – Elephant Foot Buckling

F_total is the multiplicative sum of the various items under column F. Note that the strength value of 1.5 factors in that the true dynamic buckling capacity is estimated at 50% higher than the code-specified value. The value of 0.75 recognizes that the modeling approach taken here may have underestimated the true seismic forces by 25%. Tcantilever beam model is only a crude representation of the complex state of response of a tank shell that is subject to uplift, and may not predict the true highest compressive stress; vertical earthquake issues were ignored, etc. Also note that in this calculation for elephant foot buckling, there is no obvious analytical justification for the code-specified Rw values from 3.5 to 4.5. The above calculation is to predict the onset of buckling, and there is some margin before a buckle extends far enough to rupture the steel. This depends on the ductility of the steel, the lack of stress discontinuities that would be impacted by the buckle and the dynamic behavior of the tank, which would tend to limit the formation of the buckle if the overturning moment is due to high-frequency loading. Note that in the manhole location in Figure B-1, a tear could be expected at only moderate buckled deformation.

β_u total is the square root of the sum of the squares of the β_u column, = 0.37. β_r total is the square root of the sum of the squares of the β_r column, = 0.25. See Section B.2 for a further

description. The beta values represent uncertainty and randomness in the calculation above, but assume perfect knowledge of the ground motion response spectra. Beta total for the tank only is 0.45, which is the square root of the sum of the squares of β_u and β_r .

If the ground motion beta is 0.40, and if the user wishes to compute a single overall beta, then β_u would increase to 0.55 and the total beta would be $\beta_t = 0.60$.

The overall fragility curve for this damage state would be: A (median) = 3.65g (5% spectral acceleration) and $\beta_t = 0.60$.

In a similar manner, this tank should be checked for other damage states such as roof damage due to water sloshing, in which the tank remains functional but sustains large repair costs; anchor bolt damage due to uplift forces, in which the tank remains functional but sustains small repair costs; bottom plate-to-bottom course weld damage caused by uplift once anchor bolts are stretched or fail, in which the tank is non-functional and sustains moderate repair costs; damage to the top courses of the shell from excessive roof damage, in which the tank remains partially functional and sustains moderately high repair costs; sliding of the tank, leading to damage of the attached pipes, in which the tank is non-functional and sustains moderate repair costs.

B.8 References

American Water Works Association, *Welded Steel Tanks for Water Storage*, AWWA Standard D100, Denver, Colorado.

ATC, *Earthquake Damage Evaluation Data for California*, ATC 13, Applied Technology Council, 1985.

Ballantyne, D., Crouse, C., *Reliability and Restoration of Water Supply Systems for Fire Suppression and Drinking Following Earthquakes*, prepared for National Institute of Standards and Technology, NIST GCR 97-730, 1997.

Bandyopadhyay, K., Cornell, A., Costantino, C., Kennedy, R.P., Miller, C. and Veletsos, A., *Seismic Design and Evaluation Guidelines for The Department of Energy high-Level Waste Storage Tanks and Appurtenances*, Brookhaven National Laboratory, BNL 52361, Jan. 1993.

Brown, K., Rugar, P., Davis, C., Rulla, T., "Seismic Performance of Los Angeles Water Tanks, Lifeline Earthquake Engineering," in *Proceedings, 4th US Conference*, ASCE, TCLEE Monograph No. 6, San Francisco, 1995.

Cooper, T. W., *A Study of the Performance of Petroleum Storage Tanks During Earthquakes, 1933-1995*, prepared for the National Institute of Standards and Technology, Gaithersburg, MD, June 1997.

EERI, "Loma Prieta Reconnaissance Report," *Earthquake Spectra*, Earthquake Engineering Research Institute, Supplement to Vol. 6, May 1990.

Haroun, M., "Behavior of Unanchored Oil Storage Tanks: Imperial Valley Earthquake," *Journal of Technical Topics in Civil Engineering*, ASCE, Vol. 109, No. 1, April 1983.

Hashimoto, P.S., and Tiong, L.W., *Earthquake Experience Data on Anchored Ground Mounted Vertical Storage Tanks*, EPRI Report NP-6276, March 1989.

HAZUS, *Earthquake Loss Estimation Methodology*, National Institute of Building Sciences, prepared by Risk Management Solutions, Menlo Park, California, 1997.

Kennedy, R. P. and Kassawara, R. P., "Seismic Evaluation of Large Flat-Bottomed Tanks," *Second Symposium on Current Issues Related to Nuclear Power Plant Structures, Equipment, and Piping with Emphasis on Resolution of Seismic Issues in Low-Seismicity Regions*, EPRI NP-6437-D, May 1989.

McCann, M., Sauter, F., and Shah, H.C., "A Technical Note on PGA-Intensity Relationship with Applications to Damage Estimation," *BSSA*, Vol. 7, No. 2, pp 631-637, 1980.

O'Rourke, M. and So, P., "Seismic Behavior of On-Grade Steel Tanks; Fragility Curves," in *Optimizing Post-Earthquake Lifeline System Reliability*, ed. W. Elliott and P. McDonough, Technical Council on Lifeline Earthquake Engineering, Monograph No. 16, ASCE, Aug. 1999.

Scawthorne, C., and Khater, M., *A Model Methodology for Assessment of Seismic Vulnerability and Impact of Disruption of Water Supply Systems*, C. Rojahn, Principal Investigator, Applied Technology Council, ATC-25-1, 1992.

So, Pak, *Seismic Behavior of On-Grade Steel Tanks; Fragility Curves*, thesis submitted to the Graduate Faculty of Rensselaer Polytechnic Institute, RPI, Troy, NY, April 1999.

Wald, J., Quitariano, V., Heaton, T., Kanamori, H., and Scrivner, C., TRINET Shakemaps: Rapid Generation of Peak Ground Motion and Intensity Maps for Earthquakes in Southern California, *Earthquake Spectra*, Oct. 1998.

B.9 Figures




Figure B-1. Elevation of Example Tank

C. Commentary – Tunnels

Section C.1 describes two sets of fragility curves: those in HAZUS and those in ATC-13.

Sections C.2 through C.5 provide information on the performance of tunnels in past earthquakes.

Section C.6 provides the complete tunnel database, including analyses of tunnels by liner attribute.

C.1 Tunnel Fragility Curves – Prior Studies

C.1.1 HAZUS Fragility Curves

The HAZUS computer program [HAZUS, 1997] includes a number of fragility curves for tunnels. These are provided for ground shaking and ground failure hazards in the form of landslides or fault offset.

For ground shaking hazards, data from post earthquake reconnaissance of 68 tunnels [Dowding and Rozen, 1978] were reduced to establish fragility parameters. [Figure C-1](#) shows the empirical dataset; Table C-1 provides the specific values; Table C-1 was prepared as follows:

- The tunnel locations in the Dowding and Rozen study were identified. For each earthquake, the distance from the tunnel to the causative fault was determined. A suitable attenuation model was used—at the median level of shaking, such as using equation 3.3—to estimate the peak horizontal ground motion at the tunnel location.
- Three damage states could be assessed: none, slight and moderate. Descriptions of the damage states are as follows: Slight Damage—minor cracking of tunnel liner, minor rock falls, spalling of shotcrete or other supporting materials; Moderate Damage—moderate cracking of tunnel liner and rock falls.
- The empirical data was binned into three groups – tunnels with no observed damage, tunnels with minor damage and tunnels with moderate damage.
- The mean and standard deviation were computed for each bin. These are reported directly beneath the empirical data.
- The lognormal median and beta values were computed directly from the mean and standard deviation values as shown in the bottom of Table C-1.

Approximately 17% of the tunnels were reportedly in competent rock; the remaining were in sheared or broken rock, soil or unknown ground conditions. Tunnels were constructed between 1800 and 1960. For the most part, older tunnels represent poor-to-average construction quality, although the data does not specifically segregate tunnels with respect to quality of construction. For each tunnel, the peak horizontal ground acceleration was established using empirical attenuation relationships based on the distance from the earthquake epicenter to the site.

Tunnel Number	PGA - with No Damage
1	0.075
2	0.075
3	0.08
4	0.08
5	0.08
6	0.079
7	0.99
8	0.1
9	0.12
10	0.12
11	0.13
12	0.13
13	0.14
14	0.14
15	0.145
16	0.15
17	0.16
18	0.16
19	0.16
20	0.16
21	0.165
22	0.165
23	0.17
24	0.18
25	0.185
26	0.185
27	0.19
28	0.19
29	0.19
30	0.19
31	0.2
32	0.21
33	0.21
34	0.22
35	0.22
36	0.22
37	0.24
38	0.24
39	0.31
Mean	0.1834
Std Dev	0.1429

Tunnel Number	PGA - With Slight Damage
1	0.185
2	0.195
3	0.225
4	0.230
5	0.250
6	0.260
7	0.300
8	0.305
9	0.420
10	0.460
11	0.550
12	0.550
13	0.580
14	0.580
15	0.720
Mean	0.3873
Std Dev	0.1738

Tunnel Number	PGA - With Moderate Damage
1	0.255
2	0.340
3	0.420
4	0.480
5	0.482
6	0.510
7	0.520
8	0.525
9	0.550
10	0.560
11	0.590
12	0.620
13	0.640
14	0.690
Mean	0.5130
Std Dev	0.1163

Tunnel Number	PGA - Portal Damage Only
1	0.515

Source Data
 Dowding, C.H. and Rozen, A.,
 "Damage to Rock Tunnels from Earthquake Shaking"
 Journal of the Geotechnical Engineering Division, ASCE, Feb. 1978

Damage State	Mean	Std Dev	CoVariance	Beta**2	Beta	A=-0.5 * BETA**2	Median = Mean * exp(A)
None	0.1834	0.1429	0.779	0.474	0.689	-0.2370	0.145
Minor	0.3873	0.1738	0.449	0.183	0.428	-0.0917	0.353
Moderate	0.5130	0.1163	0.227	0.050	0.224	-0.0251	0.500

Table C-1. Raw Data – Tunnel Fragility Curves

EQID	CASE	EQNAME	DATE	Mw	TNAME	OWNER	FUN	LINER SYSTEM	ROCK SOIL	COVER (M)	PGA (G)	DS	REFERENCE, NOTES
1	1-1	San Francisco, CA	18/4/06	7.8	SF #1	SPRR	RR	4	R	24	0.41	1	Sharma & Judd, 1991
2	1-2	San Francisco, CA	18/4/06	7.8	SF #3	SPRR	RR	4	R	46	0.41	1	Sharma & Judd, 1991
3	1-3	San Francisco, CA	18/4/06	7.8	SF #4	SPRR	RR	4	R	24	0.43	1	Sharma & Judd, 1991
4	1-4	San Francisco, CA	18/4/06	7.8	SF #5	SPRR	RR	4	R	24	0.45	2	Sharma & Judd, 1991
5	1-5	San Francisco, CA	18/4/06	7.8	Corte M. T,	NPC	RR	1	R	60	0.38	1	Sharma & Judd, 1991
6	1-6	San Francisco, CA	18/4/06	7.8	Pilarcitos Res #1	SFWD	WT	4	R	68	0.65	1-3	Schussler, H., 1906
7	1-7	San Francisco, CA	18/4/06	7.8	Pilarcitos Res #2	SFWD	WT	4	R	152	0.65	1-3	Schussler, H., 1906
8	1-8	San Francisco, CA	18/4/06	7.8	Pilarcitos Res #3	SFWD	WT	4	R	137	0.69	1-3	Schussler, H., 1906
9	2-1	Kanto, Japan	1/10/27	7.9	Nagoye	Nat. RW	RR	1		30	0.40	2	Sharma & Judd, 1991
10	2-2	Kanto, Japan	1/10/27	7.9	Meno-Kamiana	Nat. RW	RR	4	R	17	0.60	3	Sharma & Judd, 1991
11	2-3	Kanto, Japan	1/10/27	7.9	Yonegami Yama	Nat. RW	RR	4		50	0.66	2	Sharma & Judd, 1991
12	2-4	Kanto, Japan	1/10/27	7.9	Shimomaki Matsu	Nat. RW	RR	4		29	0.69	3	Sharma & Judd, 1991
13	2-5	Kanto, Japan	1/10/27	7.9	Happon-Matzu	Nat. RW	RR	1	S	20	0.73	3	Sharma & Judd, 1991
14	2-6	Kanto, Japan	1/10/27	7.9	Nagasha-Yama	Nat. RW	RR	4-5		90	0.73	3	Sharma & Judd, 1991
15	2-7	Kanto, Japan	1/10/27	7.9	Hakone #1	Nat. RW	RR	1		61	0.44	2	Sharma & Judd, 1991
16	2-8	Kanto, Japan	1/10/27	7.9	Hakone #3	Nat. RW	RR	1		46	0.56	3	Sharma & Judd, 1991
17	2-9	Kanto, Japan	1/10/27	7.9	Hakone #4	Nat. RW	RR	1		46	0.54	2	Sharma & Judd, 1991
18	2-10	Kanto, Japan	1/10/27	7.9	Hakone #7	Nat. RW	RR	1	R	31	0.63	3	Sharma & Judd, 1991
19	2-11	Kanto, Japan	1/10/27	7.9	Yose	Nat. RW	RR	1	R	20	0.33	4	Sharma & Judd, 1991
20	2-12	Kanto, Japan	1/10/27	7.9	Doki	Nat. RW	RR	4			0.25	4	Sharma & Judd, 1991
21	2-13	Kanto, Japan	1/10/27	7.9	Namuya	Nat. RW	RR	5		75	0.52	4	Sharma & Judd, 1991
22	3-1	Kern County, CA	21/7/52	7.4	Saugus	SPRR	RR	1	R	40	0.06	1	Sharma & Judd, 1991
23	3-2	Kern County, CA	21/7/52	7.4	San Francisquito	SPRR	RR	1	R	160	0.08	1	Sharma & Judd, 1991
24	3-3	Kern County, CA	21/7/52	7.4	Elizabeth	SPRR	RR	1	R	250	0.10	1	Sharma & Judd, 1991
25	3-4	Kern County, CA	21/7/52	7.4	Antelope	SPRR	RR	1	R	30	0.16	1	Sharma & Judd, 1991
26	4-1	Alaska	27/3/64	8.4	Whittier #1		RR	1	R	400	0.22	2	Sharma & Judd, 1991
27	4-2	Alaska	27/3/64	8.4	Whittier #2		RR	1	R	350	0.21	1	Sharma & Judd, 1991
28	4-3	Alaska	27/3/64	8.4	Seward #1		RR	1	R	20	0.25	1	Sharma & Judd, 1991
29	4-4	Alaska	27/3/64	8.4	Seward #2		RR	1	R	20	0.25	1	Sharma & Judd, 1991
30	4-5	Alaska	27/3/64	8.4	Seward #3		RR	1	R	20	0.25	1	Sharma & Judd, 1991
31	4-6	Alaska	27/3/64	8.4	Seward #4		RR	1	R	20	0.25	1	Sharma & Judd, 1991
32	4-7	Alaska	27/3/64	8.4	Seward #5		RR	1	R	20	0.25	1	Sharma & Judd, 1991
33	4-8	Alaska	27/3/64	8.4	Seward #6		RR	1	R	20	0.25	1	Sharma & Judd, 1991
34	5-1	San Fernando, CA	9/3/75	6.6	San Fernando	MWD	WT	5-6-7	S	45	0.69	2	Sharma & Judd, 1991

EQID	CASE	EQNAME	DATE	Mw	TNAME	OWNER	FUN	LINER SYSTEM	ROCK SOIL	COVER (M)	PGA (G)	DS	REFERENCE, NOTES
35	5-2	San Fernando, CA	9/3/75	6.6	Tehachapi #1	SPRR	RR	1	R	30	0.04	1	Sharma & Judd, 1991
36	5-3	San Fernando, CA	9/3/75	6.6	Tehachapi #2	SPRR	RR	1	R	30	0.04	1	Sharma & Judd, 1991
37	5-4	San Fernando, CA	9/3/75	6.6	Tehachapi #3	SPRR	RR	1	R	30	0.04	1	Sharma & Judd, 1991
38	5-5	San Fernando, CA	9/3/75	6.6	Saugus	SPRR	RR	1	R	40	0.30	1	Sharma & Judd, 1991
39	5-6	San Fernando, CA	9/3/75	6.6	San Francisquito	SPRR	RR	1	R	160	0.24	1	Sharma & Judd, 1991
40	5-7	San Fernando, CA	9/3/75	6.6	Elizabeth	SPRR	RR	1	R	250	0.15	1	Sharma & Judd, 1991
41	5-8	San Fernando, CA	9/3/75	6.6	Antelope	SPRR	RR	1	R	30	0.10	1	Sharma & Judd, 1991
42	5-9	San Fernando, CA	9/3/75	6.6	Pacoima Dam SpillwayTunnels, CA		WT	1	R	43	0.69	2	Sharma & Judd, 1991
43	6-1	Loma Prieta, CA	17/10/89	7.1	Fort Baker-Berry	NPS	HW	5	R	61	0.04	1	COE, NPS
44	6-2	Loma Prieta, CA	17/10/89	7.1	Presidio Park	Caltrans	HW	6	R	22	0.04	1	Yashinsky, 1998
45	6-3	Loma Prieta, CA	17/10/89	7.1	Alameda Creek Div	SFWD	WT			300	0.12	1	SFWD
46	6-4	Loma Prieta, CA	17/10/89	7.1	Coast Range	SFWD	WT	5	R	240	0.09	1	SFWD
47	6-5	Loma Prieta, CA	17/10/89	7.1	Pulgas	SFWD	WT	5	R	92	0.09	1	SFWD
48	6-6	Loma Prieta, CA	17/10/89	7.1	Irvington	SFWD	WT	5	R	122	0.10	1	SFWD
49	6-7	Loma Prieta, CA	17/10/89	7.1	Crystal Spr Bypass	SFWD	WT	5-6-7	R	76	0.09	1	SFWD
50	6-8	Loma Prieta, CA	17/10/89	7.1	Downtown S.F.	Caltrain	RR		R		0.05	1	
51	6-9	Loma Prieta, CA	17/10/89	7.1	Stanford Linear Collider	SU	AC	5	R		0.25	1	Rose, 1990; Fisher, 1989
52	6-10	Loma Prieta, CA	17/10/89	7.1	Lomita Mall			5	S		0.14	1	Kaneshiro, 1989
53	6-11	Loma Prieta, CA	17/10/89	7.1	Santa Teresa	SCVWD	WT	7	R		0.26	1	SCVWD
54	6-12	Loma Prieta, CA	17/10/89	7.1	Tunnel #5	SC,BT.PRR	RR	3	R		0.40	1	SC,BT,PR
55	6-13	Loma Prieta, CA	17/10/89	7.1	Tunnel #6	SC,BT.PRR	RR	3	R		0.28	1	SC,BT,PR
56	6-14	Loma Prieta, CA	17/10/89	7.1	Caldecott	Caltrans	HW	6	R	243	0.04	1	Yashinsky, 1998
57	6-15	Loma Prieta, CA	17/10/89	7.1	MacArthur	Caltrans	HW		R	46	0.04	1	Yashinsky, 1998
58	6-16	Loma Prieta, CA	17/10/89	7.1	Stanford	SFWD	WT	5-7	R	23	0.14	1	SFWD
59	6-17	Loma Prieta, CA	17/10/89	7.1	Hillsborough	SFWD	WT	5-7	R	62	0.08	1	SFWD
60	6-18	Loma Prieta, CA	17/10/89	7.1	Sunol Aqud. #1	SFWD	WT	5	R		0.09	1	SFWD
61	6-19	Loma Prieta, CA	17/10/89	7.1	Sunol Aqud. #2	SFWD	WT	5	R		0.09	1	SFWD
62	6-20	Loma Prieta, CA	17/10/89	7.1	Sunol Aqud. #3	SFWD	WT	5	R		0.09	1	SFWD
63	6-21	Loma Prieta, CA	17/10/89	7.1	Sunol Aqud. #4	SFWD	WT	5	R		0.09	1	SFWD
64	6-22	Loma Prieta, CA	17/10/89	7.1	Sunol Aqud. #5	SFWD	WT	5	R		0.09	1	SFWD
65	7-1	Petrolia, CA	25/4/92	6.9	Tunnel #40	NCRR	RR	5	S		0.13	1	NCRR
66	7-2	Petrolia, CA	25/4/92	6.9	Tunnel #39	NCRR	RR	5-3	R		0.25	1	NCRR
67	7-3	Petrolia, CA	25/4/92	6.9	Tunnel #38	NCRR	RR	5-3	R		0.21	2	NCRR

EQID	CASE	EQNAME	DATE	Mw	TNAME	OWNER	FUN	LINER SYSTEM	ROCK SOIL	COVER (M)	PGA (G)	DS	REFERENCE, NOTES
68	7-4	Petrolia, CA	25/4/92	6.9	Tunnel #37	NCRR	RR	5	R		0.15	1	NCRR
69	7-5	Petrolia, CA	25/4/92	6.9	Tunnel #36	NCRR	RR	5-3	R		0.13	1	NCRR
70	7-6	Petrolia, CA	25/4/92	6.9	Tunnel #35	NCRR	RR	5-3	R		0.12	1	NCRR
71	7-7	Petrolia, CA	25/4/92	6.9	Tunnel #34	NCRR	RR	5-3	R		0.12	2	NCRR
72	7-8	Petrolia, CA	25/4/92	6.9	Tunnel #31	NCRR	RR	5-3	R		0.08	1	NCRR
73	7-9	Petrolia, CA	25/4/92	6.9	Tunnel #30	NCRR	RR	5	R		0.08	1	NCRR
74	7-10	Petrolia, CA	25/4/92	6.9	Tunnel #29	NCRR	RR	5	R		0.06	1	NCRR
75	7-11	Petrolia, CA	25/4/92	6.9	Tunnel #28	NCRR	RR	5-3	R		0.06	1	NCRR
76	8-1	Hokkaido, Japan	0/0/93	7.8	Seikan		HW	6			0.32	1	JTA, 1994
77	9-1	Northridge, CA	17/1/94	6.7	Pershing Sq St.	LAMT	RR	6	R		0.27	1	Tunnels & Tunneling, 1994
78	9-2	Northridge, CA	17/1/94	6.7	McArthur St.	LAMT	RR	6	R		0.27	1	Tunnels & Tunneling, 1994
79	9-3	Northridge, CA	17/1/94	6.7	Civic Center St.	LAMT	RR	6	R		0.27	1	Tunnels & Tunneling, 1994
80	9-4	Northridge, CA	17/1/94	6.7	Tun# 25 @ I-5/14	SPRR	RR	5	R	92	0.67	2	METROLINK
81	9-5	Northridge, CA	17/1/94	6.7	Santa Susana	SPRR	RR	5	R		0.47	1	SPRR
82	9-6	Northridge, CA	17/1/94	6.7	Chatworth	SPRR	RR	5	R		0.50	1	SPRR
83	9-7	Northridge, CA	17/1/94	6.7	Chatworth	SPRR	RR	5	R		0.50	1	SPRR
84	9-8	Northridge, CA	17/1/94	6.7	Near I15 at Cajon Junc	ATSF	RR		R		0.10	1	ATSF
85	9-9	Northridge, CA	17/1/94	6.7	Balboa inlet	MWD	WT	2-5-6-7	R		0.67	1	MWD
86	9-10	Northridge, CA	17/1/94	6.7	Balboa outlet	MWD	WT		R		0.58	1	MWD
87	9-11	Northridge, CA	17/1/94	6.7	Castaic #1	MWD	WT	6-7	R		0.29	1	MWD
88	9-12	Northridge, CA	17/1/94	6.7	Castaic #2	MWD	WT	6-7	R		0.36	1	MWD
89	9-13	Northridge, CA	17/1/94	6.7	Saugus	MWD	WT	6-7	S		0.54	1	MWD
90	9-14	Northridge, CA	17/1/94	6.7	Placerita	MWD	WT	6-7	R		0.62	1	MWD
91	9-15	Northridge, CA	17/1/94	6.7	Newhall	MWD	WT	2-5-6-7	R		0.68	3-4	MWD. Damage attributed to fluid pressure buildup behind tunnel and not to earthquake shaking
92	9-16	Northridge, CA	17/1/94	6.7	San Fernando	MWD	WT	5-6-7	R/S		0.50	1	MWD
93	9-17	Northridge, CA	17/1/94	6.7	Sepulveda	MWD	WT	5-7	R		0.27	1	MWD
94	9-18	Northridge, CA	17/1/94	6.7	Hollywood	MWD	WT		R		0.22	1	MWD
95	9-19	Northridge, CA	17/1/94	6.7	San Rafael #1	MWD	WT	6	R		0.16	1	MWD
96	9-20	Northridge, CA	17/1/94	6.7	San Rafael #2	MWD	WT	6	R		0.18	1	MWD
97	9-21	Northridge, CA	17/1/94	6.7	Pasadena	MWD	WT	6	S		0.15	1	MWD
98	9-22	Northridge, CA	17/1/94	6.7	Siera Madre	MWD	WT		S		0.13	1	MWD
99	9-23	Northridge, CA	17/1/94	6.7	Monrovia #1, #2	MWD	WT	5-6	R		0.09	1	MWD

EQID	CASE	EQNAME	DATE	Mw	TNAME	OWNER	FUN	LINER SYSTEM	ROCK SOIL	COVER (M)	PGA (G)	DS	REFERENCE, NOTES
100	9-24	Northridge, CA	17/1/94	6.7	Monrovia #3	MWD	WT	5-6	R		0.10	1	MWD
101	9-25	Northridge, CA	17/1/94	6.7	Monrovia #4	MWD	WT	5-6	R		0.10	1	MWD
102	9-26	Northridge, CA	17/1/94	6.7	Glendora	MWD	WT	2-5-6-7	R/S		0.07	1	MWD
103	9-27	Northridge, CA	17/1/94	6.7	Oakhill	MWD	WT		R		0.15	1	MWD
104	9-28	Northridge, CA	17/1/94	6.7	Ascat	MWD	WT		R		0.14	1	MWD
105	9-29	Northridge, CA	17/1/94	6.7	Tonner #1	MWD	WT	5-7	R		0.06	1	MWD
106	9-30	Northridge, CA	17/1/94	6.7	Tonner #2	MWD	WT	5-7	R		0.06	1	MWD
107	9-31	Northridge, CA	17/1/94	6.7	LA Aqueduct	LADWP	WT	5		46	0.67	2	LADWP
108	10-1	Kobe, Japan	17/1/95	6.9	Rokkou (#1)	JRN	RR	5		460	0.60	3	Geo. Eng. Assn., 1996
109	10-2	Kobe, Japan	17/1/95	6.9	Kobe (#2)	JRN	RR	5		272	0.57	2	Geo. Eng. Assn., 1996
110	10-3	Kobe, Japan	17/1/95	6.9	Suma (#3)	JRN	RR	5		45	0.53	1	Geo. Eng. Assn., 1996
111	10-4	Kobe, Japan	17/1/95	6.9	Okuhata (#4)	JRN	RR	5		90	0.50	1	Geo. Eng. Assn., 1996
112	10-5	Kobe, Japan	17/1/95	6.9	Takatsukay(#5)	JRN	RR	5		85	0.49	1	Geo. Eng. Assn., 1996
113	10-6	Kobe, Japan	17/1/95	6.9	Nagasaka (#6)	JRN	RR	5		20	0.48	2	Geo. Eng. Assn., 1996
114	10-7	Kobe, Japan	17/1/95	6.9	Daiichinas (#7)	JRN	RR	5		150	0.55	1	Geo. Eng. Assn., 1996
115	10-8	Kobe, Japan	17/1/95	6.9	Ikuse (#8)	JRN	RR	5		250	0.57	1	Geo. Eng. Assn., 1996
116	10-9	Kobe, Japan	17/1/95	6.9	Daiichitaked(#9)	JRN	RR	5		95	0.43	1	Geo. Eng. Assn., 1996
117	10-10	Kobe, Japan	17/1/95	6.9	Arima (#12)	KBD	RR	5		25	0.46	3	Geo. Eng. Assn., 1996
118	10-11	Kobe, Japan	17/1/95	6.9	Gosha (#13)	KBD	RR	5		40	0.41	1	Geo. Eng. Assn., 1996
119	10-12	Kobe, Japan	17/1/95	6.9	Kitakami (#14)	HOE	RR	6		350	0.51	3	Geo. Eng. Assn., 1996
120	10-13	Kobe, Japan	17/1/95	6.9	Iwataki (#15)	HRP	HW	5		135	0.58	3	Geo. Eng. Assn., 1996
121	10-14	Kobe, Japan	17/1/95	6.9	Nunohiki(#18)	MRP	HW	5		260	0.58	3	Geo. Eng. Assn., 1996
122	10-15	Kobe, Japan	17/1/95	6.9	Daini Nun (#19)	MRP	HW	5		240	0.58	2	Geo. Eng. Assn., 1996
123	10-16	Kobe, Japan	17/1/95	6.9	Hirano (#20)	MRP	HW	5		85	0.58	1	Geo. Eng. Assn., 1996
124	10-17	Kobe, Japan	17/1/95	6.9	K. Daiichi (#21)	MRP	HW	5		32	0.58	1	Geo. Eng. Assn., 1996
125	10-18	Kobe, Japan	17/1/95	6.9	K. Daini (#22)	MRP	HW	5		25	0.58	1	Geo. Eng. Assn., 1996
126	10-19	Kobe, Japan	17/1/95	6.9	Kamoetsu 1(#23)	MRP	HW	5		29	0.55	1	Geo. Eng. Assn., 1996
127	10-20	Kobe, Japan	17/1/95	6.9	Kamoetsu 2(#24)	MRP	HW	5		40	0.55	2	Geo. Eng. Assn., 1996
128	10-21	Kobe, Japan	17/1/95	6.9	Kamoetsu 3(#25)	MRP	HW	5		47	0.55	2	Geo. Eng. Assn., 1996
129	10-22	Kobe, Japan	17/1/95	6.9	Hiyodori (#26)	MRP	HW	5		40	0.54	1	Geo. Eng. Assn., 1996
130	10-23	Kobe, Japan	17/1/95	6.9	Shin-kobe 1(#27)	MRP	HW	5		330	0.49	2	Geo. Eng. Assn., 1996
131	10-24	Kobe, Japan	17/1/95	6.9	Shin-kobe 2(#28)	MRP	HW	5		330	0.49	2	Geo. Eng. Assn., 1996
132	10-25	Kobe, Japan	17/1/95	6.9	Karaki (#29)	MRP	HW	5		145	0.42	3	Geo. Eng. Assn., 1996
133	10-26	Kobe, Japan	17/1/95	6.9	Arino 1 (#30)	MRP	HW	5		25	0.39	1	Geo. Eng. Assn., 1996

EQID	CASE	EQNAME	DATE	Mw	TNAME	OWNER	FUN	LINER SYSTEM	ROCK SOIL	COVER (M)	PGA (G)	DS	REFERENCE, NOTES
134	10-27	Kobe, Japan	17/1/95	6.9	Arino 2 (#31)	MRP	HW	5		35	0.38	1	Geo. Eng. Assn., 1996
135	10-28	Kobe, Japan	17/1/95	6.9	Rokkousan (#32)	MRP	HW	5		280	0.51	2	Geo. Eng. Assn., 1996
136	10-29	Kobe, Japan	17/1/95	6.9	Shinohara (#33)	MRP	HW	5		15	0.55	1	Geo. Eng. Assn., 1996
137	10-30	Kobe, Japan	17/1/95	6.9	Hiyodori (#34)	MRP	HW	5		67	0.59	2	Geo. Eng. Assn., 1996
138	10-31	Kobe, Japan	17/1/95	6.9	Suma (#36)	CDO		5		140	0.44	1	Geo. Eng. Assn., 1996
139	10-32	Kobe, Japan	17/1/95	6.9	Suma ext (#37)	CDO		5			0.58	1	Geo. Eng. Assn., 1996
140	10-33	Kobe, Japan	17/1/95	6.9	Ibuki (#38)	HHP	HW	5		20	0.43	1	Geo. Eng. Assn., 1996
141	10-34	Kobe, Japan	17/1/95	6.9	Taizanji,1E(#39)	HHP	HW	5		53	0.44	1	Geo. Eng. Assn., 1996
142	10-35	Kobe, Japan	17/1/95	6.9	Taizanji,1W(#40)	HHP	HW	5		37	0.44	1	Geo. Eng. Assn., 1996
143	10-36	Kobe, Japan	17/1/95	6.9	Taizanji,2E(#41)	HHP	HW	5		25	0.45	1	Geo. Eng. Assn., 1996
144	10-37	Kobe, Japan	17/1/95	6.9	Taizanji,2W(#42)	HHP	HW	5		17	0.45	1	Geo. Eng. Assn., 1996
145	10-38	Kobe, Japan	17/1/95	6.9	Aina, E(#43)	HHP	HW	5		68	0.46	1	Geo. Eng. Assn., 1996
146	10-39	Kobe, Japan	17/1/95	6.9	Aina, W(#44)	HHP	HW	5		65	0.46	1	Geo. Eng. Assn., 1996
147	10-40	Kobe, Japan	17/1/95	6.9	Nagasaka.,E(#45)	HHP	HW	5		68	0.42	1	Geo. Eng. Assn., 1996
148	10-41	Kobe, Japan	17/1/95	6.9	Nagasaka.,W(#46)	HHP	HW	5		68	0.42	1	Geo. Eng. Assn., 1996
149	10-42	Kobe, Japan	17/1/95	6.9	T.Higa.,TOK(#47)	JHP	HW	5		62	0.58	1	Geo. Eng. Assn., 1996
150	10-43	Kobe, Japan	17/1/95	6.9	T.Higa.,KYU(#48)	JHP	HW	5		59	0.58	1	Geo. Eng. Assn., 1996
151	10-44	Kobe, Japan	17/1/95	6.9	T.Nishi,TOK(#49)	JHP	HW	5		42	0.57	1	Geo. Eng. Assn., 1996
152	10-45	Kobe, Japan	17/1/95	6.9	T.Nishi,KYU(#50)	JHP	HW	5		42	0.57	1	Geo. Eng. Assn., 1996
153	10-46	Kobe, Japan	17/1/95	6.9	Takak.,1TOK(#51)	JHP	HW	5		97	0.59	1	Geo. Eng. Assn., 1996
154	10-47	Kobe, Japan	17/1/95	6.9	Takak.,2TOK(#52)	JHP	HW	5		86	0.59	1	Geo. Eng. Assn., 1996
155	10-48	Kobe, Japan	17/1/95	6.9	Takak.,KYU(#53)	JHP	HW	5		87	0.59	1	Geo. Eng. Assn., 1996
156	10-49	Kobe, Japan	17/1/95	6.9	Tsuki.,TOK(#54)	JHP	HW	5		43	0.60	1	Geo. Eng. Assn., 1996
157	10-50	Kobe, Japan	17/1/95	6.9	Takak.,KYU(#55)	JHP	HW	5		34	0.60	1	Geo. Eng. Assn., 1996
158	10-51	Kobe, Japan	17/1/95	6.9	Omoteyama 1(#61)	KTB	RR	5		41	0.41	1	Geo. Eng. Assn., 1996
159	10-52	Kobe, Japan	17/1/95	6.9	Ochiai (#63)	KTB	RR	5			0.56	1	Geo. Eng. Assn., 1996
160	10-53	Kobe, Japan	17/1/95	6.9	Yokoo, 1 (#64)	KTB	RR	5			0.59	1	Geo. Eng. Assn., 1996
161	10-54	Kobe, Japan	17/1/95	6.9	Yokoo, 2 (#65)	KTB	RR	5			0.60	1	Geo. Eng. Assn., 1996
162	10-55	Kobe, Japan	17/1/95	6.9	Shiroyama (#66)	JRN	RR	5			0.58	1	Geo. Eng. Assn., 1996
163	10-56	Kobe, Japan	17/1/95	6.9	Nashio 2 (#67)	JRN	RR	5			0.48	1	Geo. Eng. Assn., 1996
164	10-57	Kobe, Japan	17/1/95	6.9	Takedo 2 (#68)	JRN	RR	5			0.40	1	Geo. Eng. Assn., 1996
165	10-58	Kobe, Japan	17/1/95	6.9	Douba 1 (#69)	JRN	RR	5			0.40	1	Geo. Eng. Assn., 1996
166	10-59	Kobe, Japan	17/1/95	6.9	Douba 2 (#70)	JRN	RR	5			0.37	1	Geo. Eng. Assn., 1996
167	10-60	Kobe, Japan	17/1/95	6.9	Douba 3 (#71)	JRN	RR	5			0.36	1	Geo. Eng. Assn., 1996

EQID	CASE	EQNAME	DATE	Mw	TNAME	OWNER	FUN	LINER SYSTEM	ROCK SOIL	COVER (M)	PGA (G)	DS	REFERENCE, NOTES
168	10-61	Kobe, Japan	17/1/95	6.9	Keietu (#76)	KBD	RR	5			0.58	1	Geo. Eng. Assn., 1996
169	10-62	Kobe, Japan	17/1/95	6.9	Nakayama(#77)	KBD	RR	5			0.58	1	Geo. Eng. Assn., 1996
170	10-63	Kobe, Japan	17/1/95	6.9	Kadoyama (#78)	KBD	RR	5			0.58	1	Geo. Eng. Assn., 1996
171	10-64	Kobe, Japan	17/1/95	6.9	Kudari (#79)	KBD	RR	5			0.54	1	Geo. Eng. Assn., 1996
172	10-65	Kobe, Japan	17/1/95	6.9	Kik, Nobori(#81)	KBD	RR	5			0.54	1	Geo. Eng. Assn., 1996
173	10-66	Kobe, Japan	17/1/95	6.9	Tanigami (#82)	KBD	RR	6			0.41	1	Geo. Eng. Assn., 1996
174	10-67	Kobe, Japan	17/1/95	6.9	Kobe (#84)	KBD	RR				0.56	1	Geo. Eng. Assn., 1996
175	10-68	Kobe, Japan	17/1/95	6.9	Aina (#85)	KBD	RR				0.48	1	Geo. Eng. Assn., 1996
176	10-69	Kobe, Japan	17/1/95	6.9	Tetsukaiy (#87)	MRP	HW	5		20	0.60	1	Geo. Eng. Assn., 1996
177	10-70	Kobe, Japan	17/1/95	6.9	Taisanji (#88)	MRP	HW	5		50	0.44	1	Geo. Eng. Assn., 1996
178	10-71	Kobe, Japan	17/1/95	6.9	Kaibara (#89)	MRP	HW	5		20	0.36	1	Geo. Eng. Assn., 1996
179	10-72	Kobe, Japan	17/1/95	6.9	Shimohata (#91)	MRP	HW	5		20	0.60	1	Geo. Eng. Assn., 1996
180	10-73	Kobe, Japan	17/1/95	6.9	Fukuchi (#92)	MRP	HW	5		20	0.36	1	Geo. Eng. Assn., 1996
181	10-74	Kobe, Japan	17/1/95	6.9	Sumadera (#93)	MRP	HW	5		15	0.60	1	Geo. Eng. Assn., 1996
182	10-75	Kobe, Japan	17/1/95	6.9	Shin Arima (#95)	MRP	HW	5		20	0.48	1	Geo. Eng. Assn., 1996
183	10-76	Kobe, Japan	17/1/95	6.9	HigashiAina(#96)	MRP	HW	5		10	0.43	1	Geo. Eng. Assn., 1996
184	10-77	Kobe, Japan	17/1/95	6.9	Fukuyama (#97)	MRP	HW	5		15	0.59	1	Geo. Eng. Assn., 1996
185	10-78	Kobe, Japan	17/1/95	6.9	Minoya (#98)	MRP	HW	5		20	0.40	1	Geo. Eng. Assn., 1996
186	10-79	Kobe, Japan	17/1/95	6.9	Iwayama (#99)	MRP	HW	5		30	0.56	1	Geo. Eng. Assn., 1996
187	10-80	Kobe, Japan	17/1/95	6.9	Tamasaka (#100)	MRP	HW	5		10	0.58	1	Geo. Eng. Assn., 1996
188	10-81	Kobe, Japan	17/1/95	6.9	Fukiage (#101)	MWB	HW	5		30	0.44	1	Geo. Eng. Assn., 1996
189	10-82	Kobe, Japan	17/1/95	6.9	Maesaki (#102)	MWB	HW	5		10	0.43	1	Geo. Eng. Assn., 1996
190	10-83	Kobe, Japan	17/1/95	6.9	Nishikou 2 (103)	MWB	HW	5		20	0.39	1	Geo. Eng. Assn., 1996
191	10-84	Kobe, Japan	17/1/95	6.9	Fusehatagami (104)	MWB	HW	5		30	0.47	1	Geo. Eng. Assn., 1996
192	10-85	Kobe, Japan	17/1/95	6.9	Fusehatashita (105)	MWB	HW	5		30	0.47	1	Geo. Eng. Assn., 1996
193	10-86	Kobe, Japan	17/1/95	6.9	Enoshitayama (109)		WT	4		37	0.60	3	Geo. Eng. Assn., 1996
194	10-87	Kobe, Japan	17/1/95	6.9	Motoyama (110)		WT			96	0.59	3	Geo. Eng. Assn., 1996
195													Japan Society of Civil Eng, 1995
196	10-88	Kobe, Japan	17/1/95	6.9	N. of Itayada St.	KMS	RR	6			0.60	1	Japan Society of Civil Eng, 1995
197	10-89	Kobe, Japan	17/1/95	6.9	Near Natani	KMS	RR	5			0.60	1	Geo. Eng. Assn., 1996
198	10-90	Kobe, Japan	17/1/95	6.9	Koigawa river		WT	6			0.60	1	Geo. Eng. Assn., 1996
199	10-91	Kobe, Japan	17/1/95	6.9	Hosoyadani		WT	5		6	0.59	1	Geo. Eng. Assn., 1996
199	10-92	Kobe, Japan	17/1/95	6.9	Sennomori		WT	5		30	0.59	2	Geo. Eng. Assn., 1996
200	10-93	Kobe, Japan	17/1/95	6.9	Shioyadani		WT	5		25	0.59	2	Geo. Eng. Assn., 1996

EQID	CASE	EQNAME	DATE	Mw	TNAME	OWNER	FUN	LINER SYSTEM	ROCK SOIL	COVER (M)	PGA (G)	DS	REFERENCE, NOTES
201	10-94	Kobe, Japan	17/1/95	6.9	Kabutoyama-Ashiya	HWC	WT	5		25	0.58	1	Geo. Eng. Ass., 1996
202	10-95	Kobe, Japan	17/1/95	6.9	Sannomiya St. 3		UT	6		25	0.59	2	Geo. Eng. Ass., 1996
203		Kobe, Japan		6.9	NTT @ Chuo-ku	NTT	UT	6	S			2	Japan Society of Civil Eng, 1995
204	10-96		17/1/95								0.60		
204	10-97	Kobe, Japan	17/1/95	6.9	Kansai Electric	KEP	UT	5	S		0.60	2	Japan Society of Civil Eng, 1995
205		Kobe, Japan	17/1/95	6.9	HIGASHIYAMA (#10)	KER	RR	4, 5		4-8	0.70	3	Asakura and Sato, 1998
206		Kobe, Japan	17/1/95	6.9	EGEYAMA (#11)	KER	RR	4, 5		2-13	0.68	3	Asakura and Sato, 1998
207		Kobe, Japan	17/1/95	6.9	MAIKO (UP) (#16)	HSB	HW	5		4-50	0.62	2	Asakura and Sato, 1998
208		Kobe, Japan	17/1/95	6.9	MAIKO (DOWN) (#17)	HSB	HW	5		4-50	0.62	2	Asakura and Sato, 1998
209		Kobe, Japan	17/1/95	6.9	SHIOYA-DAN (#35)	KPW	HW	5		4-80	0.70	3	Asakura and Sato, 1998
210		Kobe, Japan	17/1/95	6.9	SEISHIN (2) (#58)	KTB	RR	6		7	0.36	1	Asakura and Sato, 1998
211		Kobe, Japan	17/1/95	6.9	SEISHIN (1) (#59)	KTB	RR	6		3	0.37	1	Asakura and Sato, 1998
212		Kobe, Japan	17/1/95	6.9	OMOTEYAMA (2) (#60)	KTB	RR	6			0.41	1	Asakura and Sato, 1998
213		Kobe, Japan	17/1/95	6.9	KODERA (#62)	KTB	RR	6		7	0.47	1	Asakura and Sato, 1998
214		Kobe, Japan	17/1/95	6.9	OBU (#86)	KPW	HW	5		50	0.55	1	Asakura and Sato, 1998
215		Kobe, Japan	17/1/95	6.9	AINA (#90)	KPW	HW	5		2	0.43	1	Asakura and Sato, 1998
216		Kobe, Japan	17/1/95	6.9	FUTATABI (#94)	KPW		5		20	0.70	1	Asakura and Sato, 1998
217		Kobe, Japan	17/1/95	6.9	SENGARI (#111)	KWS	WT	5		2-25	0.60	3	Asakura and Sato, 1998

Table C-2. Bored Tunnel Seismic Performance Database

Earthquake	Date and Time	Location of Epicenter	Magnitude, JMA Intensity	Area Most Severely Affected	Tunnel Performance	Selected References
1923 Kanto	Sep. 1 11:58 AM	Sagami Bay 139.3 E, 35.2 N (unknown)	7.90 VI	Kanagawa and Tokyo	Extensive, severest damage to more than 100 tunnels in southern Kanto area	JSCE [1984] Yoshikawa [1979]
1927 Kits-Tango	Mar. 7 6:27 PM	7 km WNW of Miyazu, Kyoto 135.15 E, 35.53 N (0)	7.30 VI	Joint section of Tango Peninsula	Very slight damage to 2 railroad tunnels in the epicentral region	Yoshikawa [1979] Yoshikawa [1984]
1930 Kita-Isu	Nov. 26 4:02 AM	7 km west of Atami, Shizuoka 139.0 E, 35.1 N (0)	7.30 VI	Northern part of Izu Peninsula	Very severe damage to one railroad tunnel due to earthquake fault crossing	Yoshikawa [1979] Yoshikawa [1982]
1948 Fukui	June 28 4:13 PM	12 km north of Fukui City 136.20 E, 36.17 N (0)	7.10 VI	Fukui Plain	Severe damage to 2 railroad tunnels within 8 km from the earthquake fault	Yoshikawa [1979]
1952 Tokachi-oki	Mar. 4 10:23 AM	Pacific Ocean 90 km ESE of Cape Erimo 144.13 E, 41.80 N (0)	8.20 VI – V	Southern part of Hokkaido	Slight damage to 10 railroad tunnels in Hokkaido	Committee Report [1954] Yoshikawa [1979]
1961 Kita-Mino	Aug. 19 2:33 PM	Border of Fukui and Gifu Prefectures 136 46'E, 36 01'N (0)	7.00 IV	Vicinity along the border of Fukui and Gifu Pref.	Cracking damage to a couple of aqueduct tunnels	Okamoto, et al. [1963] Okamoto [1973]
1964 Niigata	June 16 1:01 PM	Japan Sea 50 km NNE of Nugata City 139 11'E, 38 21'N (40)	7.50 V – VI	Nugata City	Extensive damage to about 20 railroad tunnels and one road tunnel	JSCE [1966] Kawasumi [1968] Yoshikawa [1979]
1968 Tokachi-oki	May 16 9:49 AM	Pacific Ocean 140 km south off the Cape Erimo 143 35~E, 40 44~N (0)	7.90 V	Aomori Prefecture	Slight damage to 23 railroad tunnels in Hokkaido	Committee Report [1969]
1978 Izu-Oshima-kinkai	Jan. 14 12:24 PM	In the sea between Oshima Isl. and Inatori, Shizuoka 139 15'E, 34 46N (0)	7.00 V VI	South-eastern region of Izu Peninsula	Very severe damage to 9 railroad and 4 road tunnels in a limited area	Onoda, et al. [1978] Konda [1978] Yoshikawa [1979][1982]
1978 Miyagiken-oki	June 12 5:14 PM	Pacific Ocean 115 km east of Sendai City, Miyagi 142 10'E, 38 09~N (40)	7.40 V	Sendai City and vicinity	Slight damage to 6 railroad tunnels mainly existing in Miyagi Prefecture	Committee Report [1980]
1982 Urakawa-oki	Mar. 21 11:32 AM	Pacific Ocean 18 km SW of Urakawa, Hokkaido	7.10 IV – V	Urakawa-Cho and Shizunsi-Cho,	Slight damage to 6 railroad tunnels near Urakawa	Yoshikawa [1984]

Earthquake	Date and Time	Location of Epicenter	Magnitude, JMA Intensity	Area Most Severely Affected	Tunnel Performance	Selected References
		142 36'E, 42 04'N (40)		southern Hokkaido		
1983 Nihonkai-chubu	May 26 11:59 AM	Japan Sea 90 km west of Noshiro City, Akita 139 04.6'E, 40 21.4'N (14)	7.70 V	Noshiro City and Oga City, Akita	Slight damage to 8 railroad tunnels in Akita, etc.	Yoshikawa [1984] JSCE [1986]
1984 Naganoken-seibu	Sep. 14 8:48 AM	9 km SE of Mt. Ontake, Nagano 137 33.6'E, 35 49.3'N (2)	6.80 VI - V	Otaki Village, Nagano	Cracking damage to one headrace tunnel	Matauda, et al. [1985]
1993 Notohanto-oki	Feb. 7 10:27 PM	Japan Sea 24 km north of Suzu City, Ishikawa 137 18'E, 37 39'N (25)	6.60 V	Suzu City	Severe damage to one road tunnel	Kitaura, et al. [1993] Kunita, et al. [1993]
1993 Hokkaido-nansei-oki	July 12 10:17 PM	Japan Sea 86 km west of Suttsu, Hokkaido 139 12'E, 42 47'N (34)	8 VI - V	Okushiri Isi. and south-western part of Hokkaido	Severe damage to one road tunnel due to a direct hit of falling rock	Miyajima, et al. [1993] Nishikawa, et al. [1993] JSEEP News [1993]

Table C-3. Tunnel Performance in Japanese Earthquake

JMA	Intensity Scale	Definition	Acceleration (in gals)
0	No feeling	Shocks too weak to be felt by humans and registered only by seismographs.	< 0.8
I	Slight	Extremely feeble shocks felt only by persons at rest, or by those who are observant of earthquakes.	0.8 to 2.5
II	Weak	Shocks felt by most persons; slight shaking of doors and Japanese latticed sliding doors (shoji).	2.5 to 8
III	Rather Strong	Slight shaking of houses and buildings, rattling of doors and shoji, swinging of hanging objects like electric lamps, and moving of liquids in vessels.	8 to 25
IV	Strong	Strong shaking of houses and buildings, overturning of unstable objects, and spilling of liquids out of vessels.	25 to 80
V	Very Strong	Cracks in sidewalks, overturning of gravestone and stone lanterns, etc.; damage to chimneys and mud and plaster warehouses.	80 to 250
VI	Disastrous	Demolition of houses, but of less than 30% of the total, landslides, fissures in the ground.	250 to 400
VII	Very Disastrous	Demolition of more than 30% of the total number of houses, intense landslides, large fissures in the ground and faults.	> 400

Table C-4. Japan Meteorological Agency Intensity Scale

ID	Earthquake	Name of Tunnel	Location	Use	Length (m)	Cross Section Width x Height (m)	Liner System	Liner Thickness (cm)	Geological Feature	Cover (m)
1	1923 Kanto	Hakone No. 1 (up) (down)	Yamakita-Yaga	RR	284.7	4.3 x 4.7	4	34 - 57	marlstone, soil	
			(on Tokaido [Gotemba] Line)		285.2	4.6 x 5.0		23 - 46		
2	1923 Kanto	Hakone No. 3 (up) (down)	Yamakita-Yaga	RR	312.0	4.3 x 4.7	4	23 - 57		4 - 47
			(on Tokaido [Gotemba] Line)		318.1	4.6 x 5.0		23 - 46		
3	1923 Kanto	Hakone No. 4 (up) (down)	Yamakita-Yaga	RR	269.9	4.3 x 4.7	4	23 - 57		4 - 53
			(on Tokaido [Gotemba] Line)		306.8	4.6 x 5.0		23 - 57		
4	1923 Kanto	Hakone No. 7 (up) (down)	Yaga – Surugaoyama	RR	211.2	4.6 x 5.0	4	34 - 46		
			(on Tokaido [Gotemba] Line)		232.9	4.3 x 4.7		34 - 57		
5	1923 Kanto	Nagoe (up) (down)	Kamakura – Zushi	RR	442.6	4.9 x 6.0	4-5	34 - 46	mudstone	
			(on Yokosuka Line)		344.3	4.3 x 5.6	4-5	23 - 57		
6	1923 Kanto	Komine	Odawara – Hayakawa	RR	260.5	9.1 x 6.0 (box)	4-5	126 - 137	soil	1 - 17
			(on Atami Tokaido] Line)			8.5 x 6.9 (tube)				
7	1923 Kanto	Fudoyama	Hayakawa – Nebukawa	RR	100.6	8.7 x 6.9	4-5	69 - 114	red agglomerate	4 - 20
			(on Atami Tokaido Line)							
8	1923 Kanto	Nenoueyama	Hayakawa – Nebukawa	RR	105.6	8.7 x 6.9	4-5	91	black agglomerate,	12 - 17
			(on Atami Tokaido Line)						pyroxene andesite	
9	1923 Kanto	Komekamiyama	Hayakawa – Nebukawa	RR	278.6	8.7 x 6.9	4-5	57 - 103	pyroxene andesite,	2 - 51
			(on Atami Tokaido Line)						agglomerate, volcanic ash	
10	1923 Kanto	Shimomakiyayama	Hayakawa – Nebukawa	RR	160.9	8.7 x 6.9	4-5	69 - 103	pyroxene andesite,	14 - 31
			(on Atami Tokaido] Line)						volcanic ash	
11	1923 Kanto	Happonmatan	Nebukawa – Manazurn	RR	76.4	8.7 x 6.9	4-5	69 - 91	loose agglomerate	< 17
			(on Atami Tokaido] Line)							
12	1923 Kanto	Nagasakayama	Nebukawa – Manazurn	RR	673.9	8.5 x 6.9	4-5	57 - 91	agglomerate	11 - 94
			(on Atami Tokaido] Line)							
13	1923 Kanto	Yose	Sagainiko – Fujino	RR	292.6	4.6 x 5.0	4	46 - 69	soil	4 - 21
			(on Chuo Line)							

ID	Earthquake	Name of Tunnel	Location	Use	Length (m)	Cross Section Width x Height (m)	Liner System	Liner Thickness (cm)	Geological Feature	Cover (m)
14	1923 Kanto	Toke	Toke – Ohami (on Boso [Sotobo] Line)	RR	353.3	4.3 x 4.5	4	34 - 46	mudstone	12 - 20
15	1923 Kanto	Namuya	Iwal – Tomiura (on Hojo [Uchibo] Line)	RR	740.3	4.9 x 6.0	4-5	30 - 57	shale, tuffite	9 - 70
16	1923 Kanto	Mineokayama	Futorni - Awakamogawa (on Awa [Uchibo] Line)	RR	772.5	4.9 x 6.0	4	30 - 47	sandstone, shale, gabbro	
17	1930 Kita-Izu	Tanna	Atami – Kannami (on Atami [Tokaido] Line)	RR	7804.0	8.5 x 6.4	4-5	32 - 136	andesite, agglomerate	
18	1961 Kita-Mino	I Power Plant	upperstream of Tedor River	WT	2538.0	2.1 x 2.2 2.4 x 2.45	5 5	20 - 40 20 - 40	sandstone, soil	
19	1964 Niigata	Budo	Murakami – Buya (on Route 7)	HW	320.0	8.6 x 5.8	5	50 - 60	rhyolite, talus, perlite clay	
20	1964 Niigata	Terasaka	Nezugaseki - Koiwagawa (on Uetsu Line)	RR	79.4		4-5	47 - 107	soft mudstone	
21	1964 Niigata	Nezugaseki	Nezugaseki - Koiwagawa (on Uetsu Line)	RR	104.0				soft mudstone	
22	1968 Tokachi-oki	Otofuke	Nukabira – Horoka (on Shihoro Line)	RR	165.0	4.8 x 5.2	4-5	25 - 60	tuff	< 50
23	1978 Izu-Oshima-kinkai	Inatori	Inatori – haihatna (on Izu-kyuko Une)	RR	906.0	4.4 x 5.1	5	40 - 70	metamorphic andesite solfataric clay	< 90
24	1978 Izu-Oshima-kinkai	Okawa	Okawa – Hokkawa (on Izu-kyuko Une)	RR	1219.5				andesite, fault clay	
25	1978 Izu-Oshima-kinkai	Atagawa	Atagawa - Kataseshirata (on Izu-kyuko Une)	RR	1277.0				andesite, solfararic clay	
26	1978 Izu-Oshima-kinkai	Shiroyama	Imaihama – Kawazu (on Izu-kyuko Line)	RR						
27	1978 Izu-Oshima-kinkai	Tomoro	Shirata – Inatori (on Higashi-Izu Toll Road)	HW	425.5		5		andesite	

ID	Earthquake	Name of Tunnel	Location	Use	Length (m)	Cross Section Width x Height (m)	Liner System	Liner Thickness (cm)	Geological Feature	Cover (m)
28	1978 Izu-Oshima-kinkai	Shirata	Shirata – Inatori (on Route 135)	HW	88.7				andesite	
29	1978 Izu-Oshima-kinkai	Joto	Shirata - Inatori (on Route 135)	HW	127.3		4-6		andesite	
30	1978 Izu-Oshima-kinkai	Kurone	Shirata - Inatori (on Route 135)	HW	400.0				andesite, scoria	
31	1978 Miyagiken-oki	Nakayama No.2	Naruko - Nakayamadaira (on Rikuu-east Line)	RR	262.1	4.9 x 6.1	4-5	59 - 69		
32	1984 Naganoken-seibu	Otakigawa Dam	Otaki, Nagano	UT		2.7 x 3.0	5		sandstone, shale	
33	1993 Notohanto-oki	Kinoura	Orido, Suzu, Ishikawa Shimamaki Village	HW	76.0	6.8 x 5.1	5		mudstone, tuff	< 26
34	1993 Hokkaido-nansei-oki	Shiraito No. 2	(on Route 229)	HW	1463.0		6	60	talus	

Table C-5a. Tunnels with Moderate to Heavy Damage (Japanese) (1 of 2)

ID	Earthquake	Name of Tunnel	Damage at Portals	Damage within 30 m of portals	Damage to Liner > 30 m from portal	Notes
1	1923 Kanto	Hakone No. 1 (up) (down)	2	2	1	
2	1923 Kanto	Hakone No. 3 (up) (down)	4 - slide	3	1	
3	1923 Kanto	Hakone No. 4 (up) (down)	4 - slide	3	1	Damage varies from Table C-2.
4	1923 Kanto	Hakone No. 7 (up) (down)	2	4	1	lesser damage to down (mountain side) Damage varies from Table C-2.
5	1923 Kanto	Nagoe (up) (down)	1	2	3	Damage varies from Table C-2.
6	1923 Kanto	Komine	4 (Box section)	4 (box section)	3 (tube section)	liner type depends on location
7	1923 Kanto	Fudoyama	2	2	1	
8	1923 Kanto	Nenoueyama	4 - slide	3	4	steep slope
9	1923 Kanto	Komekamiyama	4	3	1	liner with invert arch
10	1923 Kanto	Shimomakiyayama	4 - slide	4	1	steep slope Damage varies from Table C-2.
11	1923 Kanto	Happonmatan	4 - slide	3	1	steep slope
12	1923 Kanto	Nagasakayama	2	3	4	Damage varies from Table C-2.
13	1923 Kanto	Yose	1	2	4	collapse accident reported during construction
14	1923 Kanto	Toke	1	1	4	
15	1923 Kanto	Namuya	2	3	4	steep slope, landslide suspected,

ID	Earthquake	Name of Tunnel	Damage at Portals	Damage within 30 m of portals	Damage to Liner > 30 m from portal	Notes
						water accident reported during construction
16	1923 Kanto	Mineokayama	2	3	4	under construction at time of earthquake, progressive failure after the main shock
17	1930 Kita-Izu	Tanna	1	1	4	under construction at time of earthquake, earthquake fault crossing the tunnel
18	1961 Kita-Mino	I Power Plant	1	1	3	cracking 32% of whole length longitudinal crack dominant
19	1964 Niigata	Budo	1	2	2	under construction at time of earthquake cracking on the ground surface
20	1964 Niigata	Terasaka	1	3	3	landslide area cracking on the ground
21	1964 Niigata	Nezugaseki	2	2	2	landslide area
22	1968 Tokachi-oki	Otofuke	1	1	3	landslide area, slope
23	1978 Izu-Oshima-kinkai	Inatori	3	2	3	earthquake fault crossing the tunnel trouble with geology during construction
24	1978 Izu-Oshima-kinkai	Okawa	1	1	2	damage over 60 m long
25	1978 Izu-Oshima-kinkai	Atagawa	1	1	2	damage over 400 m long
26	1978 Izu-Oshima-kinkai	Shiroyama	4	1	1	a gigantic rock crashed and blocked the portal
27	1978 Izu-Oshima-kinkai	Tomoro	3	3	3	cracking on the ground surface
28	1978 Izu-Oshima-kinkai	Shirata	4 - slide	2	3	steep slope cracking on the ground surface
29	1978 Izu-Oshima-kinkai	Joto	4 - slide	1	4	steep slope cracking on the ground surface
30	1978 Izu-Oshima-kinkai	Kurone	4 - slide	2	1	

ID	Earthquake	Name of Tunnel	Damage at Portals	Damage within 30 m of portals	Damage to Liner > 30 m from portal	Notes
31	1978 Miyagiken-oki	Nakayama No.2	1	1	3	
32	1984 Naganoken-seibu	Otakigawa Dam	1	1	2	earthquake fault crossing suspected
33	1993 Notohanto-oki	Kinoura	2	4	3	collapse extended by aftershocks
34	1993 Hokkaido-nansei-oki	Shiraito No. 2	1	1	4	falling rock hit the exposed tunnel lining

Table C-5b. Tunnels with Moderate to Heavy Damage (Japanese) – (2 of 2)

EQNAME : Earthquake name
Mw: Moment Magnitude
TNAME : Tunnel name
OWNER OR REFERENCE:

ATSF	= Santa Fe Railroad
CALTRAIN	= CALTRAIN (Bay Area commuter train)
CALTRANS	= California Department of Transportation
CDO	= City Development Office
COE	= Corps of Engineers
HHP	= Hanshin Highway Public Corp.
HOE	= Hokoshin Express
HRP	= Hyogo Road Public Corp.
HWC	= Hanshin Waterworks Company
HSB	= Honsyu Shikoku Bridge Authority
JHP	= Japan Highway Public Corp.
JRN	= JR Nishinippon
JTA	= Japan Tunneling Association
KBD	= Kobe Dentetsu
KEP	= Kansai Electric Plant
KER	= Kobe Electric Railway
KMS	= Kobe Municipal Subway
KPW	= Kobe Public Works Bureau
KTB	= Kobe Transportation Bureau
KWS	= Kobe Water Supply Bureau
LADWP	= Los Angeles Department of Water and Power
LAMT	= Los Angeles Metro
MRP	= Municipal Road Public Corp.
MWB	= Municipal Waterworks Bureau
MWD	= Metropolitan Water District of Southern California
Nat. RW	= National Railway
NCCR	= North Coast Railroad
NPC	= North Pacific Coast Railroad
NPS	= National Park Service
NTT	= Nippon Telephone and Telegraph
SC, BT, PR	= Santa Cruz-Big Trees-Pacific Railway
SCVWD	= Santa Clara Valley Water District
SFWD	= San Francisco Water Department
SPRE	= Southern Pacific Railroad
SU	= Stanford University

FUN: Function of tunnel

AC	= Particle accelerator
HW	= Highway
RE	= Railroad
UT	= Utility
WT	= Water

Liner / support system

1 = Unlined	2 = Rock Bolt	3 = Timber	4 = Masonry/brick
5 = Unreinforced concrete	6 = Reinforced Concrete	7 = Steel pipe	9 = Unknown

Rock / Soil
R = Rock S = Soil

COVER: Depth of cover above tunnel (meters)
PGA : Peak Ground Acceleration in g
DM : Damage State (Table C-3)
1 = None 2 = slight 3 = moderate 4 = heavy

DM : Damage State (Table C-5)
1 = none
2 = slight (cracks, displacement, deformation)
3 = moderate (severe cracks, falling out, arch hanging down, swelling, invert cut)
4 = heavy (collapse)

Table C-6. Legend for Tables C-2 and C-5

Data was categorized in three damage states: no damage, minor damage and moderate damage. Each tunnel has a damage state and associated peak ground acceleration. Nine 'bins' (3 damage states x 3 PGA intervals) were used to sort the tunnels. The results are shown in Table C-7.

Damage State/PGA	0.0 to 0.2g	0.2 to 0.5g	0.5 to 0.7g	Total
No Damage	30	9	0	39
Minor Damage	1	9	5	15
Moderate Damage	0	5	9	14
Total	31	23	14	68

Table C-7. Number of Tunnels in Each Damage State Due to Ground Shaking

The empirical data was then averaged to obtain the mean, median, standard deviation and beta for each damage state. The results are provided in Table C-8. Beta in Table C-8 includes uncertainty and randomness (same as β_{total} in equation 5-2).

Damage State/PGA	Mean (g)	Median (g)	Std. Dev (g)	Beta (total)
No Damage	0.183	0.145	0.143	0.689
Minor Damage	0.387	0.353	0.174	0.428
Moderate Damage	0.513	0.500	0.116	0.224

Table C-8. Statistics for Tunnel Damage States

The data in Tables C-7 and C-8 include rock, alluvial and cut-and-cover tunnels, but no distinction is made between the three since the ground conditions were not reported in the literature for most of the tunnels.

Dowding [1978] reported that below 0.19g, there is no damage to either lined or unlined tunnels. Also, Owen [1981] concluded that rock tunnels perform better than alluvial or cut-and-cover tunnels. Specifically, little damage occurs to rock tunnels when accelerations at the ground surface is below 0.4g. Earthquake experience shows that most damage occurs to the tunnel liner, and such damage is well correlated with the quality of construction of the liner. For example, older-designed unreinforced concrete liners using wood sets and lagging for temporary support and without contact grouting are more susceptible to damage than are modern, cast-in-place concrete liners using steel sets and standard contact grouting.

For these reasons, fragility curves developed for HAZUS for ground shaking hazards distinguish between rock tunnels and other tunnels, and between poor and good quality construction. No distinction is made in the HAZUS fragility curves between tunnels with or without seismic design. Since the empirical database provided no indication of the original design basis, it is likely that seismic design was not included in many of the tunnels in the empirical database. The resulting HAZUS fragility curves are described in Tables C-9 through C-12.

Alluvial Cut-and-cover Tunnels of poor-to-average construction. The fragility curves are based on the data in Table C-8 with minor adjustments described below. Beta includes uncertainty and randomness.

Item	Hazard	Damage State	Median PGA (g)	Beta	Median PGD (inch)	Beta
Liner	Ground Shaking	Minor cracking of tunnel liner; minor rock falls; spalling of shotcrete or other supporting material.	0.35	0.4		
Liner	Ground Shaking	Moderate cracking of tunnel liner and rock falls.	0.55	0.6		
Liner	Ground Failure	Moderate cracking of tunnel liner and rock falls			12	0.5
Liner	Ground Failure	Major localized cracking and possible collapse of tunnel liner and rock falls			60	0.5
Portal	Ground Failure	Debris from landslide closes portal			60	0.5

Table C-9. Tunnel – Alluvial or Cut-and-cover with Liner of Average to Poor Quality Construction

Minor damage from ground shaking: median: 0.35g, beta 0.40. These values are close to the empirical data set values of Median .353g, Beta .428.

Moderate damage from ground shaking: median: 0.55g, beta 0.6. The median value of 0.55g is set 10% higher than the empirical value of 0.50g, based on judgment. The beta value of 0.6 is set much higher than the empirical value of 0.22. The empirical value is deemed too low due to the small data sample size. In fact, the moderate damage state is known with less certainty than the minor damage state, and the state of empirical data (circa 1978) was too incomplete to warrant a lower value.

Damage due to ground failure through the liner. The HAZUS fragility values are set at 12 inches of liner offset to mean moderate damage, and 60 inches of liner offset to mean major damage. This implies that the tunnel diameter is in the range of 8 to 12 feet (typical of water tunnels), and that the materials behind the liner are weak enough to cause some type of debris accumulation in the tunnel. For water tunnels, small amounts of debris will often be carried away by the water flow; large amounts of debris can result in clogging of the tunnel and damage to downstream water system components. If a large amount of debris occur, the tunnel may clog over a long period of time. No specific fragility curve is provided for fault offset through the liner, but it is understood that a fault offset of about 50% to 75% (or larger) of the inner diameter of the liner can be enough to immediately close off the tunnel. However, it has been noted that larger fault offsets (more than the diameter of the tunnel) can, in some cases, be accommodated by the tunnel without loss of flow capacity if the offset is distributed over a reasonable length of the tunnel, on the order of 20 to 50 feet. Current predictive models of fault offset are not so precise as to determine with high confidence whether the fault offset will be like a “knife edge”—which leads to tunnel closure if offset approaches or exceeds tunnel diameter—or distributed over a considerable shear zone, which may or may not lead to tunnel closure.

Damage due to ground failure of the portal area. Landslides at portal areas represent a credible hazard to all tunnels. Strong ground shaking can promote landslide movements, especially under saturated soil conditions. The HAZUS fragility model of 5 feet leading to closure of the portal is based on judgment, and assumes that the tunnel is about 8 to 12 feet in diameter.

Alluvial and Cut-and-cover Tunnels of good construction. The median values are increased from those of tunnels with average-to-poor construction by one lognormal standard deviation and then rounded. For example: for Minor Damage, $0.35g * \exp(0.428) = 0.53g$, set to 0.5g; for Major Damage, $0.55g * \exp(0.224) = 0.688g$, set to 0.7g (Table C-10). Beta includes uncertainty and randomness.

Item	Hazard	Damage State	Median PGA (g)	Beta	Median PGD (inch)	Beta
Liner	Ground Shaking	Minor cracking of tunnel liner; minor rock falls; spalling of shotcrete or other supporting material.	0.5	0.4		
Liner	Ground Shaking	Moderate cracking of tunnel liner and rock falls.	0.7	0.6		
Liner	Ground Failure	Moderate cracking of tunnel liner and rock falls			12	0.5
Liner	Ground Failure	Major localized cracking and possible collapse of tunnel liner and rock falls			60	0.5
Portal	Ground Failure	Debris from landslide closes portal			60	0.5

Table C-10. Tunnel – Alluvial or Cut-and-cover with Liner of Good Quality Construction

The HAZUS fragility curves for damage to liners due to ground shaking for tunnels of good quality construction were developed by increasing the median fragility levels from Table C-9 by about 30% to 40%, which represents an increase in the median acceleration levels of one standard deviation above those for tunnels of poor-to-average quality construction. This is based on judgment and the limited empirical data set. A similar approach was taken to establish fragility curves for rock tunnels (Tables C-11 and C-12).

Rock Tunnels of poor to average construction. The fragility curves are developed based on engineering judgment., with adjustments taken from rock tunnels of good quality construction. Beta includes uncertainty and randomness.

Item	Hazard	Damage State	Median PGA (g)	Beta	Median PGD (inch)	Beta
Liner	Ground Shaking	Minor cracking of tunnel liner; minor rock falls; spalling of shotcrete or other supporting material.	0.5	0.4		
Liner	Ground Shaking	Moderate cracking of tunnel liner and rock falls.	0.7	0.6		
Liner	Ground Failure	Moderate cracking of tunnel liner and rock falls			12	0.5
Liner	Ground Failure	Major localized cracking and possible collapse of tunnel liner and rock falls			60	0.5
Portal	Ground Failure	Debris from landslide closes portal			60	0.5

Table C-11. Tunnel – Rock without Liner or with Liner of Average to Poor Quality Construction

Rock tunnels of good construction. The median peak ground acceleration was derived recognizing that little damage occurs below 0.4g. It was assumed that the median PGA for minor damage to rock tunnels of good construction quality would occur one lognormal standard deviation above 0.4g. Beta includes uncertainty and randomness.

Item	Hazard	Damage State	Median PGA (g)	Beta	Median PGD (inch)	Beta
Liner	Ground Shaking	Minor cracking of tunnel liner; minor rock falls; spalling of shotcrete or other supporting material.	0.6	0.4		
Liner	Ground Shaking	Moderate cracking of tunnel liner and rock falls.	0.8	0.6		
Liner	Ground Failure	Moderate cracking of tunnel liner and rock falls			12	0.5
Liner	Ground Failure	Major localized cracking and possible collapse of tunnel liner and rock falls			60	0.5
Portal	Ground Failure	Debris from landslide closes portal			60	0.5

Table C-12. Tunnel – Rock without Liner or with Liner of Good Quality Construction

At the time when the tunnel fragility curves were prepared for the HAZUS program in the early 1990s, damage due to ground shaking that would result in tunnel closures was not considered likely; therefore, there is no effect to the functionality of the tunnels due to ground shaking in the damage algorithm. As will be described in subsequent sections, this “heavy” damage state has in fact been occasionally observed, suggesting that the HAZUS fragility curves might need to be modified.

For ground failures such as surface faulting through the interior of the tunnel, substantial permanent ground deformations need to occur before appreciable damage occurs. For moderate damage, a permanent ground deformation of one foot is used, and for major damage, a permanent ground deformation of five feet is used. These displacements are based on a typical water tunnel equivalent diameter of about 8 feet. For both moderate and major damage due to ground failure, tunnel closure is possible; tunnel closure could occur immediately or within a few days of the earthquake either due to aftershocks or continued erosion of the geology behind the failed liner.

If the tunnel portals are subjected to PGDs due to landslides, then the same PGDs are assumed to cause the tunnel major damage and closure. Rockfall-type avalanches are not specifically considered in the fragility curves.

C.1.2 Comparison of HAZUS and ATC-13 Fragility Curves

Table C-13 compares the median peak ground accelerations for fragility curves developed in Tables C-10 and C-12 with the damage algorithms presented in ATC-13 [ATC, 1985]. Only median values are compared because the dispersions in the ATC-13 data do not reflect variability in the ground motion; the fragility curves developed here, do. The damage probability matrices given in the ATC-13 were converted to a cumulative probability distribution using the methodology described in ASCE [1985] and using the MMI-to-PGA conversion suggested by McCann et al [1980] (Table C-14).

Tunnel Type/Damage State	HAZUS (PGA)	ATC-13 (PGA)
Rock		
Moderate Damage	0.8 g	0.94 g
Minor Damage **	0.6 g	0.45 g
Cut & Cover or Alluvial		
Moderate Damage	0.7 g	0.74 – 0.84 g *
Minor Damage **	0.5 g	0.40 – 0.44 g *

* ATC-13 gives values for cut-and-cover and alluvial tunnels. Both PGAs are given above.

** For *Minor Damage State* shown above, the corresponding ATC-13 Damage State is *Light*.

Table C-13. Comparison of Tunnel Fragility Curves

MMI	PGA Interval	PGA Used
VI	0.09 – 0.15	0.12
VII	0.16 – 0.25	0.21
VIII	0.26 – 0.45	0.36
IX	0.46 – 0.60	0.53
X	0.61 – 0.80	0.71
XI	0.81 – 0.90	0.86
XII	≥ 0.91	1.15

Table C-14. Modified Mercalli to PGA Conversion [after McCann et al, 1980]

As can be seen in Table C-13, the median fragility values for the two damage states agree reasonably well.

C.2 Databases of Owen and Scholl, Sharma and Judd

Owen and Scholl [1981] extended the database of Dowding and Rozen [1978] to a total of 127 cases. Additions to the database included observations from the 1906 San Francisco earthquake, 1971 San Fernando earthquake and a number of less well-documented earthquakes around the world. Based on their examination of the data, Owen and Scholl concluded the following:

- Little damage occurred in rock tunnels for peak ground accelerations below 0.4g.
- Severe damage and collapse of tunnels from shaking occurred only under extreme conditions, usually associated with marginal construction such as brick or plain concrete liners and lack of grout between wood lagging and the overbreak.
- Severe damage was inevitable when the underground structure was intersected by a fault that slipped during an earthquake. Cases of tunnel closure appeared to be associated with movement of an intersecting fault, landslide, or liquefied soil.
- Deep tunnels were less prone to damage than shallow tunnels.
- Damage to cut-and-cover structures appeared to be caused mainly by large increases in lateral forces from the surrounding soil backfill.
- Earthquake duration appeared to be an important factor contributing to the severity of damage.

Sharma and Judd [1991] further extended the database to 192 reported cases. In this study, the relationships between observed damage and parameters of the earthquake, tunnel support system and geologic conditions were examined. Parameters considered in their study included earthquake magnitude, epicentral distance, peak ground acceleration, form of tunnel internal support and lining, overburden depth and rock type. Sharma and Judd concluded that:

- Damage incidence decreased with increasing overburden depth.
- Damage incidence was higher for colluvium than for harder rocks.
- Internal tunnel support and lining system appeared not to affect damage incidence.
- Damage increased with increasing earthquake magnitude and decreasing epicentral distance.
- No damage or minor damage can be expected for peak accelerations at the ground surface less than about 0.15g.

C.3 Database of Power et al

The tunnel studies described in Sections C.1 and C.2, while informative and indicative of generally good tunnel performance during earthquakes, contain some limitations:

- Many of the reported cases were observations from old and/or less well-documented earthquakes and the locations and/or magnitudes of a number of the earthquakes were poorly defined.

- The estimated ground shaking levels for the cases were calculated using empirical ground motion attenuation relationships developed in early 1970s. Peak ground accelerations were estimated using distances from earthquake epicenters to the tunnel sites. Ground motions calculated using epicentral distance could be misleading for sites located close to a long or extended fault rupture area. Recently developed ground motion attenuation relationships generally use some measure of the closest distance from the site to the fault rupture area. Furthermore, recently developed attenuation relationships are better constrained than the older relationships by having more data from many recent earthquakes.
- The damage cases reported and used in the previous studies included damage observations resulting from direct fault rupture through a tunnel and other major ground failure mechanisms such as landsliding and liquefaction. In examining the effects of ground shaking on tunnels, cases of damage due to these other failure mechanisms should not be included.

To consider these limitations, Power et al. [1998] critically examined the previously compiled databases summarized above and made the following revisions:

- Data was removed for poorly documented earthquakes such as earthquakes with unknown magnitudes or locations or uncertain tunnel performance.
- Data was removed for cases of damage due directly to fault displacement, landsliding, or liquefaction in order to examine trends for shaking-induced damage in the absence of ground failure.
- Data was not included for cut-and-cover tunnels or tubes, in order to develop trends and a correlation for bored tunnels only.
- Earthquake magnitudes were reported as moment magnitudes (M_w).
- Distances were evaluated as closest distances from the tunnel locations to the fault rupture surfaces of the earthquakes.
- Peak accelerations at the ground surface of actual or hypothetical rock outcroppings at the tunnel locations were estimated using recently-developed ground motion attenuation relationships.
- Data was added from recent, moderate-to-large magnitude and better-documented earthquakes: 1989 Loma Prieta, 1992 Petrolia, 1993 Hokkaido, 1994 Northridge and 1995 Kobe earthquakes. Some data were added from case histories from older earthquakes.

Table C-2 includes the complete database summarized in Table 6-1. Included in Table C-2 is information on the earthquake including name, date, and moment magnitude; tunnel name, owner, function, lining/support system, local geologic conditions and thickness of geologic cover; level of ground shaking; damage state; and references for data on the tunnels and tunnel performance observations.

In general, peak ground accelerations at the ground surface at tunnel locations were estimated as median (50th percentile) values using rock ground motion attenuation relationships developed by Sadigh et al. [1993, 1997] for earthquakes occurring on crustal faults. The rock relationship of Youngs et al [1993, 1997] for subduction zone earthquakes were used for the 1964 Alaska earthquake. The median peak accelerations for the 1994 Northridge earthquake were estimated using event-specific ground motion attenuation relationship developed for the Northridge earthquake [Woodward-Clyde Consultants, 1995]. Rock ground motion attenuation relationships were used because most of the reported cases in the database involve tunnels founded in rock and also due to the limited information available for the local geologic conditions. The actual ground motions experienced at the depth of the tunnels would tend to be less than the values estimated for the ground surface in Table C-2 due to well-known tendencies for ground motions to decrease with depth below the ground surface [e.g., Chang et al., 1986]. The highest median peak rock acceleration estimated for the entire database is about 0.7g, for the 1923 Kanto, 1971 San Fernando, and the 1994 Northridge earthquakes. Many estimated peak rock accelerations for the 1995 Kobe earthquakes are about 0.6g. The Kobe earthquake produced by far the most observations for moderate-to-high levels of shaking and include numerous estimated median peak rock accelerations at the ground surface above the tunnels in the range of about 0.4g to 0.6g.

Damage to the tunnels was categorized into four states: none; slight, for minor cracking and spalling of the tunnel lining; moderate, for major cracking and spalling; and heavy, for total or partial collapse of a tunnel.

[Figure C-2](#) summarizes the observations of the effects of seismic ground shaking on tunnel performance for case histories 1 through 204 in Table C-2. As indicated previously, the data is for damage due only to shaking and excludes damage that was definitely or probably attributed to fault rupture, landsliding, or liquefaction. Also, the data is for bored tunnels only; data for cut-and-cover tunnels and tubes is not included. Figure C-2 shows the level of damage induced in tunnels with different types of linings subjected to the indicated levels of ground shaking.

The following trends can be inferred from Figure C-2:

- For peak ground accelerations (PGAs) equal to or less than about 0.2g, ground shaking caused very little damage in tunnels.
- For peak ground accelerations (PGAs) in the range of about 0.2g to 0.5g, some instances of damage occurred, ranging from slight to heavy.
- For peak ground accelerations (PGAs) exceeding about 0.5g, there were a number of instances of slight to heavy damage.
- Tunnels having stronger lining systems appeared to perform better, especially those with reinforced concrete and/or steel linings.

The three instances of heavy damage, indicated by solid diamonds in Figure C-2, are all from the 1923 Kanto, Japan earthquake. For the 1923 Kanto earthquake observation with PGA equal to 0.25g (see Table C-2 and Figure C-2), investigations indicated that the damage may have been due to landsliding. In the other two observed occurrences of heavy damage shown in Figure C-2, collapses occurred in the shallow portions of the tunnels.

The correlations observed in Figure C-2 show similar trends as those observed in the previous study by Dowding and Rozen in Figure C-1. For relatively low ground shaking levels, no damage or very little damage occurred for PGAs less than about 0.2g. Relatively few instances of moderate-to-heavy damage exist for accelerations at less than 0.5g, especially for stronger and well-constructed tunnels. This was evident during the 1995 Kobe earthquake, where only a few cases of moderate damage and no major damage were reported for bored tunnels at peak ground accelerations of about 0.6g.

Although the number of observations for the seismic performance of cut-and-cover tunnels are far fewer than those for bored tunnels, the available data, including observations from the 1995 Kobe earthquake, suggest that cut-and-cover box-like tunnels are more vulnerable to shaking than bored tunnels with more or less circular cross-sections. Cut-and-cover tunnels are vulnerable to racking-type deformations due to ground-imposed displacements of the top of the box structure relative to the base. The higher vulnerability of cut-and-cover tunnels as compared to bored tunnels is also probably due in part to the softer geologic materials surrounding cut-and-cover structures, which are constructed at shallower depths than are most bored tunnels.

C.4 Additions to Empirical Database

Asakura and Sato [1998] expanded the compilation of tunnel performance data for the 1995 Kobe earthquake. Additional case histories obtained from their database during the present study are summarized in Table C-2 as entries 205 through 217.

As part of US/Japanese cooperative research and state-of-the-art studies of tunnel seismic design and performance by Prof. Thomas O'Rourke for MCEER, O'Rourke and Shiba [1997] summarized tunnel performance for 15 different earthquakes in Japan from 1923 to 1993. Table C-3 summarizes tunnel damage observed in these earthquakes. Table C-4 provides an explanation of the Japanese JMA intensity scale used in Table C-3. [Figure C-3](#) shows a map of the locations of these earthquakes. The findings in Table C-3 are similar to those described in the Sections C.2 and C.3 and included the following observations:

- Generally, the most significant damage was to the portals, which was often attributed to landslides.
- Some of the most severe damage occurred because of fault movements.
- Generally, damage to tunnels due to shaking was associated with unreinforced masonry and unreinforced, cast-in-place concrete linings, and with tunnel locations where construction difficulties were experienced and poor geologic conditions were encountered.
- Significant damage to Japanese tunnels was observed predominately in locations where seismic intensities of V or higher on the JMA scale occurred, correlating approximately to MMI intensity VIII.

C.5 Tunnels with Moderate to Heavy Damage from Ground Shaking

As previously discussed, the incidence of heavy damage or collapse of at least part of the liner system in tunnels from ground shaking has been relatively rare. The following sections summarize the specific tunnels that have collapsed possibly due to ground shaking.

C.5.1 Kanto, Japan 1923 Earthquake

Table C-5 summarizes the earthquake damage observed in 34 tunnels after ten Japanese earthquakes. These tunnels were selected as those displaying the most severe damage for which there is sufficient description in the literature to convey a reasonably clear picture of the tunnel, earthquake, ground conditions and nature of the damage. The table summarizes information pertaining to tunnel location, use, length, cross-section, lining, geology, overburden and damage observed either at, within or beyond 30 m from the portals.

Collapse beyond 30 meters from the portals was observed in the absence of landslides and faulting at a few tunnels, mostly in the 1923 Kanto earthquake. In all instances, the length of tunnel that experienced collapse was relatively small, ranging from 1.5 to 60 m. The following describes specific tunnel failures:

- The Mineokayama Tunnel was under construction during the earthquake, and the collapse occurred in one of the drifts. The type and quantity of temporary support used in the drift were not reported.
- The Yose Railroad Tunnel was driven in soil for a length of 293 m at a distance from the epicenter of 48 km. The brick masonry lining was 46-69 cm thick, with soil cover ranging mostly from 4 to 21 m. The JMA intensity was V-VI. During construction in 1900, water inflow attributed to a heavy rainfall resulted in the collapse of a 20-m-long section. During the Kanto earthquake, a 60-m-long section collapsed, including the section that failed during construction. The collapsed section was about 55 m from the closest portal.
- The Toke Railroad Tunnel was driven in mudstone for a length of 353 m at a distance of 106 km from the epicenter. The brick masonry lining was 34-46 cm thick, with an overburden of 12 to 20 meters. The JMA intensity was IV. Significant inflows of water into the tunnel had persisted from the time of its construction in 1894-95. During the Kanto earthquake, a section of the brick arch, 2.7 m wide and 5.5 m long, failed, causing 90 m³ of rock and soil to collapse into the tunnel.

C.5.2 Noto Peninsular Offshore, Japan 1993 Earthquake

Tunnel collapses have been reported more recently for Japanese earthquakes. Kunita, et al. (1994) report on the collapse of the Kinoura Tunnel as a result of the 1993 Noto Peninsular Offshore earthquake. The earthquake magnitude was 6.8 and the tunnel was located 26 km from the epicenter with a JMA intensity of approximately V. This road tunnel was driven in 1965 through alternating strata of tuff and mudstone. The 76-meter-long horseshoe-shaped tunnel was 6 m wide and about 4 m high. Timber supports were used during construction, and the final lining was composed of 30-cm-thick concrete. It appears that the lining was unreinforced. After the main shock, a 4.5 x 4.5 m section of the arch lining collapsed at a distance of 21 m from the

nearest portal. An aftershock caused the fall zone to expand, and two days after the main shock, the tunnel was almost completely blocked with debris.

C.5.3 Kobe, Japan 1994 Earthquake

During the 1994 Kobe earthquake, the cut-and-cover tunnel at the Daikai Subway Station collapsed catastrophically. It appears that this is the only instance of tunnel collapse resulting from the Kobe earthquake. The performance of the Daikai Station has been covered in the technical literature. Shear distortion from vertically propagating shear waves caused hinge formation where the central reinforced concrete columns were connected to the roof and invert. There was a lack of adequate confining steel in the central columns, which helped to promote column failure. See [Figure C-4](#).

C.5.4 Duzce, Turkey 1999 Earthquake

Twin tunnels, each 18 m in excavated diameter, were significantly and adversely affected by the 1999 Duzce, Turkey earthquake. They are located on Gurnosova-Gerede portion of the Northern Anatolian Motorway. The tunnels were being driven in a faulted and deformed sequence of rocks, including flysch, shale, sandstone, marble, granite and amphibolite. Tunneling was performed according to NATM principles, with shotcrete, rock bolts and light steel sets. The epicenter of the M_w 7.2 earthquake was located about 20 km from the western portals of the tunnels. The surface rupture of the causative fault was within 3 km of these portals. Peak acceleration and velocity recorded at the nearest strong motion station at Bolu (6 km from the causative fault) were 0.81 g and 66 cm/s, respectively. Observations show that the tunnels performed remarkably well, especially in light of their close proximity to the seismic source. Some of the temporary shotcrete-supported sections, however, collapsed where the worst ground conditions were located, and these sections are discussed below.

- Adjacent twin sections collapsed in a fault zone with weak, intensely slickensided clay gouge and crushed metacrystalline rock with the consistency of silty clay. About 300-m-long sections were affected by full or partial collapse, each located approximated 240 m from the western portals. The tunnels in this location were supported with a 75-mm-thick shotcrete lining with rock bolts and light steel sets. Substantial deformation had been observed in these sections of the tunnel during construction, and it is likely that the initial lining had been subjected to considerable stress under static conditions.
- Partial collapse and severe initial lining deformation were observed near tunnel headings being driven from the eastern portals at the opposite end of the 3.3-km-long highway tunnel. Five-m-diameter tunnels were being driven as pilot bench tunnels along opposite sides of each 18-m-diameter highway tunnel. The intention was to drive the smaller tunnels initially through a fault zone and then partially fill them with concrete to act as reaction blocks for the shotcrete arch installed as the remaining parts of the heading were excavated. Each pilot bore tunnel was supported with a 30-cm-thick shotcrete lining, patterned rock bolts, and light steel sets. The pilot bores were driven in a fault zone with weak, intensely slickensided clay gouge. Thirty-m-long sections of the pilot bores were affected by significant invert heave, ruptured and partially collapsed shotcrete and buckled steel sets.

C.5.5 Summary Observations

Full or partial collapse of tunnels resulting from earthquakes has occurred under highly localized conditions, involving weak, wet and highly fractured rock and soil. Collapse has been confined to relatively short sections of tunnel. In Japan, tunnel collapse has occurred in linings with unreinforced masonry or unreinforced concrete. Failure of the Daikai Subway Station (cut-and-cover tunnel) involved the failure of reinforced concrete columns with inadequate confining steel. The collapsed tunnel sections in Turkey are located in weak, highly fractured clay gouge where construction was in progress and only the initial support system had been installed.

Both the Daikai Subway Station and Bolu Highway Tunnel were affected by near-source ground motions involving high pulses of acceleration and velocity. Peak acceleration and velocity measured at the Kobe Marine Meteorological Observatory (KMMO), which was within several km of the Dakai Station, were 0.81 g and 84 cm/s, respectively. The strong motion recordings at Bolu, which were taken at distances comparable to those separating the Daikai Station and KMMO, show peak acceleration and velocity of 0.81 g and 66 cm/s. Tunnel damage in these instances is associated with high velocity that would have promoted high transient ground strains.

Accelerations inferred from JMA intensities are much less reliable than strong motion recordings. The accelerations estimated in this way from Table C-5 for the Yose, Toke and Kinoura Tunnels are 0.25-0.40 g, 0.025-0.08 g and 0.08-0.25 g, respectively.

In summary, two aspects of the strong motion deserve attention. First, the near-source ground motion affecting the Daikai Station and Bolu Tunnel was high. Although both structures were influenced either by remarkably poor ground (Bolu Tunnels) or weakness in structural support (Daikai Station), they were nonetheless subjected to significant peak velocities. Collapsed tunnels affected by the Kanto and Noto Peninsular Offshore earthquakes were apparently subjected to a wide range of accelerations, some of which were relatively small. The most prominent features of these tunnels affecting their seismic vulnerability appears to be poor ground conditions in combination with an unreinforced masonry or concrete lining. It seems reasonable, therefore, to conclude that poor ground and weak lining conditions are the most important factors affecting seismic performance. Strong motion in the near field can supply significant excitation that will promote local collapse in tunnel sections influenced by poor ground and lack of either sufficient or final structural support.

C.6 Empirical Basis of the Tunnel Fragility Curves

Table C-2 presents the database of tunnels used in the development of fragility curves presented in Section 6-3 of the main report. Table C-15 summarizes this data set.

PGA (g)	All Tunnels	DS = 1	DS = 2	DS = 3	DS = 4
0.07	30	30	0	0	0
0.14	19	18	1	0	0
0.25	22	19	2	0	1
0.37	15	14	0	0	1
0.45	44	36	6	2	0
0.57	66	44	12	9	1
0.67	19	3	7	8	1
0.73	2	0	0	2	0
Total	217	164	28	21	4

Table C-15. Complete Bored Tunnel Database (Summary of Table C-2)

Tables C-16 through C-19 summarize the data sets based on bored tunnels with specific liner systems. Note that for a tunnel with multiple liner systems, the tunnel is classified according to the “best” liner type in the tunnel, according to the following ranking: unlined, timber/masonry/brick, unreinforced concrete, reinforced concrete/steel.

PGA (g)	Unlined Tunnels	DS = 1	DS = 2	DS = 3	DS = 4
0.05	5	5	0	0	0
0.13	4	4	0	0	0
0.25	10	9	1	0	0
0.35	2	1	0	0	1
0.42	2	0	2	0	0
0.55	2	0	1	1	0
0.66	2	0	1	1	0
0.73	1	0	0	1	0
Total	28	19	5	3	1

Table C-16. Unlined Bored Tunnels

PGA (g)	Timber or Masonry Lined Tunnels	DS = 1	DS = 2	DS = 3	DS = 4
0.26	2	1	0	0	1
0.40	1	1	0	0	1
0.42	4	3	1	0	0
0.60	2	0	0	2	0
0.67	5	0	1	4	0
Total	14	5	2	6	1

Table C-17. Bored Timber and Masonry/Brick Lined Tunnels

PGA (g)	Unreinforced Concrete Lined Tunnels	DS = 1	DS = 2	DS = 3	DS = 4
0.08	13	13	0	0	0
0.13	6	5	1	0	0
0.23	3	2	1	0	0
0.38	8	8	0	0	0
0.45	33	28	3	2	0
0.57	53	39	9	4	1
0.67	8	1	4	3	0
0.73	1	0	0	1	0
Total	125	96	18	10	1

Table C-18. Bored Unreinforced Concrete Lined Tunnels

PGA (g)	Reinforced Concrete/ Steel Lined Tunnels	DS = 1	DS = 2	DS = 3	DS = 4
0.07	9	9	0	0	0
0.15	5	5	0	0	0
0.27	6	6	0	0	0
0.35	4	4	0	0	0
0.45	4	4	0	0	0
0.57	6	3	2	1	0
0.66	4	2	1	0	1
Total	38	33	3	1	1

Table C-19. Bored Reinforced Concrete or Steel Lined Tunnels

C.7 References

- Asakura, T., and Sato, Y., "Mountain tunnels damage in the 1995 Hyogoken-Naibu earthquake," QR of RTRI, Vol. 39, No. 1, 1998.
- Dowding, C.H. and Rozen, A., "Damage to Rock Tunnels from Earthquake Shaking," *Journal of the Geotechnical Engineering Division*, American Society of Civil Engineers, New York, NY, Feb. 1978.
- ASCE, "Evaluation of Seismic Fragility and Validation of Probabilistic Models," The Fragility Evaluation/Validation Subgroup Joint Working Group on Seismic PRA of the ASCE Dynamic Analysis Committee, Draft Report, April 1985.
- Chang, C.-Y., Power, M.S., Idriss, I.M., Somerville, P.G., Silva, W., and Chen, P.C., *Engineering characterization of ground motion – Task II: Observational data on spatial variations of earthquake ground motion*, Report prepared for US Nuclear Regulatory Commission, NUREG/CR-3805, Vol. 3, 1986.
- Dowding, C.H. and Rozen, A., "Damage to Rock Tunnels from Earthquake Shaking," *Journal of the Geotechnical Engineering Division*, American Society of Civil Engineers, New York, NY, Feb. 1978.
- HAZUS, *Earthquake Loss Estimation Methodology, Technical Manual, Volume II*, prepared by the National Institute of Building Sciences for Federal Emergency Management Agency, 1997.
- Kunita, M., Takemata, R., and Lai, Y., "Restoration of a Tunnel Damaged by Earthquake," in *Tunneling and Underground Space Technology*, Vol. 9, No. 4, pp. 439-448, 1994.
- Kunita, M., et al., "Rehabilitation of Tunnel Damage caused by Noto Peninsula Offshore Earthquake," *Tunnels and Underground*, Vol.24, No.11, pp. 7-13, 1993 (in Japanese).
- McCann, M.W., Sauter, F., and Shah, H.C., "A Technical Note on PGA-Intensity Relationship with Applications to Damage Estimation," *BSSA*, Vol. 7, No. 2, pp 631-637, 1980.
- O'Rourke, T.D. and Shiba, Y., *Seismic Performance and Design of Tunnels: Annual Report*, MCEER Highway Project, Sponsored by U.S. Department of Transportation, Federal Highway Administration, FHWA Contract DTFH61-92-C-00106, 1997.
- Owen, G.N. and Scholl, R.E., *Earthquake Engineering of Large Underground Structures*, Federal Highway Administration and National Science Foundation, FHWA/RD-80/195, Jan. 1981.
- Power, M.S., Rosidi, D., and Kaneshiro, J., Gilstrap, S.D., and Chiou, S.J., *Summary and Evaluation of Procedures for the Seismic Design of Tunnels*, Multidisciplinary Center for Earthquake Engineering Research, Technical Report MCEER-98-XXXX, Draft Report, Sept. 1998.
- Sadigh, K., Chang, C.-Y., Abrahamson, N.A., Chiou, S.-J., and Power, M.S., "Specification of long-period ground motions: updated attenuation relationships for rock site conditions and adjustments factors for near-fault effects," *Proceedings of Applied Technology Council Seminar*


on Seismic Isolation, Passive Energy Dissipation, and Active Control, Publication No. ATC-17-1 San Francisco, California, p. 59-70, March 1993.

Sadigh, K., Chang, C.-Y., Egan, J.A. Makdisi, F.I., and Youngs, R.R., "Attenuation Relationships for Shallow Crustal Earthquakes Based on California Strong Motion Data," *Seismological Research Letters*, Vol. 68, No. 1, p. 180-189, 1997.

Sharma, S., and Judd, W.R., "Underground Opening Damage From Earthquakes," *Engineering Geology*, Vol. 30, 1991.

Woodward-Clyde Consultants, Personal communication, 1995.

C.8 Figures



LEGEND

- No damage
- Minor damage, due to shaking
- △ Damage from shaking
- ⊠ Near portal
- ⊞ shallow cover

Figure C-1. Peak Surface Acceleration and Associated Damage Observations for Earthquakes [after Dowding and Rozen, 1978]




Figure C-2. Summary of Empirical Observations of Seismic Ground Shaking-induced Damage for 204 Bored Tunnels [after Power et al, 1998]




Figure C-3. Map of Japan Showing Locations of 16 Earthquakes in Tunnel Database




Figure C-4. Deformations of Cut-and-cover Tunnel for Kobe Rapid Transit Railway [after O'Rourke and Shiba, 1997]

D. Commentary - Canals

D.1 1979 Imperial Valley Earthquake

The 1979 Imperial Valley M 6.5 earthquake caused widespread damage to irrigation canals. The following descriptions are adapted from [Dobry et al].

The Imperial Valley is located near the US-Mexico border in Southern California. The area is flat and landslide movements are not significant in the area. Water for domestic, industrial and irrigation purposes originates at the Colorado River and is transported to a network of canals by the All-American Canal. The canals are either unlined or are lined with unreinforced concrete.

The most extensively damaged canal was the All-American Canal, constructed in the late 1930s. The total damage to the canal was estimated to be about \$982,000 [Youd and Wieczorek]. Settlements, slumps, incipient slumps and incipient lateral spreads occurred along a 13-km-long section between Drop No. 5 near the Ash Canal and the East Highline Canal. The damage was concentrated on a 1.5-km-long section of the All American Canal, near the Alamo River. The repairs were made rapidly, preventing detailed mapping of the embankment deformations. Rotational earth slumps threatened to breach the canal, and incipient slumps, lateral spreads and many undifferentiated fissures caused extensive cracks on the embankment and also in the compacted fill around the structures. Along the All-American Canal, the damage was distributed as far as 10 km east and 3 km west of the causative Imperial fault. Youd and Wieczorek reported no evidence of large scale liquefaction around the canal, but localized liquefaction may have contributed to failure in some places.

Slumping and incipient slumping extended for about 500 m along the east side of the Highline Canal.

Both sides of the South Alamo Canal were badly cracked for a length of about 100 m; crack widths were about 15 mm and vertical crack offsets were 50 to 100 mm. At another location, the east bank showed fissures in a 500 m length. These fissures were caused by incipient slumping or lateral spreading towards the canal. The cracks at this site showed as much as 100 mm of opening and vertical offset.

The Barbara Worth Drain canal was also damaged in this earthquake.

In 1940, a M 7.1 earthquake occurred on much of the same fault as in the 1979 event. In the 1940 earthquake, damage to canals included Holtville Main Drain, All-American, Central Main, Alamo and Solfatara, for a total length of 119.7 km of damaged canal. The damage to these canals in the 1940 event was more severe than in the 1979 event. Although the 1940 damage was not clearly associated with the occurrence of liquefaction, the soil in the affected areas did contain sand layers; soils in the areas without canal damage did not.

Based on damage to the canal and irrigation ditch network in the 1979 earthquake, the authors analyzed the repair rate as a function of distance and recorded PGAs at representative distances from the nearest fault rupture. The results are shown in [Figure D-1](#). In Figure D-1a, “conduit” represents either a canal or an irrigation ditch. The following trends are noted:

- The repair rate is highest for locations closest to the fault. For PGAs in the range of 0.5g to 0.8g, with corresponding PGVs of 22 in/sec to 35 in/sec, repair rates are about 0.15 to 0.25 repairs per kilometer. Repair rates drop to about one-tenth this rate when PGAs/PGVs have attenuated to about 0.2g/9 in/sec.
- Due to the lack of detailed design information for each canal or ditch in the area, we do not attempt to provide a fragility curve based on this information.

With regards to the operation of the All-American Canal in the 1979 earthquake, it was reported [EERI, 1980] that at the time of the earthquake, 3,700 cubic feet per second (cfs) of water was flowing in the canal. The bulk of this water was used for irrigation. Due to damage in the canal, flow was reduced to about 700 cfs, in order to prevent flooding over damaged levees of the canal. As repairs were made to the canal, flow was increased, reaching the required flow of 4,100 cfs by October 19, four days after the earthquake. During the four-day operation of the canal at low flows, there was sufficient raw water in an open cut reservoir for the city of El Centro's water treatment plant and, therefore, the damage to the canal did not directly affect treated water deliveries to customers in the city of El Centro—although damage to distribution pipelines did affect treated water deliveries.

D.2 1980 Greenville Earthquake

The Contra Costa Canal is operated by the Contra Costa Water District. It transports raw water from the Delta to the City of Concord, California, and other nearby localities.

This canal underwent minor levels of ground shaking in the 1980 Greenville earthquake. PGAs were on the order of 0.02g to 0.10g. Minor damage was observed as a result of earth sloughing from adjacent earthen banks.

D.3 1989 Loma Prieta Earthquake

The Contra Costa Canal underwent minor levels of ground shaking in the 1989 Loma Prieta earthquake. PGAs were on the order of 0.02g to 0.10g. No damage was observed.

The South Bay Aqueduct is operated by the State of California, Division of Water Resources. It transports water from the Delta to the cities of Livermore, Pleasanton and San Jose, California. This canal underwent moderate levels of ground shaking in the 1989 Loma Prieta earthquake. However, no canal lining damage was sustained. A bridge adjacent to the canal suffered moderate damage.


D.4 References

Dobry, R., Baziar, M. H., O'Rourke, T. D., Roth, B. L., and Youd, T. L., "Liquefaction and Ground Failure in the Imperial Valley, Southern California During the 1979, 1981 and 1987 Earthquakes," in *Case Studies of Liquefaction and Lifeline Performance During Past Earthquakes, Volume 2, United States Case Studies*, Eds. T. D. O'Rourke and M. Hamada, NCEER Report 92-0002, Feb. 1992.


EERI, *Imperial County, California Earthquake Reconnaissance Report*, Earthquake Engineering Research Institute, G. Brandow Coordinator, D. Leeds, Editor, Feb. 1980.

Youd T.L. and Wiczorek G.F., "Liquefaction and Secondary Ground Failure in the Imperial Valley California Earthquake Oct 15, 1979," in *The Imperial Valley California Earthquake*, US Geological survey, Professional Paper 1254, pp. 223-246, 1982, Oct. 1979.

D.5 Figures



D-1a. Repair Rate versus Distance to Nearest Fault



D-1b. Repair Rate versus PGAs Recorded at Similar Distances to the Nearest Fault

Figure D-1. Canal and Ditch Repair Rates, 1979 Imperial Valley Earthquake [after Dobry et al]

E. Basic Statistical Models

Appendix E describes the general process used in establishing fragility curves.

E.1 Options

Three general approaches can be used in developing fragility curves. These are:

- **The empirical approach.** This involves use of observed damage/non-damage from past earthquakes.
- **The analytical approach.** This involves the use of specific engineering characteristics of a component to assess its seismic capacity in a probabilistic way.
- **The engineering judgment approach.** This involves the review of available information by cognizant engineers and making an informed judgment as to the capacity of a component.

Part 1 uses all three approaches in developing fragility curves for the various components. Appendix E provides the mathematical models used in this process. Appendix G provides an alternate approach, called Bayesian Analysis, to standard regression analysis.

E.2 Randomness and Random Variables

Randomness in a parameter means that more than one value is possible; the actual value is, to some degree, unpredictable. Mathematical representation of a random variable is a primary task in any probabilistic formulation.

In a loss estimation study, a prediction of the future is made using information from the past, including experience and judgment whenever possible. Thus, it is necessary to collect all relevant information from the past for this purpose. A typical flow chart of the steps involved is shown in [Figure E-1](#). The information collected will constitute the sample space.

Appendices A-D provide empirical information for some of the water system components. The empirical information is likely to be incomplete, and further effort in reviewing the performance of water transmission system components would yield additional information that could be added to the sample space. It was not feasible in the current effort to consider every known piece of information. By expanding the data in the sample space, it is hoped that better fragility curves can be developed in the future.

The randomness characteristics of any sample space can be described graphically in the form of a histogram, or frequency diagram, as shown in [Figure E-2](#). For a more general representation of the randomness, the frequency diagram can be fitted to some theoretical probability density function (PDF) $f_x(x)$. By integrating the probability density function thus obtained, a cumulative distribution function (CDF) $F_x(x)$ can be obtained.

To describe the PDF or CDF uniquely, some parameters of the distribution need to be estimated. The estimation of these parameters, called statistics, is a key step in the development of fragility curves.

E.2.1 The Normal Distribution

A random variable usually can be described mathematically by a distribution. A random variable can be discrete or continuous. Most commonly used discrete random variable are described by the binomial distribution, Poisson, distribution, geometric distribution, etc. Continuous random variables are generally described by the normal distribution, lognormal distribution, exponential distribution, Gamma distribution, Beta distribution, Chi-Square distribution, etc. Refer to Benjamin and Cornell [1970] for a more complete description of various distributions.

Among the most important statistical parameters are the mean value, μ , which denotes the average of expected value of the random variable, and the standard deviation, σ , which denotes the dispersion of a random variable with respect to the mean value. The coefficient of variation (COV) is the ratio of the standard deviation and the mean value.

For a discrete random variable, the mean and unbiased variance can be calculated as follows:

$$\mu_x = \frac{1}{n} \sum_{i=1}^n x_i$$

$$Var(x) = \frac{1}{n-1} \sum_{i=1}^n (x_i - \mu)^2$$

The standard deviation and COV are calculated from the following relationships once the mean and variance of a random variable are known.

$$\sigma_x = \sqrt{Var(x)}$$

$$COV = \sigma_x / \mu_x$$

E.2.2 Which Distribution Model?

To develop a probabilistic model, the underlying distribution of a random variable and its statistics need to be known. The methods to empirically determine the distribution model are discussed in this section.

In practice, the choice of the probability distribution is often dictated by mathematical convenience. In many engineering evaluations of damage to water system components from past earthquakes, the functional form of the required probability distribution may not be easy to determine, as more than one distribution may fit the available data. The basis of the properties of the physical process may suggest the form of the required distribution.

The required probability distribution may be determined empirically, based entirely on the available observed data. A frequency diagram for the set of data can be constructed and a distribution model can be selected by visual comparison as shown in Figure E-2.

When the distribution model is obtained using this method, or when two or more distributions appear to be plausible probability distribution models, statistical tests (known as goodness-of-fit tests for distributions) can be carried out to verify the distribution model. Two such tests commonly used for this purpose are the Chi-Square χ^2 and the Kolmogorov-Smirnov (K-S)

tests. For this report, the lognormal distribution is assumed in essentially all fragility formulations. This has been done as the lognormal distribution is mathematically convenient. See Section E.6 for further details. Other researchers may find that other dispersion models are better suited for specific applications.

E.2.3 Lognormal Variables

In some special cases, suppose:

$$Y = X_1 \cdot X_2 \cdot L \cdot X_n$$

where X_i is a statistically independent lognormal variable with means μ_{X_i} and standard deviation σ_{X_i} ; then Y is also a lognormal variable.

From an engineering point of view, for loss estimation of water system components, the form of the lognormal distribution has some advantages. The total response, Y , can be represented as the deterministic response value multiplied by a series of correction factors that are random and associated with various uncertainties. Irrespective of the proper distribution of these individual variables X_i , the product of the variable will be approximately lognormal. Another advantage of the lognormal function is that a variable cannot take negative values. For these reasons, it is commonly adopted to model a variable as a lognormal variable rather than a normal variable. Note that whether or not the real world is really “lognormal” is often ignored in the evaluation—but it is convenient that it should be.

Knowing the mean and variance for a random variable X , μ_X and σ_X the two parameters of the lognormal distribution λ_X (logarithmic mean) and ζ_X (logarithmic standard deviation, beta, β) can be obtained as follows:

$$\lambda_X = \ln(\mu_X) - \frac{1}{2} \zeta_X^2$$

and

$$\zeta_X^2 = \ln\left(1 + \frac{\sigma_X^2}{\mu_X^2}\right)$$

Say that x_m is the median (x_{50}) of the variable X . Then,

$$\lambda = \ln(x_m)$$

and the 84th percentile value of X (i.e., one standard deviation higher than the median) is

$$x_{84} = x_{50} e^{\beta} = x_m e^{\zeta}$$

Since X_i s are lognormal, then $\ln(X_i)$ s are normal and

$$\lambda_Y = \text{Expected_Value}(\ln Y) = \sum_{i=1}^n \lambda_{X_i}$$

and

$$\zeta_Y^2 = \text{Var}(\ln Y) = \sum_{i=1}^n \zeta_{X_i}^2$$

E.2.4 Regression Models

Some of the regression models used in this report for buried pipe are of the logarithmic regression form. In other words, if Y_i is the repair rate per 1,000 feet and X_i is the PGV in inches/sec, then:

$$Y_i = \alpha X_i^B z_i$$

where α and B are constants to be determined from a regression analysis, and z_i is the error term. The solution for α and B using least squares methods can be found in many statistics textbooks. Appendix G provides an alternative approach, called Bayesian analysis.

This model can be simplified into the standard linear regression model by taking the log of the equation, thus:

$$\ln Y_i = \ln \alpha + B \ln X_i + e_i$$

E.3 Simulation Methods

When performing loss estimates for water system components, the Monte Carlo simulation technique can be employed. This technique is readily adapted to computer techniques. One of its advantage is that many independent variables can be processed on an individual basis, and the distribution of the dependent variable can be examined by reviewing the results of many independent trials.

The number of simulations to be used will affect the accuracy of the final results. A larger number of simulations will reduce the effects of the tails of the derived distribution.

E.4 Risk Evaluation

Using the procedures described in the previous sections, the uncertainties associated with the random resistance R and the random load S can be quantified. This is graphically shown in [Figure E-3](#). The shaded region in Figure E-3 indicates the region where the loading function (S) is greater than the resistance function (R). The risk that the damage state R occurs is the area represented by the shaded region. Mathematically,

$$\begin{aligned} \text{Risk} &= P(\text{damage state } R \text{ occurs}) = P(R \leq S) \\ &= \int_0^{\infty} \left[\int_0^r f_R(r) dr \right] f_S(s) ds \end{aligned}$$

E.5 Fragility Curve Fitting Procedure

For the fragility curves developed for tanks and tunnels, a best-fit regression analysis was performed. The approach was as follows:

The tanks and tunnels were “binned” into PGA bins. Each bin was for typically for a range of 0.1g, with the exception of PGAs over 0.7g. The higher g bins were wider as there were fewer tunnels in this PGA range. The PGA for each bin was set at the average of the PGA values for each tunnel in that bin. The percent of tunnels reaching or exceeding a particular damage state was calculated for each bin.

A lognormal fragility curve was calculated for each of the damage states. A fragility curve was calculated for all tanks or tunnels which reached damage state 2 (DS2) or above, DS3 or above, DS4 or above, and DS5, as applicable. The fragility curve uses the median acceleration to reach that damage state or above and a lognormal dispersion parameter, β . The best-fit fragility curve was selected by performing a least square regression for all possible fragility curves in the range of $A=0.01g$ to $5.00g$ (in $0.01g$ steps) and $\beta=0.01$ to 0.80 (in 0.01 steps).

Since an unequal number of tanks or tunnels are in each bin, the analysis was performed using an unweighted regression analysis and also a weighted regression analysis. The weighted analysis is considered a better representation.

E.6 Randomness and Uncertainty

In developing or updating fragility curves, this report often separately characterizes “randomness” from “uncertainty.”

Randomness reflects variables in the real world that current technology and understanding cannot explain. In other words, no reasonable amount of additional study of the problem will reduce randomness. Randomness exists in the level of ground motion at two nearby sites, even if they have very similar soil profiles and distances from the fault rupture. Randomness is characterized using a logarithmic dispersion parameter:

$$\beta_R$$

β_R can be determined by doing regressions for ground motion attenuation functions for the suitable parameter of PGA for tanks and tunnels and PGV and PGD for buried pipelines. There are many published references for these values, and it varies based on earthquake magnitude, type of faulting mechanism, type of soil, etc. Recent work by Geomatrix (Power, Wells and Coppersmith, et al) can be used to provide β_R for permanent ground deformations (PGDs), fault offset, liquefaction and landslides.

Uncertainty reflects the uncertainty in the predictions, given the level of simplification taken in the analysis. For example, suppose a water utility wanted to do a quick earthquake loss estimate for buried transmission pipelines without having to do a detailed effort to ascertain exactly what type of buried pipelines are in use at which locations, how old they are, what their leak history is, which soils are most susceptible to corrosion, which soils are most susceptible to PGDs, what level of corrosion protection has been taken for a particular pipeline, and so on. In such a case, the fragility curve used should take into account that there is uncertainty in the pipeline inventory, as well as how that inventory would respond to a given level of ground motion. Uncertainty is characterized using a logarithmic dispersion parameter:

$$\beta_U$$

The total uncertainty is then expressed as:

$$\beta_T = \sqrt{\beta_R^2 + \beta_U^2}$$

E.6.1 Total Randomness and Uncertainty

The method by which randomness and uncertainty are tabulated for this report considers the following:

- A possible update of the water pipeline/transmission system component fragilities in the HAZUS computer program. HAZUS makes many simplifying assumptions in order to get a computer program that is both easy to use and easy to program. Only one dispersion parameter is allowed in HAZUS, which is the equivalent of β_T .
- Depending on the source data sets used to establish the uncertainty parameters, the underlying uncertainty in the empirical data may or may not include β_R . A good quality data set using GIS techniques on a well document earthquake would primarily reflect β_U . In either case, the fragility curves in Part 1 must clearly indicated whether or not the dispersion parameter includes β_R . In so doing, the results in Part 1 can be suitably interpreted to allow for separation of uncertainty in ground motion and inventory response.
- To summarize, it would be ideal to present three measures of uncertainty: β_T , if used in HAZUS or HAZUS-like programs; β_R , so this could be varied by the type of earthquake and by future advances in geotechnical descriptions of ground motion; and β_U , so that this can be used in programs that are more sophisticated than HAZUS, and for users who establish a high-quality inventory database.

E.7 The Model to Estimate Fragility of a Structure or Piece of Equipment

The variability of how a structure or piece of equipment can respond can be described by a probability density function (PDF) as shown in Figure E-3 ($f_r(r)$). Rarely does the engineer consider the shape of the PDF of the item being designed; instead, the item is designed to “code.” For convenience, we call designing to code a “deterministic” design. Generally conservative parameters are used in deterministic design so that only a low probability exists that the actual seismic demand ‘S’ exceeds the actual seismic capacity. It is neither necessary nor desirable for the deterministic design to be so conservatively performed that the probability of failure is negligibly low.

In deterministic analysis, the deterministic factor of safety, F_D , is defined as the ratio of the deterministic code capacity, C_D , to the deterministic computed response, R_D , i.e.,

$$F_D = \frac{C_D}{R_D}$$

In probabilistic analysis, both the capacity C and the response R are random variables. Thus, the factor of safety is given by:

$$F = \frac{C}{R}$$

which is also a random variable. A capacity factor, F_C , can be defined as the ratio of the actual capacity, C , to the deterministic code capacity, C_D . Similarly, a response factor, F_R , is defined as the ratio of the deterministic computed response, R_D , to the actual response R , i.e.,

$$F_C = \frac{C}{C_D}; \quad F_R = \frac{R_D}{R}$$

Thus, the probabilistic factor of safety, F , can be defined in terms of the deterministic factor of safety, F_D , by:

$$F = F_C \cdot F_R \cdot F_D$$

The probability of failure is the probability that the factor of safety, F , is less than 1. The reliability is the probability that the factor of safety, F , is 1 or greater.

Computation of the probability of failure is tractable mathematically when the capacity and the response factors, F_D and F_R , are assumed to be lognormally distributed random variables. F is a lognormal random variable if F_D and F_R are lognormal random variables. The median value, \hat{F} , and the logarithmic standard deviation, β_F of F are given by:

$$\hat{F} = \hat{F}_C \cdot \hat{F}_R \cdot F_D$$

$$\beta_F^2 = \beta_C^2 + \beta_R^2$$

where \hat{F}_C and \hat{F}_R are the median values and β_C and β_R and the logarithmic standard deviations for the capacity, F_C , and response, F_R , factors. The probability of failure is then given by:

$$P_f = \Phi \left(\frac{\ln \left(\frac{1}{\hat{F}} \right)}{\beta_F} \right)$$

where Φ is the standard cumulative distribution function.

Section E.7 is concerned with estimating the capacity factor random variable, F_C , that, when combined with the response random variable, F_R , and a code-specified deterministic factor of safety, F_D , can be used to estimate a probabilistic factor of safety, F , and a probability of failure.

Section 3 of Part 1 of this report briefly describes how to compute F_R . It is beyond the scope of the current effort to determine how to compute seismic response at a location.

Under dynamic loading, the capacity factor is assumed to be made up of two parts:

$$F_C = F_S \cdot F_\mu$$

where F_S represents the strength factor for an equivalent static loading and F_μ represents the added capacity due to the ductility of the structure and the fact that the loading has limited energy content.

E.8 References

Benjamin, J. R. and Cornell, C. A., *Probability, Statistics and Decision for Civil Engineers*, McGraw-Hill.

E.9 Figures




Figure E-1. Steps in a Probabilistic Study




Figure E-2. Typical Histogram or Frequency Diagram




Figure E-3. Risk Evaluation

F. Example

Data reflecting a portion of a California water transmission aqueduct built in the 1930s is examined in Appendix F. The aqueduct consists of 33,400 feet of 62-inch diameter concrete pipe with steel cylinder and 48,000 feet of 66-inch diameter welded steel pipe.

For the purpose of illustrating how to apply the guideline procedures, this portion of pipeline is further divided into the following four segments according to their surface geological conditions:

Segment	Length	Material	Joint	Avg. Dist. from Fault Considered	Surface Geology
1	7,200 ft	Conc. w/ steel cyl.	Welded	2.3 mi.	Rock-like soils
2	30,500 ft	Steel	Welded	0.6 mi.	Firm soils
3	17,500 ft	Steel	Welded	1.5 mi.	Firm Soils
4	26,200 ft	Conc. w/ steel cyl.	Welded	3.7 mi.	Rock-like soils

Table F-1. Water Transmission Aqueduct Example

[Figure F-1](#) is a simplified map of the water transmission system of Table F-1. The issue at hand is to estimate the number of repairs that may be required for this portion of the pipeline during an earthquake with Richter moment magnitude of 7.1 ($M_w 7.1$) generated by the fault near the pipeline.

Tables F-2a and F-2b give the summary results of the analysis.

Segment	PGA	Number of Repairs				
		Ground Shaking	Liquefaction		Landslide	Total
			Settlement only	With Lateral Spread		
1 ¹	0.58g	0.18		–	–	0.18
2 ²	0.55g	0.24	0.23	–	–	0.47
3 ³	0.40g	0.0		2.73	–	2.73
4 ⁴	0.40g	0.60		–	1.49	2.09
Total	–	1.02	0.23	2.73	1.49	5.47

Notes.

1. Detailed calculation provided in Section F.1.
2. Detailed calculation provided in Section F.2.
3. Detailed calculation provided in Section F.3.
4. Detailed calculation provided in Section F.4

Table F-2a. Summary Results (Dry Conditions)

Segment	PGA	Number of Repairs				
		Ground Shaking	Liquefaction		Landslide	Total
			Settlement only	With Lateral Spread		
1 ¹	0.58g	0.18		–	–	0.18
2 ²	0.55g	0.24	0.23	–	–	0.47
3 ³	0.40g	0.0		2.73	–	2.73
4 ⁴	0.40g	0.50		–	15.1	15.6
Total	–	0.92	0.23	2.73	15.1	19.0

Notes [1] to [4]. See Notes for Table F-2a.

Table F-2b. Summary Results (Wet Conditions)

F.1 Calculations – Segment 1

This segment of welded steel pipeline is subject to strong ground shaking from the nearby fault. The pipe traverses an area best characterized as rock or rock-like material without potential for liquefaction or landslide.

Ground Shaking

Step 1. Obtain anticipated earthquake magnitude generated from an active fault. Calculate the site specific peak ground acceleration (PGA) from this earthquake.

Assume $M_w = 7.1$ and average PGA for this segment = 0.58g. The selection of the moment magnitude is beyond the scope of this report. Section 3.2 of Part 1 provides some guidance, differentiating between deterministic and probabilistic definitions of earthquakes. Lacking input from knowledgeable seismologists, a rational approach would be to evaluate the pipeline for a specific scenario earthquake. Select the moment magnitude M_w for the scenario earthquake based on the length of the fault (L_r in km), using an expression like:

$$\log_{10} L_r = -2.36 + 0.58M_w$$

Once the magnitude of the scenario earthquake is selected, calculate the median horizontal ground acceleration (PGA) by using an equation like F.1—other equations might be more suitable, depending on location in the US, type of fault mechanism, etc. This assumes the pipeline is underlain by rock or rock-like soils.

$$\ln Z = -1.274 + 1.1M - 2.1 \left[\ln \left(R + e^{-0.48451 + 0.524M} \right) \right] \quad (\text{eqn. F.1})$$

Assuming the average distance to the fault is 2.3 miles (= 3.7 km), gives $\ln Z = -0.543$, or $Z = 0.58g$.

Step 2: Calculate peak ground velocity (PGV) with a suitable attenuation relationship.

For $M=7.1$ and rock-like soil conditions, assume $PGV = 49.4 \text{ cm/sec} = 19.4 \text{ inch/sec}$.

Step 3: Calculate number of repairs per 1,000 feet based on PGV, pipe material, pipe joints, soil corrosiveness and pipe diameter.

From Table 4-4, the repair rate for the “backbone” pipe fragility curve is $RR = 0.00187 * PGV = 0.0363$ repairs per 1,000 feet. From Table 4-5, apply $K1 = 0.7$ (large-diameter concrete cylinder pipe with lap welded joints), so the total repair rate is 0.0254 repairs per 1,000 feet.

Step 4: Calculate total number of repairs in this segment due to ground shaking

$N = 0.0254 * 7200/1000 = 0.18$.

F.2 Calculations – Segment 2

This segment of welded steel pipeline is subject to strong ground shaking from the nearby fault. This segment also traverses reasonably competent soils that are subject to localized liquefaction.

Ground Shaking

Step 1. Obtain anticipated earthquake magnitude generated from an active fault. Calculate the site-specific peak ground acceleration (PGA) from this earthquake.

Calculate the median horizontal ground acceleration (PGA) using an attenuation model such as in Equation F.2. Again, other equations may be more suitable. This assumes the pipeline is underlain by firm soils.

$$\ln Z = -2.17 + 1.0M - 1.7 \left[\ln \left(R + 0.3825e^{0.5882M} \right) \right] \quad (\text{eqn. F.2})$$

Assuming the average distance to the fault is 0.6 miles (= 1 km) gives $Z = 0.55g$.

Step 2: Calculate peak ground velocity (PGV) with suitable attenuation relationship.

For $M=7.1$ and firm soil conditions, $PGV = 73.7 \text{ cm/sec} = 29 \text{ inch/sec}$.

Step 3: Calculate number of repairs per 1,000 feet based on PGV, pipe material, pipe joints, soil corrosiveness and pipe diameter.

From Table 4-4, the repair rate for the “backbone” pipe fragility curve is $RR = 0.00187 * PGV = 0.0543$ repairs per 1,000 feet. From Table 4-5, apply $K1 = 0.15$ for large-diameter, single lap welded steel pipe, so the total repair rate is 0.00814 repairs per 1,000 feet.

Step 4: Calculate total number of repairs in this segment due to ground shaking

$N = 0.00814 * 30500/1000 = 0.25$. But note that the value $N=0.25$ assumes that the entire length of Segment 2 is not subject to liquefaction. As described below, about 4% of the length is subject to liquefaction. So the damage in the ground shaking zone is 96% of this value ($=0.96 * 0.25$).

Liquefaction

Step 1: For a scenario earthquake, calculate the level of shaking (PGA) at the particular location of the component being evaluated.

M = 7.1, PGA = 0.55g (same as the value from the ground shaking calculations)

Note that geotechnical investigation done by knowledgeable professionals is strongly recommended. Steps 2 through 5 below are to be used only when detailed geotechnical investigation is unavailable.

Step 2: Establish the geologic unit for the near surface environment at the component location.

From a site-specific geotechnical report or USGS or CDMG publication, determine:

- Type of deposit: Alluvial.
- Age of deposit: Holocene

Chance of susceptibility to liquefaction is “Low.”

Step 3: Given the PGA, geologic unit and liquefaction susceptibility description, the estimated ground water depth and the magnitude of the earthquake, calculate the probability that liquefaction occurs at the location.

For this PGA level, earthquake magnitude and ground water table, assume the probability of liquefaction is 80% for liquefiable deposits. Assume 5% of the deposits are liquefiable. Thus, the probability that a specific location liquefies is 4% ($=0.8 * 0.05$).

Step 4: Given that the site liquefies, calculate the maximum permanent ground deformation or the probabilities for different settlement ranges.

Assume the settlement ranges in Table F-3 are prepared using techniques outside the scope of this report.

Settlement Range (in.)	Probability of settlement due to 4% probability of liquefaction
≤ 1	4% * 35% = 1.4%
1 – 3	4% * 60% = 2.4%
3 – 6	4% * 4% = 0.16%
6 -12	4% * 1% = 0.04%

Table F-3. Settlement Ranges – Segment 2

Step 5: If there is no lateral spread (e.g., the pipe is not adjacent to an open cut or a slope), calculate the repair rates per 1,000 feet using the vertical ground settlement.

From Table 4-4 and 4-6, the repair rate for the “backbone” pipe fragility curve is $RR = K2 * 1.06$ * PGD repairs per 1,000 feet. From Table 4-6, apply $K2 = 0.15$ for large-diameter, single lap welded steel pipe. The vertical displacement will be the total estimated PGD parameter.

The average values of the settlement ranges in the first column of Table F-3 are used as the estimated PGDs.

Assumed estimated PGD (in.)	Number of repairs per 1,000 ft. (Assume 100% probability for each estimated PGD)	Number of repairs per 1000 ft.
1	$n = 0.15 * 1.06 * (1)^{0.319} = 0.16$	$n = 0.16 * 1.4\% = 0.00224$
2	$n = 0.15 * 1.06 * (2)^{0.319} = 0.20$	$n = 0.20 * 2.4\% = 0.0048$
4	$n = 0.15 * 1.06 * (4)^{0.319} = 0.25$	$n = 0.25 * 0.16\% = 0.00040$
9	$n = 0.15 * 1.06 * (9)^{0.319} = 0.32$	$n = 0.32 * 0.04\% = 0.00013$

Table F-4. Pipe Repair Rates – Segment 2

Repair rate per 1,000 feet = $0.00224 + 0.0048 + 0.00040 + 0.00013 = 0.0076$.

Step 6: Calculate total number of repairs in this segment due to liquefaction.

$$N = .0076 * 30,500/1000 = 0.23$$

Note that the PGD algorithm already includes damage due to PGV.

Step 7: Calculate total number of repairs (Ground Shaking and Liquefaction) for Segment 2.

The total number of repairs for Segment 2:

Liquefaction zone: $N = 0.23$

Ground shaking zone without liquefaction:

$$N = 0.25 * 0.96 = 0.24$$

$$\text{Total} = 0.23 + 0.24 = 0.47.$$

F.3 Calculations – Segment 3

Repair rates for liquefaction with and without lateral spread are calculated. Assume $M=7.1$ and average PGA for this segment= $0.5g$. The pipeline is assumed to be buried and to traverse liquefiable soils near a body of water. It is also assumed that the pipe has been installed using typical cut-and-cover trench techniques without special soil improvement to address liquefaction hazards. While the soil within the pipeline trench may be of various materials, the native soils underlying and adjacent to the pipe trench are assumed to control the overall potential for PGDs along the length of pipeline.

Liquefaction

Step 1: For a scenario earthquake, calculate the level of shaking (PGA) at the particular location of the component being evaluated.

$M = 7.1$, $PGA = 0.40g$. Note that for this segment, the pipe traverses modern young soils, and moderately high values of PGA ($0.4g$) may still have very high values of PGV (over 35 inches/sec).

Note that geotechnical investigation done by knowledgeable professionals is strongly recommended. Steps 2 through 6 below are to be used only when no detailed geotechnical investigation is unavailable.

Step 2: Establish the geologic unit for the near surface environment at the component location.

From a site-specific geotechnical report or USGS or CDMG publication, determine:

- Type of deposit: Delta
- Age of deposit: Modern

Chance of susceptibility to liquefaction is “Very High.”

Step 3: Given the PGA, geologic unit and liquefaction susceptibility description, the estimated ground water depth and the magnitude of the earthquake, calculate the probability that liquefaction occurs at the location.

For this PGA level, earthquake magnitude and ground water table, assume the probability of liquefaction is 95% for liquefiable deposits. Assume 25% of the deposits are liquefiable. Thus, the probability that a specific location liquefies is 24% ($=0.95 * 0.25$).

Step 4: Given that the site liquefies, calculate the maximum permanent ground deformation and the probabilities for different PGD ranges.

Step 4a. No Lateral Spread. Table F-5 gives a range of settlements for the specific soil deposits and earthquake conditions.

Settlement Range (in.)	Probability of settlement due to 24% probability of liquefaction
1 – 3	24% * 5% = 1.2%
3 – 6	24% * 25% = 6%
6 - 12	24% * 50% = 12%
> 12	24% * 20% = 4.8%

Table F-5. Settlement Ranges – Segment 3

Step 4b. With Lateral Spread. Assume an analysis is performed that determines that a lateral spread with PGD = 82 inches is possible at locations so susceptible.

Step 5: For areas with no lateral spread, calculate the repair rates per 1,000 feet using the vertical ground settlement.

From Table 4-4 and 4-6, the repair rate for the “backbone” pipe fragility curve is $RR = K2 * 1.06 * PGD$ repairs per 1,000 feet. From Table 4-6, apply $K2 = 0.15$ for large-diameter, single lap welded steel pipe. The vertical displacement will be the total estimated PGD parameter.

The average values of the settlement ranges in the first column of Table F-6 are used as the estimated PGDs.

Assumed estimated PGD (in.)	Number of repairs per 1000 ft. (Assume 100% probability for each estimated PGD)	Number of repairs per 1,000 ft.
2	$n = 0.15 * 1.06 * (2)^{0.319} = 0.20$	$n = 0.20 * 1.2 \% = 0.0024$
4	$n = 0.15 * 1.06 * (4)^{0.319} = 0.25$	$n = 0.25 * 6.0 \% = 0.015$
9	$n = 0.15 * 1.06 * (9)^{0.319} = 0.32$	$n = 0.32 * 12 \% = 0.038$
12	$n = 0.15 * 1.06 * (12)^{0.319} = 0.35$	$n = 0.35 * 4.8 \% = 0.017$

Table F-6. Pipe Repair Rates – Segment 3

Repair rate per 1000 feet = $0.0024 + 0.015 + 0.038 + 0.017 = 0.072$ (settlement only).

Step 6: For area adjacent to an open cut where lateral spread is possible, calculate the repair rates per 1,000 feet using the vector sum of the ground settlement and the lateral displacement.

The vector sum of the ground settlement and the lateral spread displacement should be used for PGD when lateral spread is possible. Assume the most probable settlement range is 6 to 12 inches. Conservatively, use the high value to calculate PGD.

$$\therefore PGD = \sqrt{(12)^2 + (82)^2} = 83 \text{ in.}$$

$K_2 = 0.15$ (steel pipe with welded joints), per Table 4-6.

$$\text{Repair rate per 1,000 feet} = 0.15 * 1.06 * (83)^{0.319} = 0.65.$$

As the repair rate with lateral spread (0.65) is higher than the repair rate from settlement only (0.072), use the higher value in zones with liquefaction with potential for lateral spread.

Step 7: Calculate the total number of repairs (Ground Shaking and Liquefaction) for Segment 3.

The total number of repairs for Segment 3:

$$\text{Liquefaction zone: } N = 0.24 * 0.65 * 17,500/1,000 = 2.73.$$

Check damage rate if there was no liquefaction.

$$\text{Assume } PGV = 35 \text{ inches per second. } RR = 0.15 * 0.00187 * 35 = 0.0098 \text{ per 1,000 ft.}$$

$$N = 0.76 * .0098 * 17,500/1,000 = 0.13. \text{ since } 0.13 \ll 2.73, \text{ liquefaction rate controls.}$$

F.4 Calculations – Segment 4

Repair rates for Segment 4 include the potential for landslide hazards along this length of pipeline. It is assumed that the entire Segment 4 length is located in sloped terrain.

Landslide

Step 1: For a scenario earthquake, calculate the level of shaking (PGA) at the particular location of the component being evaluated.

Assume an average PGA for this segment=0.4g, and that the typical soil profile is rock. While landslide zones may be characterized as having up to a few tens of feet of colluvial material, it is still reasonable to use a rock-type attenuation model to estimate ground motions at the pipe locations.

$$\therefore A_{is} = 0.4g$$

Note that geotechnical investigation done by knowledgeable professionals is strongly recommended. Steps 2 thru 4 below are to be used only when detailed geotechnical investigation is unavailable.

Step 2: Determine slope angle and geologic group of the region or subregion being evaluated.

Slope: 20° to 30°, based on site survey.

Geologic Group: Weakly cemented rock

Step 3: Determine the susceptibility category, the critical acceleration, a_c , and the percentage of the landslide susceptibility area that is expected to be susceptible to landslide during dry and wet conditions.

Dry condition : $\Rightarrow a_c = 0.30g$

Wet condition : $\Rightarrow a_c = 0.10g$

Assume the following percentage of the pipeline lengths that are within susceptible soils:

Dry condition: \Rightarrow Percentage of Map Area with Landslide Susceptible Deposit = 8%

Wet condition: \Rightarrow Percentage of Map Area with Landslide Susceptible Deposit = 25%

Step 4: Estimate amount of PGD due to landslide based the critical acceleration (a_c), the induced acceleration (a_{is}), and the expected number of cycles.

Dry condition: $E[PGD] = 0.57$ in.

Wet condition: $E[PGD] = 23$ in.

Step 5: Calculate the repair rates for dry and wet conditions.

Dry condition:

$$N = 0.8 * 1.06 * (0.57)^{0.319} = 0.71 \text{ per 1,000 ft. (covers 8\% of pipe length).}$$

$$N = 0.08 * 0.71 * 26,200/1,000 = 1.49 \text{ repairs.}$$

Wet condition:

$$N = 0.8 * 1.06 * (23)^{0.319} = 2.31 \text{ per 1,000 ft. (covers 25\% of pipe length).}$$

$$N = 0.25 * 2.31 * 26,200/1,000 = 15.1 \text{ repairs.}$$

Step 6: Calculate the total number of repairs (Ground Shaking) for Segment 4.

The total number of repairs for Segment 4:

Assume $PGV = 0.4g * 85 \text{ cm/g} = 13.4 \text{ inches per second}$.

$RR = 1.0 * 0.00187 * 13.4 = 0.025 \text{ per } 1,000 \text{ ft}$.

$N = 0.92 * 0.025 * 26,200/1,000 = 0.60 \text{ (dry conditions)}$.

$N = 0.75 * 0.025 * 26,200/1,000 = 0.50 \text{ (wet conditions)}$.

F.5 Figures




Figure F-1. Example Water Transmission System

G. Bayesian Estimation of Pipe Damage

G.1 Introduction

Appendix G provides an alternative approach for developing fragility curves to estimate damage potential for buried pipelines.

As described in Section 4.6.2 of Part 1, the complete empirical dataset exhibits a lot of scatter. It is the judgment of the authors that the form of the fragility function used to describe damage to buried pipelines due to wave passage effects is to use a straight line through the entire data set. Alternative approaches are investigated in Part 1, including a power model. The decision to use a straight line through the data set, fitted so that 50% of the empirical data points lied below and 50% lied above the curve, was selected for the following reasons:

- The scatter in the empirical dataset is large. Many different types of curves can be fitted through the dataset, but no one would be much better than the other, except for mathematical convenience.
- The theoretical basis for estimating strain in the ground from wave propagation is that it is linearly correlated with maximum ground velocity. For wave propagation, pipe strain is often assumed to be the same as the ground strain, which basically assumes that the pipe does not slide relative to the ground.
- The desired accuracy of the fragility model for ground shaking is perhaps not as important as that for permanent ground deformations. This is because the rate of pipeline damage in soils prone to PGDs is often an order of magnitude larger than the rate of pipeline damage in soils not prone to PGDs.
- Regression analyses that use weighted damage data (Figure A-15) show that the best-fit curve through the empirical data has an exponent of 0.99 ($RR = 0.001795 * PGV^{0.99}$), which is essentially linear.
- Bayesian analyses presented in Section G.10 for cast iron pipe with diameters 6" and 8", the most common type, show a linear trend (exponent of 0.9942).

Any method used to fit a fragility function through the pipeline empirical database must deal with the form of the empirical database. Specifically, the empirical database has the following issues that might influence how to fit a fragility function through it:

- The empirical data is expressed in terms of repairs per length of pipeline. Each empirical data point is ideally developed by calculating the actual PGV for each pipe of homogeneous attribute. A homogeneous attribute for a pipe mean that the pipe has the same material, same joinery, same diameter, same lay lengths, same installation method, same age, same corrosion protection system, same level of ground shaking and so on. The repair rate is calculated by adding up the entire length of pipe that experienced the same or nearly the same level of ground motion, adding up all the repairs made to that length of pipe, and taking the ratio = total repairs/total length of pipe with homogeneous attributes.

- For the empirical database presented in Section 4 of Part 1, only pipe repairs from the 1994 Northridge earthquake for the LADWP and the 1989 Loma Prieta earthquake for EBMUD have used rigorous GIS techniques to present the empirical data as homogeneous data points. Even so, the only attributes that the homogeneous data points that were evaluated were pipe barrel material, pipe diameter and level of ground shaking.
- When combining empirical data points using regression analysis, a limitation is that each data point is treated equally in the regression analysis. For example, a data point that represents 2 pipe repairs for 20 km of pipe at PGV = 15 inch/sec is 0.1 ($=2/20$). Another data point that represents 200 pipe repairs for 1,000 km of pipe at PGV = 15 inch/sec is 0.2 ($=200/1,000$). It is obvious that doing a regression analysis that incorporates these two data points should weight the 1,000 km inventory higher than the 20 km inventory; however, standard regression analysis equally weights the data points.

Recognizing these issues, Appendix G introduces an alternative way to fit fragility curves through the empirical data set. The method is called Bayesian Estimation.

Sections G.2 through G.9 use a portion of the entire empirical data set for purposes of sample application of the method. This introduces the following limitations on the results presented in these sections:

1. The empirical data sample is derived for only the Northridge earthquake for the LADWP water system and only for cast iron, ductile iron and asbestos cement type pipes.
2. The empirical data sample uses a different parameter for ground motion than that used in Part 1. Specifically, the data sample in Sections G.2 through G.9 uses the highest of the peak PGV of two horizontal directions, while Part 1 uses mean PGV of two horizontal directions. The differences in these two forms of PGV is about 21%.
3. The empirical data sample excludes known damage to pipelines for cases where the repair records had missing attributes. In other words, it is known that a pipe repair was made, but perhaps the pipe barrel material or the pipe diameter are unknown. This causes an undercount of pipe repairs by about 8%.
4. Section G.10 addresses these limitations by including additional empirical data from the Loma Prieta earthquake and making the necessary adjustments to allow combination of the Northridge and Loma Prieta datasets into one analysis.

G.2 Background

Bayesian methods provide an alternative to statistical analysis of data that can be particularly effective for the assessment of seismic fragility based on field or laboratory observations. This approach has several features, including:

- The possibility of incorporating engineering expert opinion through a prior distribution.
- The ability to handle all types of information, including direct measurements, measurement of bounds, and indirect observations.

- The feasibility of properly and fully accounting for all types of aleatory (meaning random, in the sense of Section E.6) and epistemic (meaning uncertain, in the sense of Section E.6) uncertainties.
- The ease with which parameter estimates can be updated when new data becomes available.

Appendix G describes an application of the Bayesian approach to estimate the mean rate of damage along buried pipes caused by seismic ground shaking. The pipe damage data is the same as presented in Tables A.3-14, A.3-15 and A.3-16, but subdivided by pipe diameter; the data is given in Tables G-1, G-2 and G-3.

The Bayesian approach recognizes that uncertainties are always present in the estimation of parameters. Accordingly, the state of information about a set of parameters is expressed in terms of a probability distribution. The less dispersed this distribution, the more information it conveys about the parameters. As new information becomes available, the distribution is updated and could become more informative. As seen in Part 1, the collection of pipeline damage data across different earthquakes has not yet shown this trend, possibly because of non-homogenous sampling methods.

The Bayesian parameter estimation method is based on the following updating rule:

$$f(\theta) = kL(\theta)p(\theta) \quad [\text{G.1}]$$

which has the following elements:

$\theta = [\theta_1, \theta_2, \dots, \theta_K]^T$ is the vector of parameters to be estimated.

$p(\theta)$ is the prior distribution reflecting our state of knowledge about θ before new data is obtained. This distribution can be based on engineering expert opinion, which is subjective. A non-informative prior should be used if no prior information about the parameters is available.

$L(\theta)$ is the likelihood function and represents the objective information contained in the new data. This function is proportional to the conditional probability of observing the data, given the parameters θ . Specific formulations of this function are given later in this appendix.

$k = \left[\int L(\theta)p(\theta)d\theta \right]^{-1}$ is a normalizing factor.

$f(\theta)$ is the posterior distribution representing our updated state of knowledge about θ . This distribution combines the information contained in the prior, which can be subjective in nature, with the objective information contained in the likelihood.

Once the posterior distribution $f(\theta)$ is determined, the posterior mean vector of the parameters is obtained as:

$$M_\theta = \int \theta f(\theta) d\theta \quad [\text{G.2}]$$

and the posterior mean-square matrix is obtained as:

$$E[\theta\theta^T] = \int (\theta\theta^T) f(\theta) d\theta \quad [G.3]$$

where the superimposed T is the vector transpose. The posterior covariance matrix is computed as:

$$\Sigma_{\theta\theta} = E[\theta\theta^T] - M_{\theta}M_{\theta}^T \quad [G.4]$$

The diagonal elements of $\Sigma_{\theta\theta}$ are the variances σ_i^2 of the parameters, where σ_i denotes the standard deviation of θ_i , and the off-diagonal elements are the covariances $\rho_{ij}\sigma_i\sigma_j$ from which the correlation coefficients ρ_{ij} are obtained after division by the two standard deviations. The coefficient of variation (c.o.v.) of θ_i is defined as $\delta_i = \sigma_i / \mu_i$. The integrals in [G.2] and [G.3] are carried out over the applicable domain of θ . A method for computing these integrals is described in Section G.9.

G.3 Poisson Model for Pipe Damage

It can be conveniently assumed that damage along a length of buried pipe due to ground shaking can be modeled as a homogeneous Poisson process. According to this model, the probability that damage occurs at exactly n points along a pipe of length L is given by:

$$P(n,L) = \frac{(\lambda L)^n}{n!} \exp(-\lambda L), \quad n = 0,1,2,K \quad [G.5]$$

This model has a single parameter λ which is equal to the mean rate of events. Thus, the mean number of damage points along a pipe of length L is given by λL . The objective of the Bayesian analysis is to estimate parameter λ .

G.4 Pipe Damage Data

Tables G-1, G-2 and G-3 present pipeline damage data for cast iron (CI), ductile iron (DI) and asbestos cement (AC) pipe from LADWP for the 1994 Northridge earthquake. Section G-1 presents some limitations to this data that would be required to combine it with data from the other sources presented in this report.

Each data point is for a homogeneous length of pipeline L with diameter D that experienced a range (bin) of peak ground velocity centered on PGV (cm/s) and that experienced n known pipe repairs. Blank entries in the tables indicate that there were no pipes of the specified diameter that were located in an area that experienced ground motion PGV in the specified bin.

The mean rate of damage along a buried pipe may depend on such variables as the intensity of the ground motion, the material of the pipe, the pipe diameter and wall thickness, the depth of soil cover, the lay length of the pipe, the corrosiveness of the soil, the corrosion protection system for the pipe, the number and type of laterals, etc. Determining the mean rate of damage as a function of all these variables would require a large matrix of observed pipe damage data for each set of these variables, which is not available at this time. As a result, the data has to be

“binned” together to make estimates of the mean rate as a function of only a subset of these variables.

The data in Tables G-1 to G-3 is used in the following sections to estimate λ as a function of the PGV for each pipe type. In the case of CI pipes with diameters in the range of 4 to 12 inches, the data is sufficiently rich to allow inferring a dependence of λ on the pipe diameter as well. Note that [Figure A-11](#) using another dataset does not show the same dependence on diameter. For larger diameter CI pipes or for DI and AC pipes, the data is not sufficiently rich to allow inferring the dependence of λ on the pipe diameter.

As is the case with any statistical estimate, the results and conclusions derived in the following analyses are conditioned on the database. If the data is changed or modified, the results and conclusions may also vary.

G.5 Estimation of λ for Cast Iron Pipes

Examination of the data for CI pipes in Table G-1 reveals there is fairly uniform data available for pipe sizes 4 to 12 inches in diameter, except for pipes of 10-inch diameter. Specifically, for these pipe sizes, observations for relatively long pipe segments of tens or hundreds of kilometers have been made. In contrast, the data for pipe sizes 16 to 24 inches in diameter is relatively sparse. If data for all pipe sizes were combined, obviously the smaller pipes with larger data would dominate the result. For this reason, separate analyses for these two ranges of pipe diameters are performed.

G.5.1 Cast Iron Pipes with 4 to 12" Diameter

In order to estimate λ as a function of the PGV and the pipe diameter, an interpolation model is needed. We select the relation:

$$\lambda = a * V^b * D^{-c} \quad [G.6]$$

where V is PGV is in cm/sec and D is the pipe diameter in inches and a , b and c are the parameters to be estimated. Note that by selecting the form of equation [G.6], the Bayesian model assumes that pipe damage increases with increasing PGV and decreases with increasing D ; that is, if parameters b and c are positive. The issue as to whether pipe damage increases with PGV seems to be well-accepted. The issue as to whether pipe damage rate should decrease with increasing D seems to be indicated in some data sets, but not in others. For purposes of Sections G.2 through G.9, the [G.6] model is presented as illustrative of the technique using the particular data sets of Tables G-1, G-2 and G-3, recognizing that the smoothness inferred from this model is not well-represented in the more complete empirical database currently available. Section G.10 examines this issue in more detail.

Using this relation in [G.5], the probability that a pipe of length, L , having diameter, D , will experience n damage points due to a ground motion with PGV equal to V , is given by:

$$P(n, L) = \frac{(aV^b D^{-c} L)^n}{n!} \exp(-aV^b D^{-c} L) \quad [G.7]$$

PGV cm / sec	Pipe Diameter, Inches																	
	4		6		8		10		12		16		18		20		24	
	L	n	L	n	L	n	L	n	L	n	L	n	L	n	L	n	L	n
5	33.8	0	126.5	0	47.5	0	3.7	0	23.3	0	7.8	0	0.2	0	8	0		
15	263.8	7	768.7	24	379.5	5	16.5	0	193	6	32.4	2	2.3	0	32	0	0.8	0
25	387.2	64	878.8	66	574.1	25	30.6	3	263	7	43.8	0	4.4	1	11	0	0.5	0
35	129.5	29	536.9	58	298.5	14	3	0	125	8	19.7	1	0.2	0	5.3	1	1.9	0
45	52.3	24	427.7	22	230.5	9			84.7	4	9.2	0			0.6	0		
55	23.3	18	276	23	140	10			56	5	6.9	0						
65	22.4	15	195.5	45	90.9	18			34.9	7	11.9	2			0.7	0		
75	9.4	6	84.7	21	62	11			19.7	1	2.3	0			0.6	0		
85	10.4	2	72.4	10	42.1	11			8.4	1	3.9	0			2.9	1		
95	8	0	48.2	1	21	1			10.7	0	3	0			1.2	0		
105	9.9	0	53.1	1	23.1	1			7.9	0	1.8	0			0.2	0		
115	9.2	0	47.9	3	22.8	2			4	0	2.4	0			0.4	0		
125	7.5	0	40.4	4	17	1			6.4	1	4.3	0			0.6	0		
135	4.8	0	28.5	0	24.4	2			7.5	0	5	0			1.2	0		
145	3.3	3	33.9	2	19.8	3			4.6	1	2.7	0						
155	3.6	0	30.9	9	15.6	5			6.8	2	2.1	0			0.9	0		
165	4.1	5	32	19	24.8	20			5.4	0								
Total	982.5	173	3682	308	2034	138	53.8	3	861.3	43	159.2	5	7.1	1	65.6	2	3.2	0

Notes

L = length of pipeline in km, within the specified PGV bin

n = number of repairs

See Section G.1 for further description of the data

Table G-1. Cast Iron Pipe Damage, 1994 Northridge Earthquake, LADWP

PGV cm / sec	Pipeline Diameter, Inches											
	4		6		8		12		16		20	
	L	n	L	n	L	n	L	n	L	n	L	n
5	0.9	0	19.9	0	11.6	0	5.3	0	3.4	0	1.1	0
15	2.2	0	53.2	1	32.4	0	21.4	0	4.6	0	2.9	0
25	2.5	1	47.5	5	33	0	8	0	1.7	0		
35	1.3	1	16	0	12.8	1	6.5	0	2.3	0	1.4	0
45	1.7	1	10.8	1	10.6	1	8.4	0	0.7	0		
55	2.1	0	6.2	1	8.5	0	1.3	0	0	0		
65	2.1	0	5.6	3	3.4	1	1.4	0	0.2	0	0.2	0
75	1.3	1	1.7	0	2.3	1	2.3	0				
85	0.3	0	2	1	0.4	0	2.6	0				
95	2.6	0	6.2	0	4.5	0	2.7	0	0.1	1		
105	0.6	0	2.8	0	2.1	0	0.2	0	1.7	0		
115	1.5	0	3.9	0	6.5	0	2.2	1	1.4	0	0.2	0
125	0.8	0	2.5	0	1.3	0	0.7	0			0.6	0
135	0.5	0	2.7	0	0.4	0	0.7	0	0.8	0	0.3	0
145	0.3	0	3.2	0	1.4	0			0.7	0	0.1	0
155			4.3	0	0.1	1	0.7	0	0.3	0		
165			2.6	1			0.7	0				
Total	20.7	4	191.1	13	131.3	5	65.1	1	17.9	1	6.8	0

Notes

L = length of pipeline in km, within the specified PGV bin

n = number of repairs

See Section G.1 for further description of the data

Table G-2. Ductile Iron Pipe Damage, 1994 Northridge Earthquake, LADWP

PGV cm / sec	Pipeline Diameter, Inches									
	4		6		8		10		12	
	L	n	L	n	L	n	L	n	L	n
5	9.5	0	79.3	0	53.4	0			15.1	0
15	14.1	0	180.5	2	88.1	0	1.9	0	23.2	0
25	12.5	6	129.7	7	82.1	2			11.2	0
35	8	0	73.2	1	32.2	1			4.3	0
45	1.1	0	22.6	0	13.1	0			1	0
55	2.8	0	25.1	0	5.4	0			0.7	0
65	2.6	7	17.6	0	3.9	0			0.2	0
75	2.4	0	7	0	1.5	0				
85	0.7	0	2.1	0	0.1	0				
95	0.3	0	0.9	0						
105	0.5	0	3.2	0	1.2	0				
115	0.2	0	1	0	0.4	0				
125	0.3	0	3.4	0	0.1	0				
135	0.6	0	5.5	0	1.1	0				
145	0.2	0	3	0	1.8	0				
155	0.5	0	3.4	0	1.9	0				
165	0.1	0	2.6	0	0.9	0				
Total	56.4	13	560.1	10	287.2	3	1.9	0	55.7	0

Notes

L = length of pipeline in km, within the specified PGV bin

n = number of repairs

See Section G.1 for further description of the data

Table G-3. Asbestos Cement Pipe Damage, 1994 Northridge Earthquake, LADWP

As mentioned earlier, the likelihood function is proportional to the conditional probability of the data, given the set of parameters. The data in this case consists of observations V_i , D_i , L_i and n_i , $i = 1, K, N$, as listed in Table G-1 for the considered pipe sizes. Assuming statistical independence between the observations and using [G.7], the likelihood function takes the form:

$$L(a, b, c) = \prod_{i=1}^N \left[\frac{(aV_i^b D_i^{-c} L_i)^{n_i}}{n_i!} \exp(-aV_i^b D_i^{-c} L_i) \right] \quad [G.8]$$

For Bayesian updating analysis, a prior distribution needs to be selected. If prior information on the parameters were available, it would be included through this distribution. For purposes of Appendix G, we use a non-informative prior, which for the case of positive-valued parameters, is proportional to their reciprocals [see Box and Tiao 1992], i.e.,:

$$p(a, b, c) \propto 1/abc \quad [G.9]$$

With the likelihood function and the prior distribution formulated, the Bayesian analysis is carried out by use of the updating rule in [G.1]. Once the posterior density is determined, the posterior means, standard deviations and correlation coefficients are computed using [G.2]-[G.4]. Sections G.9 and G.11 describes the computational method used for this purpose.

Table G-4 lists the posterior means, standard deviations and correlation coefficients of the model parameters obtained for this case. These are computed with an accuracy of 5% c.o.v. in the estimated means (see Section G.9). It is important to note that these parameter estimates are for the units indicated in parenthesis in the title of the table.

Parameter	μ_i	σ_i	ρ_{ij}		
			a	b	c
a	0.0631	0.0205	1.000	-0.640	0.720
b	0.8424	0.0547	-0.640	1.000	0.021
c	1.4568	0.1378	0.720	0.021	1.000

Table G-4. Posterior statistics of parameters a , b and c for CI pipes of diameter 4 to 12 inches (for V in cm/s, D in inches, and λ per km^{-1}).

With the posterior statistics of the parameters available, we can now estimate the mean and coefficient of variation of λ . Using first-order approximations [Ang and Tang 1975], the mean of λ is given by:

$$\mu_\lambda \cong \mu_a V^{\mu_b} D^{-\mu_c} \quad [G.10]$$

and its c.o.v., δ_λ , is given by:

$$\begin{aligned}
\delta_\lambda^2 &\cong \frac{1}{\mu_\lambda^2} \sum_i \sum_j \frac{\partial \lambda}{\partial \theta_i} \frac{\partial \lambda}{\partial \theta_j} \rho_{ij} \sigma_i \sigma_j \\
&= \delta_a^2 + (\ln V)^2 \sigma_b^2 + (\ln D)^2 \sigma_c^2 \\
&\quad + 2(\ln V) \delta_a \sigma_b \rho_{ab} - 2(\ln D) \delta_a \sigma_c \rho_{ac} - 2(\ln V)(\ln D) \sigma_b \sigma_c \rho_{bc}
\end{aligned} \tag{G.11}$$

These values are plotted in [Figures G-1](#) and [G-2](#) (solid curves) as functions of the PGV (in in/sec) for different diameter pipes. The estimates for the mean are multiplied by 0.3048 to find the mean rate of damage per 1,000 ft of pipe.

It is noted in Figure G-1 that for these pipes the mean rate of damage is strongly influenced by the pipe diameter. The mean rate of damage shows a steady increase with the PGV for all pipe sizes. The c.o.v. of λ , which is a measure of the epistemic uncertainty in measuring the mean rate of damage, is of the order of 10-15%. Note that the percent difference between the estimated mean rates for different pipe sizes is much greater than the estimated c.o.v., which would appear to justify the use of the pipe diameter as a variable for estimating λ , at least for this data set, even though other datasets do not seem to support this hypothesis; for an example, see Figure A-11.

G.5.2 Cast Iron Pipes with 16 to 24" Diameter

For this group of pipes, the data in Table G-1 is rather sparse. Analysis with the three-parameter formula in [G.6] leads to results that cannot be justified. Specifically, the percent difference between estimates of the mean rate of damage for different pipe sizes is smaller than the estimated c.o.v. of λ . This implies that, based on the present data, the differentiation of the pipe sizes is not justified. Therefore, for these pipes the two-parameter formula is used:

$$\lambda = aV^b \tag{G.12}$$

where a , b are the parameters to be estimated. The likelihood function in this case takes the form:

$$L(a,b) = \prod_{i=1}^N \left[\frac{(aV_i^b L_i)^{n_i}}{n_i!} \exp(-aV_i^b L_i) \right] \tag{G.13}$$

And select the non-informative prior:

$$p(a,b) \propto \frac{1}{ab} \tag{G.14}$$

Table G-5 lists the posterior means, standard deviations and correlation coefficients of the model parameters for this case. These are estimated with an accuracy of 5% or less c.o.v. of the estimated means. Note again that these parameter estimates are valid for the units indicated in parenthesis in the title of the table.

Parameter	μ_i	σ_i	ρ_{ij}	
			a	b
a	0.0230	0.0139	1.000	-0.686
b	0.1658	0.2270	-0.686	1.00

Table G-5. Posterior statistics of parameters a and b for CI pipes of diameter 16 to 24 inches (for V in cm/s and λ per km^{-1}).

The mean and c.o.v. of λ are computed, based on first-order approximations, from:

$$\mu_\lambda \cong \mu_a V^{\mu_b} \quad [\text{G.15}]$$

$$\delta_\lambda^2 \cong \delta_a^2 + (\ln V)^2 \sigma_b^2 + 2(\ln V) \delta_a \sigma_b \rho_{ab} \quad [\text{G.16}]$$

The results are shown in Figures G-1 and G-2, respectively, as dashed lines. The c.o.v. of λ is around 50% to 90%, indicating a high level of epistemic uncertainty in the estimation. This could be due to the sparseness of the data for this range of pipe sizes or other unknown factors. It is noted that the mean of λ only mildly increases with the PGV for this type of pipe.

G.6 Estimation of λ for Ductile Iron Pipes

The data for DI pipes in Table G-2 is rather sparse for all pipe sizes and use of the three-parameter formula [G.6] cannot be justified. Instead, the two-parameter formula in [G.12] is used with $\theta = (a, b)$ as the set of parameters. Table G-6 lists the posterior statistics of the parameters.

Parameter	μ_i	σ_i	ρ_{ij}	
			a	b
a	0.0073	0.0071	1.000	-0.840
b	0.6770	0.2510	-0.840	1.00

Table G-6. Posterior statistics of parameters a and b for DI pipes (for V in cm/s and λ per km^{-1})

The mean and c.o.v. of λ are computed by use of [G.15] and [G.16]. These are plotted in [Figures G-3](#) and [G-4](#), respectively, as functions of the PGV (in in/sec). The estimates for the mean are multiplied by 0.3048 to find the mean rate of damage per 1,000 ft of pipe. The c.o.v. of λ is around 50% to 70%, signifying a large epistemic uncertainty in the estimation. This could be due to the sparseness of the data for the DI pipes or other factors. A rapid increase in the mean of λ with the PGV is observed in Figure G-3.

G.7 Estimation of λ for Asbestos Cement Pipes

The data for AC pipes in Table G-3 is rather sparse for all pipe sizes use of the three-parameter formula [G.6] cannot be justified. Instead, the two-parameter formula in [G.12] is used with $\theta = (a, b)$ as the set of parameters. Table G-7 lists the posterior statistics of the parameters.

Parameter	μ_i	σ_i	ρ_{ij}	
			A	b
a	0.0044	0.0038	1.000	-0.860
b	0.6625	0.2477	-0.860	1.00

Table G-7. Posterior statistics of parameters a and b for AC pipes
(for V in cm/s and λ per km^{-1})

The mean and c.o.v. of λ are computed by use of [G.15] and [G.16]. These are plotted in [Figures G-5](#) and [G-6](#), respectively, as functions of the PGV (in in/sec). The estimates for the mean are multiplied by 0.3048 to find the mean rate of damage per 1,000 feet of pipe. The c.o.v. of λ is around 45% to 65%, signifying a large epistemic uncertainty in the estimation. This might be due to the sparseness of the data for the AC pipes or other factors. The mean of λ shows a rapid increase with the PGV in Figure G-5.

G.8 Comparison of Results for Different Pipe Materials

[Figures G-7](#) and [G-8](#) compare the mean and c.o.v. estimates of λ for all the pipes, respectively. Solid lines are for CI pipes of different diameter, as indicated, dotted lines are for the DI pipes with 4 to 20" diameter, and dashed lines are for AC pipes with 4 to 12" diameter. It is clear from Figure G-8 that the estimation is most accurate for the CI pipes with 4 to 12" diameter, for which a large amount of data is available. The estimates for the CI pipes with 16 to 24" diameter and for the DI and AC pipes are much more uncertain.

The mean estimates in Figure G-1 indicate that large-diameter CI pipes and AC pipes have the lowest mean damage rates. However, this conclusion should be used with caution, particularly for AC pipes, because of the large epistemic uncertainty present in the estimation. Further data collection can help reduce this uncertainty.

If and when new data becomes available, the posterior statistics obtained in Appendix E can be used to formulate a prior distribution for the parameters. The updating procedure can then be used to derive posterior statistics of the parameters that incorporate the information gained from the new data.

G.9 Integration by Importance Sampling

Determination of the normalizing factor in the Bayesian updating rule [G.1] and the posterior statistics in [G.2] and [G.3] require multi-dimensional integral calculations. Conventional numerical integration methods may not be effective for more than two parameters. Section G.9 presents a method for evaluation of these integrals by importance sampling that is effective for any number of parameters. Section G.11 provides computation routines to apply this method.

The integrals to be computed can all be written in the unified form:

$$I = \int K(\theta)L(\theta)p(\theta) d\theta \quad [\text{G.17}]$$

For $K(\theta) = 1$, the integral yields the reciprocal of the normalizing factor k ; for $K(\theta) = k\theta$, the integral yields the posterior mean vector \mathbf{M}_θ ; and for $K(\theta) = k\theta\theta^T$, the integral yields the posterior mean-square matrix $E[\theta\theta^T]$, from which the posterior covariance matrix is computed as in [G.4]. In the following, the computation of a typical integral is described as in [G.17].

Let $h(\theta)$ denote a suitable sampling probability density function that has a non-zero value within the domain of θ . We can rewrite [G.17] as:

$$I = \int \frac{K(\theta)L(\theta)p(\theta)}{h(\theta)} h(\theta) d\theta$$

$$= E\left[\frac{K(\theta)L(\theta)p(\theta)}{h(\theta)}\right] \quad \text{[G.18]}$$

where $E[\bullet]$ denotes expectation. It is clear that the integral of interest is equal to the mean of $K(\theta)L(\theta)p(\theta)/h(\theta)$ with respect to the sampling density $h(\theta)$. Therefore, a simple method for computing the integral I is:

1. Generate a sample of parameter values θ_i , $i = 1, 2, \dots, N$, according to the probability density function $h(\theta)$.
2. Compute the corresponding values $I_i = K(\theta_i)L(\theta_i)p(\theta_i)/h(\theta_i)$.
3. Compute the sample mean $\bar{I} = \sum_{i=1}^N I_i/N$.
4. As N becomes large, \bar{I} asymptotically approaches the integral I . A measure of accuracy of the computation is given by the c.o.v. of \bar{I} . This is computed as $\delta I/\sqrt{N}$, where δ is the c.o.v. of the sampled values I_i , $i = 1, 2, \dots, N$.

Matlab routines for computing the posterior statistics of the three-parameter model [G.6] are presented in Section G.11. For the sampling density function $h(\theta)$, owing to the non-negativeness of the parameters, a joint lognormal distribution is used. For faster convergence, it is important that the sampling density have a mean vector and a covariance matrix that are close to the posterior mean vector and covariance matrix of the parameters. Since these values are not known in advance, an adaptive approach is used. That is, start with an assumed mean vector and covariance matrix for the sampling density $h(\theta)$ and make a first estimate of the posterior statistics of the parameters. The mean vector and covariance matrix of the sampling density are then replaced by the estimated posterior mean and covariance matrix and the calculation is repeated. This process is continued until sufficiently small c.o.v. values of the estimated posterior mean values are obtained. For numerical stability, it is also important that the normalizing factor k be neither too small nor too large. A scale parameter for the likelihood function is provided in the Matlab code that can be adjusted to control the magnitude of the normalizing factor.

G.10 Updated Bayesian Analyses

The analytical results presented in Sections G.1 through G.8 are based on application of the Bayesian model using data only from the 1994 Northridge earthquake in Tables G-1, G-2 and G-3. To further examine the Bayesian model, the analyses were repeated, this time also using the data from the 1989 Loma Prieta earthquake in Tables A.3-7, A.3-8 and A.3-9.

As described elsewhere in this report, the available empirical datasets from these two earthquakes do not use precisely the same definitions of PGV. The differences are that the Northridge data set uses peak of two horizontal directions versus the Loma Prieta data set, which uses median of two horizontal directions. The Northridge data set excludes 7.9% of main damage (see Section A.3.12).

Table G-8 provides a summary of the computed mean a , b and c values from the updated Bayesian analyses. For small-diameter cast iron pipe, the parameters are for the model in equation G.6. for other entries, the parameters are for the model in equation G.12.

Pipe Material	Diameter	a	b	c
Cast Iron	4-12"	0.0324	0.9942	1.3188
Cast Iron	16-24"	0.0187	0.2454	
Asbestos Cement	4-12"	0.0016	0.8804	
Ductile Iron	4-20"	0.0073	0.677	
Welded Steel	4-30"	0.000213	1.8678	

*Table G-8. Summary of Updated Bayesian Analysis Parameters a, b, c
Units are: (for V in cm/s, D in inches, and λ repairs per km⁻¹)*

Table G-9 compares the updated Bayesian analysis results with those presented elsewhere in this report. The most common pipe material in the empirical dataset is 6- and 8-inch diameter cast iron pipe. The Bayesian analysis assumes an explicit diameter value (D^c) in equation G.6. To make comparisons, this factor is evaluated and the Bayesian 'a' value is adjusted accordingly. The results are in Table G-9. The Bayesian analysis predicts parameter 'b' to be 0.9942, which is essentially unity. By averaging the most common empirical data, the Bayesian analysis would suggest a model of:

$RR = 0.0197 (PGV)^{0.9942}$, with RR = repairs per 1,000 feet and PGV in inches per second.

This model is very similar to that derived using a slightly wider data set using weighted regression, and also very similar to the small diameter cast iron fragility model provided in the main report (Table 4-4, with K1 = 1.0 from Table 4-5).

Pipe Material	Diameter	Adjusted Parameter a	Parameter b	Notes
Cast Iron	6"	0.00234	0.9942	Bayesian, LP+NR
Cast Iron	8"	0.00160	0.9942	Bayesian, LP+NR
Cast iron	Avg 6", 8"	0.00197	0.9942	Bayesian Average, LP+NR
Cast Iron	All diameters	0.00180	0.99	Weighted Regression, Fig A-15, LP+NR
Cast Iron	Up to 12"	0.00187	1.00	Tables 4-4, 4-5

Table G-9. Comparison of Fragility Models for Small-Diameter Cast Iron Pipe

G.11 Matlab Routines

Section G.11 provides the Matlab source code and data input files used to compute the statistics presented in Appendix G.

Posterior2.m: computes the posterior statistics of the parameters for the two-parameter model (CI pipes 16-24" diameter, DI pipes, AC pipes). It calls Loghhood2.m.

Posterior3.m: computes the posterior statistics of the parameters for the three-parameter model (CI pipes 4-12" diameter). It calls Loghhood3.m.

Loghhood2.m: computes the natural logarithm of the likelihood function for the two-parameter model. It calls Data2.m.

Loghhood3.m: computes the natural logarithm of the likelihood function for the three-parameter model. It calls Data3.m.

Data2.m: contains the pipe damage data for the two-parameter model (listed data is for DI pipes).

Data3.m: contains the pipe data for the three-parameter model (listed data is for CI pipes 4-12" diameter).

Note that in Data2.m, the lengths of pipe segments and the number of damage points at each PGV level are combined.

Data_CI_16_24.m: contains the combined data for CI pipes 16-24" diameter.

Data_AC.m: contains the combined data for AC pipes.

To run the Matlab routine for the two-parameter model, do the following:

1. Put all *.m files in a single directory on the path of Matlab.
2. Copy the data file of interest into Data2.m. Right now, Data2.m has the data for DI pipes.
3. Adjust the input parameters in Posterior2.m. Read the heading for guidelines. The parameters are now set for the DI pipes.
4. Issue the command Posterior2 in the Matlab environment.
5. The computation will take quite some time. To do a quick check without high accuracy, change parameter 'nmax' to something small like nmax=1000. The posterior results will

appear on the screen. They will also be stored in the file Results2.mat. Read the guidelines regarding the accuracy of estimation.

To run the program for the 3-parameter model (CI pipes of 4 to 12" diameter), do as above but replace 2 with 3. The Data3.m file now contains the data for the CI pipes with diameter 4 to 12".

Posterior2.m

```

%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%
%
% This program computes the posterior means, standard deviations and
% correlation matrix of the parameters of a 2-parameter model describing
% the mean rate of damage points along a pipe. It uses importance sampling
% to carry out the necessary integrations over the Bayesian kernel. The
% joint lognormal distribution with specified means, standard deviations
% and correlation matrix is used for the sampling distribution. Convergence
% will be faster if these statistics of the sampling distribution are close
% to the corresponding statistics of the posterior distribution that are
% to be computed. The program may be run several times to adjust the
% statistics of the sampling distribution.
%
% For numerical stability, it is important that the normalizing factor
% k in the Bayesian updating formula be neither too small nor too large.
% This factor can be adjusted by scaling the likelihood function. In this
% program this is done by adjusting the "scale" parameter.
%
% Run the program with trial estimates of the means, standard deviation
% and correlation matrix of the sampling density, and of the scale
% parameter. This will give a first estimate of the reciprocal of the
% normalizing factor k and the posterior statistics of the parameters.
% Make sure that the sampling density has sufficiently large standard
% deviations (no smaller than the posterior standard deviations estimated).
% Use the first posterior estimates as the new means, standard deviations
% and correlation matrix of the sampling distribution and adjust the
% scale parameter (decrease it if k is too large, increase it if k is too
% small). Run the program again to obtain a second set of posterior estimates.
% Repeat this process until sufficient accuracy in the posterior estimates
% is achieved.
%
% The accuracy is measured in terms of the coefficients of variation of
% the posterior mean estimates (denoted cov_p_mean in this program).
% A value less than 5% for each element of cov_p_mean is a good level
% of accuracy.
%
% The results of the computation are stored in the file "Results2.mat"
% as follows:
%
%      nmin   minimum number of simulations
%      nmax   maximum number of simulations
%      npar   number of parameters
%      k      normalizing factor in the updating formula
%      p_mean posterior mean vector
%      cov_p_mean c.o.v. of the posterior mean estimates
%      p_st_dev vector of posterior standard deviations
%      p_cov  vector of posterior c.o.v.'s
%      p_cor  posterior correlation matrix
%
%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%
clear

%----- Specify the means, standard deviations and correlation matrix
%----- of the sampling density

```



```

M      = [0.0081;          % mean vector of sampling density
          0.657];

D = [0.01 0.00;          % diagonal matrix of standard deviations of
      0.00 0.30];        % the sampling density

R = [ 1.00 -0.80; % correlation matrix of the sampling density
      -0.80 1.00];

%----- Specify the scale parameter

scale = 20;

%----- Set minimum and maximum number of simulations:

nmin = 50000;
nmax = 200000;

%----- Begin calculations

d = diag(D);           % vector of standard deviations
cov = d ./ M;          % c.o.v.'s
z = sqrt(log(1+(cov).^2)); % zeta parameters of lognormal distribution
LAM = log(M) - 0.5 * (z).^2; % lambda parameters of lognormal dist.
Z = diag(z);           % diagonal matrix of zeta's
S = Z*R*Z;             % covariance matrix of transformed normals
L= chol(S)';          % lower choleski decomposition of S
iS = inv(S);           % inverse of S

%----- Initialize integral values:
I1 = 0;
I2 = 0;
I3 = 0;
I4 = 0;

npar = length(M);     % number of parameters
i_counter = 0;
flag = 1;
constant = 1/( (6.28318531)^(npar/2) * sqrt(det(S)) );

%----- Begin importance sampling:

for i = 1:nmax

    %-- simulate standard normal random variables;
    u = random('Normal',0,1,npar,1);
    theta = exp( LAM + L*u); % simulated lognormal theta's

    %-- define three kernels
    K1 = 1; % this is for computing the normalizing constant k
    K2 = theta; % this is for computing the mean
    K3 = theta*theta'; % this is for computing the mean squares

    %-- compute the scaled likelihood function
    lhood = exp(Loglhood2(theta)+scale);

    %--- compute the prior distribution (non-informative):

```

```

    p = 1/(theta(1)*theta(2));

    %--- compute the sampling probability density
    h = constant * exp(-0.5*(log(theta)-LAM)'*iS*(log(theta)-LAM));
    h = h/(theta(1)*theta(2));

    %--- compute (kernel*likelihood*prior)/sampling-density:
    I1 = I1 + K1*lhhood*p/h;
    I2 = I2 + K2*lhhood*p/h;
    I3 = I3 + K3*lhhood*p/h;

    I4 = I4 + (K2*lhhood*p/h).^2; % this is for computing cov_p_mean

    %--- reciprocal of the normalizing constant
    k = I1/i;

    %--- posterior mean and its c.o.v.
    p_mean = I2/I1;
    cov_p_mean = sqrt(( 1/i*(I4/(k^2*i)-(I2/(k*i)).^2) ))./abs(p_mean);

    %--- posterior covariance matrix
    p_cov = I3/I1 - p_mean*p_mean';

    % check if c.o.v is <= 0.05 for all the posterior means, but
    % make sure that at least nmin simulations are performed.
    % flag = 0 means that convergence has been achieved.
    i_counter = i_counter+1;
    if max(cov_p_mean) <= 0.05 & i_counter>nmin
        flag = 0;
        break
    end
end

%----- display results:
%
disp('--- Number of simulations')
disp(i_counter);

disp('--- Number of parameters')
disp(npar)

disp('=====  
Bayesian Posterior Estimates  
=====')

disp('--- Reciprocal of normalizing factor k')
disp(k);

disp('--- Posterior means')
disp(p_mean');

disp('--- c.o.v.s for the posterior means')
disp(cov_p_mean')

for i=1:npar
    p_st_dev(i) = sqrt(p_cov(i,i));
    p_c_o_v(i) = p_st_dev(i)/abs(p_mean(i));
end
disp('--- Posterior standard deviations')
disp(p_st_dev)

```

```

disp('--- Posterior c.o.v.s')
disp(p_c_o_v)
for i=1:npar
    for j=1:npar
        p_cor(i,j)=p_cov(i,j)/(p_st_dev(i)*p_st_dev(j));
    end
end
disp('--- Posterior correlation matrix')
disp(p_cor);

%--- save results
save Results2 i_counter npar k p_mean cov_p_mean p_st_dev p_c_o_v p_cor

```

Posterior3.m

```

%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%
%
% This program computes the posterior means, standard deviations and
% correlation matrix of the parameters of a 3-parameter model describing
% the mean rate of damage points along a pipe. It uses importance sampling
% to carry out the necessary integrations over the Bayesian kernel. The
% joint lognormal distribution with specified means, standard deviations
% and correlation matrix is used for the sampling distribution.
% Convergence will be faster if these statistics of the sampling
% distribution are close to the corresponding statistics of the
% posterior distribution that are to be computed. The program may be
% run several times to adjust the statistics of the sampling distribution.
%
% For numerical stability, it is important that the normalizing factor
% k in the Bayesian updating formula be neither too small nor too large.
% This factor can be adjusted by scaling the likelihood function. In this
% program this is done by adjusting the "scale" parameter.
%
% Run the program with trial estimates of the means, standard deviation
% and correlation matrix of the sampling density, and of the scale
% parameter. This will give a first estimate of the reciprocal of the
% normalizing factor k and the posterior statistics of the parameters.
% Make sure that the sampling density has sufficiently large standard
% deviations (no smaller than the posterior standard deviations estimated).
% Use the first posterior estimates as the new means, standard deviations
% and correlation matrix of the sampling distribution and adjust the
% scale parameter (decrease it if k is too large, increase it if k is too
% small). Run the program again to obtain a second set of posterior estimates.
% Repeat this process until sufficient accuracy in the posterior estimates
% is achieved.
%
% The accuracy is measured in terms of the coefficients of variation of
% the posterior mean estimates (denoted cov_p_mean in this program).
% A value less than 5% for each element of cov_p_mean is a good level
% of accuracy.
%
% The results of the computation are stored in the file "Results3.mat"
% as follows:
%
%           nmin   minimum number of simulations
%           nmax   maximum number of simulations
%           npar   number of parameters
%           k      normalizing factor in the updating formula

```

```

%      p_mean   posterior mean vector
%      cov_p_mean   c.o.v. of the posterior mean estimates
%      p_st_dev   vector of posterior standard deviations
%      p_cov     vector of posterior c.o.v.'s
%      p_cor     posterior correlation matrix
%
%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%%
clear

%----- Specify the means, standard deviations and correlation matrix
%----- of the sampling density

M      = [0.06;           % mean vector of sampling density
          0.8;
          1.5];

D = [0.03 0.00 0.00;      % diagonal matrix of standard deviations of
      0.00 0.06 0.00;      % the sampling density
      0.00 0.00 0.14];

R = [ 1.00 -0.60  0.70;    % correlation matrix of the sampling density
      -0.60  1.00  0.00;
      0.70  0.00  1.00];

%----- Specify the scale parameter

scale = 310;

%----- Set minimum and maximum number of simulations:

nmin = 50000;
nmax = 200000;

%----- Begin calculations

d = diag(D);           % vector of standard deviations
cov = d ./ M;          % c.o.v.'s
z = sqrt(log(1+(cov).^2)); % zeta parameters of lognormal distribution
LAM = log(M) - 0.5 * (z).^2; % lambda parameters of lognormal dist.
Z = diag(z);           % diagonal matrix of zeta's
S = Z*R*Z;             % covariance matrix of transformed normals
L= chol(S)';          % lower choleski decomposition of S
iS = inv(S);           % inverse of S

%----- Initialize integral values:
I1 = 0;
I2 = 0;
I3 = 0;
I4 = 0;

npar = length(M);      % number of parameters
i_counter = 0;
flag = 1;
constant = 1/( (6.28318531)^(npar/2) * sqrt(det(S)) );

%----- Begin importance sampling:

```

```

for i = 1:nmax

    %-- simulate standard normal random variables;
    u = random('Normal',0,1,npar,1);
    theta = exp( LAM + L*u); % simulated lognormal theta's

    %-- define three kernels
    K1 = 1; % this is for computing the normalizing constant k
    K2 = theta; % this is for computing the mean
    K3 = theta*theta'; % this is for computing the mean squares

    %-- compute the scaled likelihood function
    lhood = exp(Loglhood3(theta)+scale);

    %--- compute the prior distribution (non-informative):
    p = 1/(theta(1)*theta(2)*theta(3));

    %--- compute the sampling probability density
    h = constant * exp(-0.5*(log(theta)-LAM)'*iS*(log(theta)-LAM));
    h = h/(theta(1)*theta(2)*theta(3));

    %--- compute (kernel*likelihood*prior)/sampling-density:
    I1 = I1 + K1*lhood*p/h;
    I2 = I2 + K2*lhood*p/h;
    I3 = I3 + K3*lhood*p/h;

    I4 = I4 + (K2*lhood*p/h).^2; % this is for computing cov_p_mean

    %--- reciprocal of normalizing constant
    k = I1/i;

    %--- posterior mean and its c.o.v.
    p_mean = I2/I1;
    cov_p_mean = sqrt(( 1/i*(I4/(k^2*i)-(I2/(k*i)).^2) ) ./abs(p_mean));

    %--- posterior covariance matrix
    p_cov = I3/I1 - p_mean*p_mean';

    % check if c.o.v is <= 0.05 for all the posterior means, but
    % make sure that at least nmin simulations are performed.
    % flag = 0 means that convergence has been achieved.
    i_counter = i_counter+1;
    if max(cov_p_mean) <= 0.05 & i_counter>nmin
        flag = 0;
        break
    end
end

%----- display results:
%
disp('--- Number of simulations')
disp(i_counter);

disp('--- Number of parameters')
disp(npar)

disp('==== Bayesian Posterior Estimates =====')

```

```

disp('--- Reciprocal of normalizing factor k')
disp(k);

disp('--- Posterior means')
disp(p_mean');

disp('--- c.o.v.s for the posterior means')
disp(cov_p_mean')

for i=1:npar
    p_st_dev(i) = sqrt(p_cov(i,i));
    p_c_o_v(i) = p_st_dev(i)/abs(p_mean(i));
end
disp('--- Posterior standard deviations')
disp(p_st_dev)
disp('--- Posterior c.o.v.s')
disp(p_c_o_v)
for i=1:npar
    for j=1:npar
        p_cor(i,j)=p_cov(i,j)/(p_st_dev(i)*p_st_dev(j));
    end
end
disp('--- Posterior correlation matrix')
disp(p_cor);

%--- save results
save Results3 i_counter npar k p_mean cov_p_mean p_st_dev p_c_o_v p_cor

```

Loglikelihood2.m

```

% FUNCTION STATEMENT
% Loglikelihood2 is a string containing the name of a function that computes
% the logarithm of the likelihood function for the 2-parameter model
% of the mean rate of pipe damage. This function reads the necessary
% data stored in array "x" from the file named "Data2.m".

% ** VARIABLE DESCRIPTION **
% theta = model parameters;
% Loglikelihood2 = logarithm of the likelihood function.

function[Loglikelihood2] = Loglikelihood2(theta)

% load data stored in array x:

Data2

[nobsrv] = size(x);
a = theta(1);
b = theta(2);

% Log-likelihood calculation
Loglikelihood2 = 0;

for i = 1 : nobsrv

    Vi = x(i,1);    % PGV in cm/s
    Li = x(i,2);    % Pipe length in km

```

```

    Ni = x(i,4);    % Number of damage points

    lambdaL = a * (Vi^b) * Li;
    if Ni==0
    LogP = -lambdaL;
    elseif Ni>0
    LogP = Ni*log(lambdaL) - log(factorial(Ni)) - lambdaL;
    end

    Loglikelihood2 = Loglikelihood2 + LogP;

end

                                Loglikelihood3.m

% FUNCTION STATEMENT
% Loglikelihood3 is a string containing the name of a function that computes
% the logarithm of the likelihood function for the 3-parameter model
% of the mean rate of pipe damage. This function reads the necessary
% data stored in array "x" from the file named "Data3.m".

% ** VARIABLE DESCRIPTION **
% theta = model parameters;
% Loglikelihood3 = logarithm of the likelihood function.

function[Loglikelihood3] = Loglikelihood3(theta)

% load data stored in array x:

Data3

[nobsrv] = size(x);
a = theta(1);
b = theta(2);
c = theta(3);

% Log-likelihood calculation
Loglikelihood3 = 0;

for i = 1 : nobsrv

    Vi = x(i,1);    % PGV in cm/s
    Li = x(i,2);    % Pipe length in km
    Di = x(i,3);    % Pipe diameter in inches
    Ni = x(i,4);    % Number of damage points

    lambdaL = a * (Vi^b) * (Di^(-c)) * Li;
    if Ni==0
    LogP = -lambdaL;
    elseif Ni>0
    LogP = Ni*log(lambdaL) - log(factorial(Ni)) - lambdaL;
    end

    Loglikelihood3 = Loglikelihood3 + LogP;

end

```

Data2.m

```
% This file contains failure data on pipes damaged in past earthquakes.
% This data is for Ductile Iron pipes and was collected by O'Rourke
% and Jeon after the Northridge 1994 earthquake.
%
% V = Peak Ground Velocity, cm/s
% L = Pipe segment length, km
% D = Range of pipe diameters (not used in the calculation)
% N = Number of damage points in the pipe segment.

%      V      L      D      N
x = [ 5      42.2   420   0;
      15     116.7   420   1;
      25     92.7   420   6;
      35     40.3   420   2;
      45     32.2   420   3;
      55     18.1   420   1;
      65     12.8   420   4;
      75      7.5   420   2;
      85      5.3   420   1;
      95     16.1   420   1;
     105      7.4   420   0;
     115     15.6   420   1;
     125      5.8   420   0;
     135      5.4   420   0;
     145      5.7   420   0;
     155      5.4   420   1;
     165      3.3   420   1];
```


Data3.m

```

% This file contains failure data on pipes damaged in past earthquakes.
% and Jeon after the Northridge 1994 earthquake.
% This data is for Cast Iron pipes with diameters 4-12 inches.
%
% V = Peak Ground Velocity, cm/s
% L = Pipe segment length, km
% D = Pipe diameter, in
% N = Number of damage points in the pipe segment.
%
%      V      L      D  N
x = [ 5      33.8    4  0;
      15     263.8    4  7;
      25     387.2    4 64;
      35     129.5    4 29;
      45      52.3    4 24;
      55      23.3    4 18;
      65      22.4    4 15;
      75       9.4     4  6;
      85      10.4    4  2;
      95       8.0     4  0;
     105      9.9     4  0;
     115      9.2     4  0;
     125      7.5     4  0;
     135      4.8     4  0;
     145      3.3     4  4;
     155      3.6     4  0;
     165      4.1     4  5;
      5     126.5     6  0;
     15     768.7     6 24;
     25     878.8     6 66;
     35     536.9     6 58;
     45     427.7     6 22;
     55     276.0     6 23;
     65     195.5     6 45;
     75      84.7     6 21;
     85      72.4     6 10;
     95      48.2     6  1;
    105      53.1     6  1;
    115      47.7     6  3;
    125      40.4     6  4;
    135      28.5     6  0;
    145      33.9     6  2;
    155      30.9     6  9;
    165      32.0     6 19;
      5      47.5     8  0;
     15     379.5     8  5;
     25     574.1     8 25;
     35     298.5     8 14;
     45     230.5     8  9;
     55     140.0     8 10;
     65      90.9     8 18;
     75      62.0     8 11;
     85      42.1     8 11;
     95      21.0     8  1;
    105      23.1     8  1;

```

```

115 22.8 8 2;
125 17.0 8 1;
135 24.4 8 2;
145 19.8 8 3;
155 15.6 8 5;
165 24.8 8 20;
5 3.7 10 0;
15 16.5 10 0;
25 30.6 10 3;
35 3.0 10 0;
5 23.3 12 0;
15 193.0 12 6;
25 263.0 12 7;
35 125.0 12 8;
45 84.7 12 4;
55 56.0 12 5;
65 34.9 12 7;
75 19.7 12 1;
85 8.4 12 1;
95 10.7 12 0;
105 7.9 12 0;
115 4.0 12 0;
125 6.4 12 1;
135 7.5 12 0;
145 4.6 12 1;
155 6.8 12 2;
165 5.4 12 0];

```

Data_AC.m

```

% This file contains failure data on pipes damaged in past earthquakes.
% This data is for Asbestos Cement pipes and was collected by O'Rourke
% and Jeon after the Northridge 1994 earthquake.
%
% V = Peak Ground Velocity, cm/s
% L = Pipe segment length, km
% D = Range of pipe diameters, in (not used in the analysis)
% N = Number of damage points in the pipe segment.
%
%      V      L      D      N
x = [ 5    157.3  412  0;
      15   307.9  412  2;
      25   235.5  412 15;
      35   117.7  412  2;
      45    37.8  412  0;
      55    34.1  412  0;
      65    24.4  412  7;
      75    10.9  412  0;
      85     3.0  412  0;
      95     1.2  412  0;
     105     4.8  412  0;
     115     1.6  412  0;
     125     3.9  412  0;
     135     7.2  412  0;
     145     5.0  412  0;
     155     5.8  412  0;
     165     3.5  412  0];

```

Data_CI_16_24.m

```
% This file contains failure data on pipes damaged in past earthquakes.
% This data is for Cast Iron pipes and was collected by O'Rourke
% and Jeon after the Northridge 1994 earthquake.
%
% V = Peak Ground Velocity, cm/s
% L = Pipe segment length, km
% D = Range of pipe diameters, in (not used in the analysis)
% N = Number of damage points in the pipe segment.
%
%      V      L      D      N
x = [ 5      15.9    1624    0;
      15     67.6    1624    2;
      25     59.8    1624    1;
      35     27.2    1624    2;
      45      9.8    1624    0;
      55      6.9    1624    0;
      65     12.6    1624    2;
      75      2.8    1624    0;
      85      6.8    1624    1;
      95      4.3    1624    0;
     105     2.0    1624    0;
     115     2.9    1624    0;
     125     4.9    1624    0;
     135     6.2    1624    0;
     145     2.7    1624    0;
     155     2.9    1624    0;
     165     0.0
```

G.12 References

Ang, A. H-S., and W-H. Tang. *Probability concepts in engineering planning and design, Vol. I - Basic Principles*. John Wiley & Sons, New York, N.Y, 1975.

Box, G.E.P., and Tiao, G.C. *Bayesian Inference in Statistical Analysis*, Addison-Wesley, Reading, Mass, 1992.

G.13 Figures




Figure G-1. Mean of λ for CI Pipes




Figure G-2. Coefficient of Variation of λ for CI Pipes




Figure G-3. Mean of λ for DI Pipes




Figure G-4. Coefficient of Variation of λ for DI Pipes




Figure G-5. Mean of λ for AC Pipes




Figure G-6. Coefficient of Variation of λ for AC Pipes




Figure G-7. Comparison of Mean of λ for Pipes of Different Materials and Diameter




Figure G-8. Comparison of C.O.V. of λ for Pipes of Different Materials and Diameter