



Photo 17 - Medical gases in unsecured cylinders  
*These require restraints to prevent them from toppling in earthquakes.*



Photo 18 - Staircase in the Hospital  
Note the irregularities in the heights of adjacent steps.  
This is dangerous, especially in a hospital.