



Photo 33 - Blood Bank  
Unrestrained gas cylinder is vulnerable to toppling in the event of an earthquake.

<<<<<<<<<  
<<<<<<<<<



Photo 34 - Wash Room  
High-level equipment vulnerable to toppling in the event of an earthquake.