







37. Loose items, and especially those containing dangerous substances, such as these gas bottles, should be effectively secured and preferably stored away from critical gear such as this sub-station panel.



38. Shelving should be securely fixed to walls and provided with lips (as lower shelves here) to prevent objects from toppling/rolling off.



39. Poor drainage near the Chest Wi.



40. The main stormwater outfall on the western side of the compound is impeded by tree branches and hospital debris - linen, broken bottles, etc.